

UNITED STATES
NUCLEAR REGULATORY COMMISSION
OFFICE OF INSPECTION AND ENFORCEMENT
REGION III
799 ROOSEVELT ROAD
GLEN ELLYN, ILLINOIS 60137

50-249
Aug 21, 1975

A. IE Inspection Report No. _____

Transmittal Date : _____

Distribution:
IE Chief, FS&EB
IE:HQ (5)
DR Central Files
Regulatory Standards (3)
Licensing (13)
IE Files

Distribution:
IE Chief, FS&EB
IE:HQ (4)
L:D/D for Fuels & Materials
DR Central Files
IE Files
IE Chief, M&PPB
L:D/D for Reactor Project

B. IE Inquiry Report No. _____

Transmittal Date : _____

Distribution:
IE Chief, FS&EB
IE:HQ (5)
DR Central Files
Regulatory Standards (3)
Licensing (13)
IE Files

Distribution:
IE Chief, FS&EB
IE:HQ
DR Central Files
IE Files

C. Incident Notification From: Commonwealth Edison Company 50-249
(Licensee & Docket No. (or License No.))

Transmittal Date : August 21, 1975 Dresden Station Unit 3

Distribution:
IE Chief, FS&EB
IE:HQ (4)
Licensing (4)
DR Central Files
IE Files

Distribution:
IE Chief, FS&EB
IE:HQ (4)
L:D/D for Fuels & Materials
DR Central Files
IE Files



A O & I
3

Directorate of Regulatory Operations
Region III
U.S. Nuclear Regulatory Commission
799 Roosevelt Road
Glen Ellyn, IL 60137

Telecopied YES 8-8-75
or
Telegraphed: GE 1:57
DC
DY YC

cc:
J. P. O'Leary, Director
Directorate of Licensing
U.S. Nuclear Regulatory Commission
Washington, D.C. 20555

SUBJECT: DPA-25, Dresden Nuclear Power Station, Unit 3.

This will confirm a conversation with Mr. P. Johnson of
your office at 1330 hrs this date concerning Failure of Cool.
Condenser Condensate High Flow switches.
3-1349 A and 3-1349 B to Trip within the
Technical Specification Limits. This was
Apparently the result of the instrument
setpoint shift. Switches were immedi-
ately reset to correct setpoints. The
Rx is subcritical < 212°F.

To Call:

GE - 5-858-2660x16 (auto)
DC - 9-1-301-492-7617 (auto) - cn 6
WD - 815-942-4449/4321

Station Dist: Originator (copy)
Incident File (copy)
Telegram File (original)

B. B. Stephenson, Superintendent
Dresden Nuclear Power Station
Commonwealth Edison Company
R.R. #1
Morris, IL 60450

Telephone: 815-942-2928/2921x212
(telecopy x262)

Rec'd 2:09 8/8/75 JCU