



ROCHESTER GAS AND ELECTRIC CORPORATION • 89 EAST AVENUE, ROCHESTER, N.Y. 14649-0001

ROGER W. KOBER  
VICE PRESIDENT  
ELECTRIC & STEAM PRODUCTION

TELEPHONE  
AREA CODE 716 546-2700

October 9, 1985

Mr. Harold R. Denton  
Director  
Office of Nuclear Reactor Regulation  
U.S. Nuclear Regulatory Commission  
Washington, D.C. 20555


Re: Rochester Gas and Electric Corporation,  
R.E. Ginna Nuclear Power Plant  
Docket No. 50-244

Dear Mr. Denton:

Enclosed are:


1. Three (3) originals and nineteen (19) copies of an Application for Amendment to Operating License to amend Appendix A of that license to delete the requirement for operation of the auxiliary building ventilation and charcoal filter absorber system when the fuel being moved or stored in the spent fuel storage pool had decayed at least 60 days since irradiation.
2. Forty (40) copies of documents designated Attachments A and B which set forth the requested change in Technical Specifications, its safety evaluation, and the basis for determining that the change does not involve a significant hazards consideration, and
3. A check for \$150 in accordance with 10 CFR 170.12.

Very truly yours,

  
Roger W. Kober

Enclosures

xc: Mr. Jay Dunkleberger,  
New York State Energy Office



Rec'd w/check \$150.00  
# 319075

A001  
11

