

UNITED STATES OF AMERICA
NUCLEAR REGULATORY COMMISSION

In the Matter of)
)
Rochester Gas and Electric Corporation) Docket No. 50-244
(R. E. Ginna Nuclear Power Plant))

APPLICATION FOR AMENDMENT
TO OPERATING LICENSE

Pursuant to Section 50.90 of the regulations of the U.S. Nuclear Regulatory Commission (the "Commission"), Rochester Gas and Electric Corporation ("RG&E"), holder of Facility Operating License No. DPR-18, hereby requests that the Technical Specifications set forth in Appendix A to that license be amended. This request for a change to the Technical Specification is submitted in order to delete the requirement for operation of the spent fuel pit charcoal filter absorber and ventilation systems when moving fuel that has decayed at least 60 days since irradiation.

The proposed technical specification change is set forth in Attachment B to this Application. A safety evaluation is set forth in Attachment B and a no significant hazards evaluation is at Attachment C. This evaluation demonstrates that the proposed change does not involve a significant change in the types or a significant increase in the amounts of effluents or any change in the authorized power level of the facility.

8510220278 851009
PDR ADOCK 05000244
P PDR

WHEREFORE, Applicant respectfully requests that Appendix A to Facility Operating License No. DPR-18 be amended in the form attached hereto as Attachment A.

Rochester Gas and Electric Corporation

By Roger W. Kober
Roger W. Kober
Vice President,
Electric and Steam Production

Subscribed and sworn to before me
on this 9th day of October 1985

Ryan J. Hauck

Notary Public, State of N.Y., Monroe County
My Commission Expires March 30, 1986