

# REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION: N9R:8111040313, DOC. DATE: 81/10/30 NOTARIZED: NO DOCKET #  
 FACIL: 50-244 Robert Emmet Ginna Nuclear Plant, Unit 1, Rochester G. 05000244  
 AUTH. NAME: MAIER, J. E. AUTHOR AFFILIATION: Rochester Gas & Electric Corp.  
 RECIP. NAME: CRUTCHFIELD, D. RECIPIENT AFFILIATION: Operating Reactors Branch 5.

SUBJECT: Informs of withdrawal of 761108 request for underfrequency trip setpoint reduction based on discovery that proposed change no longer required for coordination w/Northeast Power Coordinating Council requirements.

DISTRIBUTION CODE: A0015 COPIES RECEIVED: LTR 1 ENCL 0 SIZE: 1 / 1 / 1  
 TITLE: General Distribution for after Issuance of Operating License

NOTES: 1 copy: SEP Sect. Ldr. 05000244

ACTION:	RECIPIENT ID CODE/NAME		COPIES		RECIPIENT ID CODE/NAME		COPIES	
			LTR	ENCL			LTR	ENCL
ACTION:	ORR #5 BCI	01.	13	13				
INTERNAL:	ELO		1	0	I&E	06	2	2
	NRR/DHFS DEPY08		1	1	NRR/DL DIR		1	1
	NRR/DL/DRAB		1	0	NRR/DSI/RAB		1	1
	<u>RES. FILE</u>	04	1	1				
EXTERNAL:	ACRS	09	16	16	LPDR	03	1	1
	NRC PDRI	02	1	1	NSIC	05	1	1
	NTIS		1	1				

NOV 06 1981

TOTAL NUMBER OF COPIES REQUIRED: LTR

42 ENCL 34






ROCHESTER GAS AND ELECTRIC CORPORATION • 89 EAST AVENUE, ROCHESTER, N.Y. 14649

JOHN E. MAIER  
VICE PRESIDENT

TELEPHONE  
AREA CODE 716 546-2700



October 30, 1981



Director of Nuclear Reactor Regulation  
Attention: Mr. Dennis M. Crutchfield, Chief  
Operating Reactors Branch No. 5  
U.S. Nuclear Regulatory Commission  
Washington, D.C. 20555

Subject: Reduction of Underfrequency Scram Setpoint  
R.E. Ginna Nuclear Power Plant  
Docket No. 50-244

Dear Mr. Crutchfield:

By letter dated November 8, 1976, we submitted a request for underfrequency trip setpoint reduction. The proposal was prepared in order to achieve coordination with the Northeast Power Coordinating Council (NPCC) guidelines. Following a telephone call with members of your Staff on July 20, 1981 and receipt of your letter dated July 23, 1981, we reevaluated our need for this change. We have found that the proposed change is no longer required for coordination with NPCC guidelines. Therefore, we withdraw our request for change in underfrequency trip setpoint.

Very truly yours,

*John E. Maier*  
John E. Maier

*Acc'd  
S/10*

