

REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR: 8202090246 DOC. DATE: 82/02/01 NOTARIZED: YES DOCKET #  
 FACIL: 50-244 Robert Emmet Ginna Nuclear Plant, Unit 1, Rochester G 05000244  
 AUTH. NAME AUTHOR AFFILIATION  
 MAIER, J. E. Rochester Gas & Electric Corp.  
 RECIP. NAME RECIPIENT AFFILIATION  
 EISENHUT, D. G. Division of Licensing

SUBJECT: Forwards response to 801222 ltr re NUREG 0612 "Control of Heavy Loads." Response identifies extent to which facility conforms to Section 2.1, "General Requirements for Overhead Handling Sys."

DISTRIBUTION CODE: A033S COPIES RECEIVED: LTR 1 ENCL 3 *on shelf 73* SIZE: *73*  
 TITLE: Control of Heavy Loads Near Spent Fuel (USI A-36) Operating Reactor

NOTES: 1 copy: SEP Sect. Ldr.

05000244

ACTION:	RECIPIENT ID CODE/NAME		COPIES		RECIPIENT ID CODE/NAME		COPIES	
			LTTR	ENCL			LTTR	ENCL
ACTION:	ORB #5 BC		7	7	NRR CLEMENSON01		4	4
INTERNAL:	IE	07	2	2	NRR REQUA, G	09	1	1
	NRR/DL/ORAB	12	1	1	NRR/DSI/ADCCS11		1	1
	NRR/DSI/AEB		1	1	NRR/DSI/RAB	10	1	1
	<u>REG FILE</u>	04	1	1				
EXTERNAL:	ACRS	13	10	10	LPDR	03	1	1
	NRC PDR	02	1	1	NSIC	06	1	1
	NTIS		1	1				

TOTAL NUMBER OF COPIES REQUIRED: LTTR

34


34 ENCL

34

34

*Do*





ROCHESTER GAS AND ELECTRIC CORPORATION • 89 EAST AVENUE, ROCHESTER, N.Y. 14649

JOHN E. MAIER  
Vice President

TELEPHONE  
AREA CODE 716 546-2700

February 1, 1982

Mr. Darrell G. Eisenhut, Director  
U.S. Nuclear Regulatory Commission  
Division of Licensing  
Washington, D.C. 20555



SUBJECT: "Control of Heavy Loads"  
Response to Section 2.1,  
"General Requirements For Overhead Handling Systems"

Dear Mr. Eisenhut:

Enclosed please find our response to your letter of December 22, 1980, "Control of Heavy Loads". This response concerns Section 2.1 of said letter, General Requirements For Overhead Handling Systems.

Sincerely,

*John E. Maier*  
J. E. Maier

Subscribed and sworn to me  
on this *1st* day of February 1982

*Sharon G. Cavalieri*

SHARON G. CAVALIERI  
NOTARY PUBLIC, State of N. Y., Monroe County  
My Commission Expires March 30, 1983

*A033  
5 1/3 on shelf*

8202090246 820201  
PDR ADCK 05000244  
PDR




NUREG 0612 CONTROL OF HEAVY LOADS

LIST OF COMMITMENTS (6 MONTH REPORT)

1. SPECIAL LIFTING DEVICES - COMPARISON ANALYSIS DONE TO DETERMINE EXTENT OF COMPLIANCE WITH ANSI N14.6-1978 (WESTINGHOUSE ELECTRIC CORPORATION, \$30,317).
2. OVERHEAD HANDLING SYSTEM STUDIES TO DETERMINE LOAD WEIGHT AND HEIGHT RESTRICTIONS IN CERTAIN AREAS FOR THE FOLLOWING:
  - 1) RHR Basement Monorail
  - 2) Containment 100(20) Ton Overhead Crane
  - 3) 10 Ton Jib in Containment
  - 4) 1 Ton Jib (E), 1 Ton Jib (W); Containment
  - 5) 3 Ton Jib, 2 Ton Jib; Containment
  - 6) Turbine Hall 125(25) Ton Overhead Crane
  - 7) Intermediate Bldg. Monorail (Upper Level)
3. ANALYSIS AND MODIFICATIONS REQUIRED TO INSURE COMPLIANCE OF ALL MONORAIL SYSTEMS LISTED IN THIS REPORT WITH ANSI B30.11-1980, "MONORAILS AND UNDERHUNG CRANES"
4. ADMINISTRATIVE CONTROL AND PROCEDURE DEVELOPMENT.
5. ESTIMATED ANALYTICAL COSTS 80 - 100K

RG&E ENGINEERING & MODIFICATIONS - \$10,000

RG&E ENGINEERING



1944

1944

1944

1944