

CONTROL BLOCK:                      (1)

(PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

0 1 N Y R E G I 2 0 0 - 0 0 0 0 0 - 0 0 3 4 1 1 1 1 4 5  
7 8 9 LICENSEE CODE 14 15 LICENSE NUMBER 25 26 LICENSE TYPE 30 57 CAT 58

CON'T  
0 1 REPORT SOURCE L 6 0 5 0 0 0 2 4 4 7 1 0 0 9 7 9 8 1 1 0 7 7 9 9  
7 8 60 61 DOCKET NUMBER 68 69 EVENT DATE 74 75 REPORT DATE 80

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

0 2 During snubber inspection snubber in position MS 146 (top) was found with no  
0 3 accumulator level. Unit was replaced with a new factory tested spare.  
0 4 (T.S. 3.13.1)  
0 5  
0 6  
0 7  
0 8

0 9 SYSTEM CODE H B 11 CAUSE CODE E 12 CAUSE SUBCODE B 13 COMPONENT CODE S U P P O R T 14 COMP. SUBCODE D 15 VALVE SUBCODE Z 16  
7 8 9 10 11 12 13 18 19 20  
17 LER/RO REPORT NUMBER 7 9 21 22 23 SEQUENTIAL REPORT NO. 0 2 0 24 26 27 OCCURRENCE CODE 0 3 28 29 REPORT TYPE L 30 31 REVISION NO. 0 32  
ACTION TAKEN C 18 FUTURE ACTION Z 19 EFFECT ON PLANT Z 20 SHUTDOWN METHOD Z 21 HOURS 0 0 0 0 22 ATTACHMENT SUBMITTED N 23 NPSR-4 FORM SUB. Y 24 PRIME COMP. SUPPLIER A 25 COMPONENT MANUFACTURER B 2 0 9 26  
33 34 35 36 37 40 41 42 43 44 47

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

1 0 Constant movement of pipe resulted in wear on accumulator, tube, piston, shaft,  
1 1 check valves and eventual failure of the shaft seal. The unit is a Bergen-Paterson  
1 2 model HSSA-30. Inspection of snubbers will continue as dictated by the Technical  
1 3 Specification.  
1 4

1 5 FACILITY STATUS E 28 % POWER 1 0 0 29 OTHER STATUS NA 30 METHOD OF DISCOVERY B 31 DISCOVERY DESCRIPTION Surveillance of snubbers 32  
7 8 9 10 12 13 44 45 46 80

1 6 ACTIVITY CONTENT Z 33 RELEASED OF RELEASE Z 34 AMOUNT OF ACTIVITY NA 35 LOCATION OF RELEASE NA 36  
7 8 9 10 11 44 45 80

1 7 PERSONNEL EXPOSURES NUMBER 0 0 0 37 TYPE Z 38 DESCRIPTION NA 39  
7 8 9 10 11 12 13 80

1 8 PERSONNEL INJURIES NUMBER 0 0 0 40 DESCRIPTION NA 41  
7 8 9 10 11 12 80

1 9 LOSS OF OR DAMAGE TO FACILITY TYPE Z 42 DESCRIPTION NA 43  
7 8 9 10 80

2 0 PUBLICITY DESCRIPTION N 44 NA 45  
7 8 9 10 80

NAME OF PREPARER S. Spector

PHONE: 716/546-2700, ext. 291-215

7911140 239

10-11-12

