

THIS DRAWING SUPERSEDES WESTINGHOUSE DRAWING 499B425 SH.254 REV 5

VALVE NO. B/M NO.	FIG. /SH	SW DEV.	OPER. MODE	CS/LGT LOCATION	INTERLOCKS	REFERENCE AND	DRAWING REMARKS
3505 TAFSV-1A RN21A	322	6/329	C/FAI	CB		SH.317 TURB. DRY. STM. GEN. F.W. PUMP STM. ADM. VALVE 1A	
3504 TAFSV-1B RN21B	322	6/329	C/FAI	CB		SH.317 TURB. DRY. STM. GEN. F.W. PUMP STM. ADM. VALVE 1B	
3996 TAFDV	293	C/12	C/FAI	CB		SH.317 TURB. DRY. STM. GEN. F.W. PUMP DISCH. VALVE (WATER)	
3150 CWDV-1A	294	9/12	O/FAI	PB LOCAL 1/CWP 1A CB	SEE SH.294	SH.31 & 31G CIRC. WTR. PUMP DISCH. VALVE 1A	
3151 CWDV-1B	294	9/12	O/FAI	PB LOCAL 1/CWP 1B CB	SEE SH.294	SH.31 & 31G CIRC. WTR. PUMP DISCH. VALVE 1B	
5171 FSIV RNG3	292	9/12	O/FAI	CONT. RM FIRE CONT PANEL			TURB. RM. FIRE SERV. ISOL. VALVE

	CONSTRUCTION	
	LIMITED CONSTRUCTION: AS NOTED	
	PRELIMINARY NOT FOR CONSTRUCTION	
	BIDDING PURPOSES	
SEP 21 '81	FOR INFORMATION ONLY	pcr
DATE	RELEASED FOR	ENGR.

OPER. MODE
O-NORMALLY OPER. OPEN
C-NORMALLY OPER. CLOSED
X-NORMALLY OPER. OPEN &
CLOSED
FC: FAILED CLOSED
FO: FAILED OPEN
FAI: FAILED AS IS

CONTROL SWITCH AND/OR POS. LGT.
LOCATION:
L-LOCAL
CB-CONTROL BOARD
SR-SAMPLE ROOM
AP-AUXILIARY PANEL
WP-WASTE DISPOSAL PANEL

TERA
APERTURE
CARD

REV.	Δ	REV.	REV.	REV.	REV.
ORIGINAL		D.H.	Rev	Rev	Rev
DRAWN BY		8-5-76	8-10-76	8-10-76	8-10-76
CED		Rev	Rev	Rev	Rev
ENG'G		Rev	Rev	Rev	Rev
DATE		4/1/76	8/1/76	8/1/76	8/1/76

ROCHESTER GAS & ELECTRIC CORP. ROCHESTER, NEW YORK	ROBERT EMMETT GINNA NUCLEAR POWER STATION UNIT NO.1	DRAWN BY D.H.	DATE 10-75	SCALE
ENG'R	ELEM. WIRING DIAGRAM	TRACED		APPROVED
NO. 10905-254 Δ	MOTOR OPERATED VALVES	CHECKED		Folder NO.
		ENG.		JOB NO.

REGULATORY DOCKET FILE COPY

C
5
Docket # 50-244
Control # B109240350-
Date 9-22-81 of Document
REGULATORY DOCKET FILE