

WIRE SIZE
A= 18 G A.
G= 6 G A.
⬭ —ISOLATED TWISTED PAIR

PASS WIRE THRU CT202
A - 4 TIMES FOR 500VA INVERTER
B - 3 " " 1 KVA "
C - 2 " " 2 KVA "
D - 1 " " 3 KVA "
E - 2 " " 5 KVA "
F - 1 TIME FOR 7.5KVA AND ABOVE

DATE	REV.	REVISION RECORD	DR.	APPR.

REGULATORY DOCKET FILE COPY

FINAL DRAWINGS

Solidstate Controls, Inc. guarantees compliance
Vice-President, Engineering

Docket # 50-244
Control # 8110140360 -1 D
Date 10-09-81 of Document
REGULATORY DOCKET FILE

R. E. GINNA NUCLEAR POWER STATION #1
PURCHASE IDENTIFICATION #N-EG-81337-76-1

CONTROL JOB

SCI SOLIDSTATE CONTROLS, INC.
600 OAKLAND PARK AVENUE • COLUMBUS, OHIO 43214

TOLERANCE UNLESS NOTED	SCALE	REFERENCE P.L. 14255 B.M.
DECIMAL ±	DRAWN BY K.D.R.	TITLE SCHEMATIC STATIC SW. 7.5 KVA 1Ø 60HZ 120 V.A.C.
FRACTION ±	APPROVED BY	
276-299	DATE 11/10/77	DWG. NO. 015C 14255 PROJECT NO. 10506