

UNITED STATES OF AMERICA
NUCLEAR REGULATORY COMMISSION

In the Matter of

Rochester Gas and Electric Corporation
(R. E. Ginna Nuclear Power Plant)

)
)
)
)

Docket No. 50-244

APPLICATION FOR AMENDMENT
TO OPERATING LICENSE

Pursuant to Section 50.90 of the regulations of the U.S. Nuclear Regulatory Commission (the "Commission"), Rochester Gas and Electric Corporation ("RG&E"), holder of Facility Operating License No. DPR-18, hereby requests that the Technical Specifications set forth in Appendix A to that license be amended. This request for a change in Technical Specifications is submitted to revise the core safety limit curves and overpower and overtemperature delta T setpoints resulting from increasing the percentage of plugged steam generator tubes assumed in the reference reload safety analysis.

The proposed technical specification change is set forth in Attachment A to this Application. A safety evaluation is set forth in Attachment B. This evaluation also demonstrates that the proposed change does not involve a significant change in the types or a significant increase in the amounts of effluents or any change in the authorized power level of the facility. As demonstrated in Attachment B, the proposed change does not involve a significant hazards consideration.

8710300130 871027
PDR ADDCK 05000244
P PDR

WHEREFORE, Applicant respectfully requests that Appendix A to Facility Operating License No. DPR-18 be amended in the form attached hereto as Attachment A.

Rochester Gas and Electric Corporation

By Roger W. Kober
Roger W. Kober
Vice President, Electric Production

Subscribed and sworn to before me
on this 27th day of October, 1987.

Lynn I. Hauck
LYNN I. HAUCK
Notary Public in the State of New York
MONROE COUNTY
Commission Expires Nov. 30, 1988