

ACCELERATED DISTRIBUTION DEMONSTRATION SYSTEM

REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR:9002260486 DOC.DATE: 90/02/15 NOTARIZED: NO DOCKET #
 FACIL:50-244 Robert Emmet Ginna Nuclear Plant, Unit 1, Rochester G 05000244
 AUTH.NAME AUTHOR AFFILIATION
 MECREDY,R.C. Rochester Gas & Electric Corp.
 RECIP.NAME RECIPIENT AFFILIATION
 JOHNSON,A.R. Project Directorate I-3

SUBJECT: Forwards chronological listing of all correspondence
 between Commission & util re CRDR alarm mod.

DISTRIBUTION CODE: A003D COPIES RECEIVED:LTR 1 ENCL 1 SIZE: 3
 TITLE: OR/Licensing Submittal: Suppl 1 to NUREG-0737(Generic Ltr 82-33)

NOTES:License Exp date in accordance with 10CFR2,2.109(9/19/72). 05000244


	RECIPIENT ID CODE/NAME	COPIES LTTR ENCL	RECIPIENT ID CODE/NAME	COPIES LTTR ENCL
	PD1-3 LA JOHNSON,A	1 1 1 1	PD1-3 PD	7 7
INTERNAL:	NRR/DLPQ/LHFB11 OC/LFMB RES/DSIR/EIB	1 1 1 0 1 1	<u>NUDOCS-ABSTRACT REG FILE 01</u>	1 1 1 1
EXTERNAL:	LPDR NSIC	1 1 1 1	NRC PDR	1 1

NOTE TO ALL "RIDS" RECIPIENTS:

PLEASE HELP US TO REDUCE WASTE! CONTACT THE DOCUMENT CONTROL DESK,
 ROOM P1-37 (EXT. 20079) TO ELIMINATE YOUR NAME FROM DISTRIBUTION
 LISTS FOR DOCUMENTS YOU DON'T NEED!

TOTAL NUMBER OF COPIES REQUIRED: LTTR 17 ENCL 16

mm/4





ROCHESTER GAS AND ELECTRIC CORPORATION • 89 EAST AVENUE, ROCHESTER, N.Y. 14649-0001



February 15, 1990

TELEPHONE
AREA CODE 716 546-2700

U.S. Nuclear Regulatory Commission
Document Control Desk
Attn: Allen R. Johnson
Project Directorate I-3
Washington, D.C. 20555

Subject: Current Status of Ginna Station Control Room
Design Review (CRDR)
R.E. Ginna Nuclear Power Plant
Docket No. 50-244

Reference: Control Room Design Review (CRDR) Alarm Modifications,
R. Mecredy letter to C. Stahle, dated August 2, 1988

Dear Mr. Johnson:

For your information, and to aid in your efforts to "close out" the Control Room Design Review issue at the Ginna Nuclear Power Plant, I have attached a chronological listing of all correspondence between the Commission and RG&E relevant to this project.

Of the 477 Human Engineering Discrepancies (HED) that were generated during the course of subject review, there is currently only one HED outstanding that has yet to be dispositioned.

The HED in question suggests the Control Room annunciator alarm does not meet all the human factor guidelines for alarm systems (reference letter). After many tests of several new alarm systems, all of which proved to be ineffective, it was decided to modify the Main Control Board (MCB) exhaust fan prior to installing a new annunciator alarm system. The modification to the exhaust fan involves the addition of exhaust ducting which will result in a lower background noise level in the Control Room. The lower background noise level will make the new alarm system more adaptable to the guidelines established in the referenced letter.

The MCB structural integrity is sensitive to most modifications, consequently, an extensive seismic analysis of the MCB with exhaust duct work attached, must be performed prior to installation.

9002260486 900215
PDR ADOCK 05000244
PDC

A003
11
Cut No
P340956852

The scope of work involved in the exhaust fan modification including installation, is scheduled for June 1990. The new annunciator alarm system will be installed, tested and operational one month thereafter.

Upon completing the above, RG&E will have completed all obligations of the CRDR. If you have any questions or require further clarification, please let me know.

Very truly yours,



Robert C. Mecredy
Division Manager
Nuclear Production

CJM\084
Attachment

xc: Mr. Allen R. Johnson (Mail Stop 14D1)
Project Directorate I-3
Washington, D.C. 20555

U.S. Nuclear Regulatory Commission
Region I
475 Allendale Road
King of Prussia, PA 19406

Ginna Senior Resident Inspector

CHRONOLOGY

Ginna Station Control Room Design Review Correspondence

1. Control Room Design Review Program Plan
R. Kober letter to J. Zwolinski
October 31, 1984
2. Review of the Detailed Control Room Design Review (DCRDR)
J. Zwolinski letter to R. Kober
April 16, 1985
3. Results of In-Progress Audit of the Detailed Control Room Design Review
J. Zwolinski letter to R. Kober
August 9, 1985
4. Control Room Design Review Summary Report
R. Kober letter to G. Lear
December 30, 1985
5. Detailed Control Room Design Review Safety Evaluation Report
M. Fairtile letter to R. Kober
September 4, 1986
6. Control Room Design Review Status
R. Kober letter to C. Stahle
June 22, 1987
7. Control Room Design Review Supplemental Report
R. Kober letter to C. Stahle
July 14, 1987
8. Control Room Design Review (CRDR) Control Switch Relocation
R. Kober letter to C. Stahle
December 15, 1987
9. Control Room Design Review (CRDR) Alarm Modifications
R. Mecredy letter to C. Stahle
August 2, 1988
10. Control Room Design Review of Control Switch Relocation Modifications
R. Mecredy letter to A. Johnson
January 11, 1990