

ACCELERATED DISTRIBUTION DEMONSTRATION SYSTEM

REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR:9007250220 DOC.DATE: 90/07/20 NOTARIZED: NO DOCKET #
 FACIL:50-244 Robert Emmet Ginna Nuclear Plant, Unit 1, Rochester G 05000244
 AUTH.NAME AUTHOR AFFILIATION
 MCCREDY,R.C. Rochester Gas & Electric Corp.
 RECIP.NAME RECIPIENT AFFILIATION
 JOHNSON,A.R. Project Directorate I-3

SUBJECT: Advises that structural evaluations of containment sys performed in response to containment integrity insp.

DISTRIBUTION CODE: A001D COPIES RECEIVED:LTR 1 ENCL 0 SIZE: 1
 TITLE: OR Submittal: General Distribution

NOTES:License Exp date in accordance with 10CFR2,2.109(9/19/72). 05000244

	RECIPIENT		COPIES			RECIPIENT		COPIES		
	ID CODE/NAME		LTTR	ENCL		ID CODE/NAME		LTTR	ENCL	
	PD1-3 LA		1	1		PD1-3 PD		1	1	
	JOHNSON,A		5	5						
INTERNAL:	NRR/DET/ECMB 9H		1	1		NRR/DOEA/OTSB11		1	1	
	NRR/DST 8E2		1	1		NRR/DST/SELB 8D		1	1	
	NRR/DST/SICB 7E		1	1		NRR/DST/SRXB 8E		1	1	
	NUDOCS-ABSTRACT		1	1		OC/LEMB		1	0	
	OGC/HDS2		1	0		REG FILE 01		1	1	
	RES/DSIR/EIB		1	1						
EXTERNAL:	LPDR		1	1		NRC PDR		1	1	
	NSIC		1	1						

p249194151

NOTE TO ALL "RIDS" RECIPIENTS:

PLEASE HELP US TO REDUCE WASTE! CONTACT THE DOCUMENT CONTROL DESK, ROOM P1-37 (EXT. 20079) TO ELIMINATE YOUR NAME FROM DISTRIBUTION LISTS FOR DOCUMENTS YOU DON'T NEED!

TOTAL NUMBER OF COPIES REQUIRED: LTTR 21 ENCL 19

MA/4
 ulb



ROCHESTER GAS AND ELECTRIC CORPORATION • 89 EAST AVENUE, ROCHESTER, N.Y. 14649-0001



July 20, 1990

TELEPHONE
AREA CODE 716 546-2700

U.S. Nuclear Regulatory Commission
Document Control Desk
Attn: Allen R. Johnson
Project Directorate I-3
Washington, D.C. 20555

Subject: Containment Integrity Inspection
R.E. Ginna Nuclear Power Plant
Docket No. 50-244

Dear Mr. Johnson:

As stated in our July 11, 1990 correspondence on the referenced subject, RG&E has performed an evaluation of the source of groundwater in the annular access area around containment. Based on the results of our review, RG&E has high confidence that groundwater is entering this area from behind the sheetpiling, rather than from underneath containment.

RG&E is at this time performing structural evaluations of the containment system to address the NRC's request for additional information of July 9, 1990 and the subsequent July 18, 1990 conference call. These evaluations will be performed in an expeditious manner. The schedule for and level of detail in our responses will be discussed with the NRC in the near future.

Very truly yours,

Robert C. Mecredy
Division Manager
Nuclear Production

GJW/113

xc: Mr. Allen R. Johnson (Mail Stop 14D1)
Project Directorate I-3
Washington, D.C. 20555

U.S. Nuclear Regulatory Commission
Region I
475 Allendale Road
King of Prussia, PA 19406

Ginna Senior Resident Inspector

9007250220 900720
PDR ADOCK 05000244
Q PDC

P249194151

A001
110