

ACCELERATED DISTRIBUTION DEMONSTRATION SYSTEM

REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR:9008210156 DOC DATE: 90/07/31 NOTARIZED: NO DOCKET #
 FACIL:50-244 Robert Emmet Ginna Nuclear Plant, Unit 1, Rochester G 05000244
 AUTH.NAME AUTHOR AFFILIATION
 DODGE,R.E. Rochester Gas & Electric Corp.
 MECREDY,R.C. Rochester Gas & Electric Corp.
 RECIP.NAME RECIPIENT AFFILIATION

SUBJECT: Monthly operating rept for Jul 1990 for RE Ginna Nuclear
 Power Plant.W/900815 ltr.

DISTRIBUTION CODE: IE24D COPIES RECEIVED: LTR 1 ENCL 1 SIZE: 5
 TITLE: Monthly Operating Report (per Tech Specs)

NOTES: License Exp date in accordance with 10CFR2,2.109(9/19/72). 05000244

	RECIPIENT ID CODE/NAME	COPIES		RECIPIENT ID CODE/NAME	COPIES	
		LTTR	ENCL		LTTR	ENCL
	PD1-3 LA	3	3	PD1-3 PD	1	1
	JOHNSON,A	1	1			
INTERNAL:	AEOD/DOA	1	1	AEOD/DSP/TPAB	1	1
	IRM TECH ADV	2	2	NRR/DLPO/LPEB10	1	1
	NRR/DOEA/OEAB11	1	1	REG FILE 01	1	1
	RGN1	1	1			
EXTERNAL:	EG&G BRYCE,J.H	3	3	LPDR	1	1
	NRC PDR	1	1	NSIC	1	1

NOTE TO ALL "RIDS" RECIPIENTS:


PLEASE HELP US TO REDUCE WASTE! CONTACT THE DOCUMENT CONTROL DESK,
 ROOM P1-37 (EXT. 20079) TO ELIMINATE YOUR NAME FROM DISTRIBUTION
 LISTS FOR DOCUMENTS YOU DON'T NEED!

TOTAL NUMBER OF COPIES REQUIRED: LTTR 19 ENCL 19

MR
web



ROCHESTER GAS AND ELECTRIC CORPORATION • 89 EAST AVENUE, ROCHESTER N.Y. 14649-0001



ROBERT C. MECREDY
Vice President
Ginna Nuclear Production

TELEPHONE
AREA CODE 716 546-2700

GINNA STATION

August 15, 1990

US Nuclear Regulatory Commission
Document Control Desk
Washington, DC 20555

Subject: Monthly Report for July, 1990
Operating Status Information
R. E. Ginna Nuclear Power Plant
Docket No. 50-244

Dear Sir:

Pursuant to our Technical Specification 6.9.1, attached herewith is the monthly operating status report for Ginna Station for the month of July, 1990.

Very truly yours,


Robert C. Mecredy

/eeh

Attachments

cc: Mr. Thomas T. Martin NRC (1)

9008210156 900731
PDR ADOCK 05000244
R&G PDC

IE24
11

OPERATING DATA REPORT

DOCKET NO. 50-244

DATE August 15, 1990

COMPLETED BY Robert E. Dodge
Robert E. Dodge

TELEPHONE (315) 524-4446 ext. 396

OPERATING STATUS

1. Unit Name: R.E. GINNA NUCLEAR POWER PLANT
2. Reporting Period: July, 1990
3. Licensed Thermal Power (MWt): 1520
4. Nameplate Rating (Gross MWe): 490
5. Design Electrical Rating (Net MWe): 470
6. Maximum Dependable Capacity (Gross MWe): 490
7. Maximum Dependable Capacity (Net MWe): 470
8. If Changes Occur in Capacity Ratings (Items Number 3 Through 7) Since Last Report, Give Reasons:

Notes: The unit operated at approximately 100% reactor power level for the entire report period; except for the event detailed on page 4 of this report.

9. Power Level to Which Restricted, If Any (Net MWe): _____
10. Reasons For Restrictions, If Any: _____

	This Month	Yr.-to-Date	Cumulative
11. Hours In Report Period	<u>744</u>	<u>5,087</u>	<u>181,271</u>
12. Number of Hours Reactor Was Critical	<u>744</u>	<u>3,993.84</u>	<u>142,339.98</u>
13. Reactor Reserve Shutdown Hours	<u>0</u>	<u>0</u>	<u>1,687.55 *</u>
14. Hours Generator On-Line	<u>744</u>	<u>3,960.5</u>	<u>139,801.88</u>
15. Unit Reserve Shutdown Hours	<u>0</u>	<u>0</u>	<u>8.5 *</u>
16. Gross Thermal Energy Generated (MWH)	<u>1,098,566</u>	<u>5,806,428</u>	<u>197,428,878</u>
17. Gross Electrical Energy Generated (MWH)	<u>369,402</u>	<u>1,962,569</u>	<u>64,995,914</u>
18. Net Electrical Energy Generated (MWH)	<u>351,218</u>	<u>1,866,688</u>	<u>61,684,601</u>
19. Unit Service Factor	<u>100</u>	<u>77.86</u>	<u>77.12</u>
20. Unit Availability Factor	<u>100</u>	<u>77.86</u>	<u>77.13</u>
21. Unit Capacity Factor (Using MDC Net)	<u>100.44</u>	<u>78.08</u>	<u>73.71</u>
22. Unit Capacity Factor (Using DER Net)	<u>100.44</u>	<u>78.08</u>	<u>73.71</u>
23. Unit Forced Outage Rate	<u>0</u>	<u>1.14</u>	<u>6.22</u>

24. Shutdowns Scheduled Over Next 6 Months (Type, Date and Duration of Each):

25. If Shut Down At End Of Report Period, Estimated Date of Startup: May 7, 1990

26. Units In Test Status (Prior to Commercial Operation):	Forecast	Achieved
INITIAL CRITICALITY	<u> </u>	<u> </u>
INITIAL ELECTRICITY	<u> </u>	<u> </u>
COMMERCIAL OPERATION	<u> </u>	<u> </u>

*CUMULATIVE TOTAL COMMENCING JANUARY 1, 1975

AVERAGE DAILY UNIT POWER LEVEL

DOCKET NO. 50-244
UNIT R.E. Ginna Nuclear Power Plant
DATE August 15, 1990
COMPLETED BY Robert E. Dodge
Robert E. Dodge

TELEPHONE 1 (315) 524-4446 ext. 396

MONTH July, 1990

DAY AVERAGE DAILY POWER LEVEL
(MWe-Net)

1.	<u>476</u>
2.	<u>473</u>
3.	<u>473</u>
4.	<u>473</u>
5.	<u>467</u>
6.	<u>472</u>
7.	<u>473</u>
8.	<u>475</u>
9.	<u>473</u>
10.	<u>471</u>
11.	<u>470</u>
12.	<u>471</u>
13.	<u>480</u>
14.	<u>481</u>
15.	<u>481</u>
16.	<u>480</u>

DAY AVERAGE DAILY POWER LEVEL
(MWe-Net)

17.	<u>478</u>
18.	<u>473</u>
19.	<u>472</u>
20.	<u>471</u>
21.	<u>476</u>
22.	<u>471</u>
23.	<u>471</u>
24.	<u>470</u>
25.	<u>468</u>
26.	<u>467</u>
27.	<u>466</u>
28.	<u>465</u>
29.	<u>467</u>
30.	<u>468</u>
31.	<u>464</u>

INSTRUCTIONS

On this format, list the average daily unit power level in MWe-Net for each day in the reporting month. Compute to the nearest whole megawatt.

UNIT SHUTDOWN AND POWER REDUCTIONS

REPORT MONTH JULY 1990

DOCKET NO. 50-244

UNIT NAME: R.E. GINNA NUCLEAR POWER PLANT

DATE August 15, 1990

COMPLETED BY Robert E. Dodge

TELEPHONE: 315-524-4446 x-396

Ginna Station

No.	Date	Type 1	Duration (Hours)	Reason 2	Method of Shutting Down Reactor 3	Licensee Event Report #	System Code 4	Component Code 5	Cause & Corrective Action to Prevent Recurrence
	07/05/90	F	2.0	A	1		RB	CONROD	Control Bank "C" Rod problem

1

F: Forced
S: Scheduled

2

Reason:
A-Equipment Failure (Explain)
B-Maintenance or Test
C-Refueling
D-Regulatory Restriction
E-Operator Training & License Examination
F-Administrative
G-Operational Error (Explain)
H-Other (Explain)

3

Method:
1-Manual
2-Manual Scram.
3-Automatic Scram.
4-Other (Explain)

4

Exhibit G - Instructions for Preparation of Data Entry Sheets for Licensee Event Report (LER) File (NUREG-0161)

5

Exhibit 1 - Same Source

11

10

NARRATIVE SUMMARY OF OPERATING EXPERIENCE

DOCKET NO. 50-244
UNIT R.E. Ginna Nuclear Power Plant
DATE August 15, 1990
COMPLETED BY *Robert E. Dodge*
Robert E. Dodge
TELEPHONE 1 (315) 524-4446 ext. 396

MONTH July, 1990

The unit operated at ~ 100% reactor power level for the entire report period, except for the following event:

On July 5, 1990 at 0925, the reactor power level was reduced to ~ 85% due to a control bank "C" rod problem. The reactor power level was restored to ~ 100%, at 1309 the same day.