

ACCELERATED DISTRIBUTION DEMONSTRATION SYSTEM

REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR:9009260068 DOC.DATE: 90/08/31 NOTARIZED: NO DOCKET #
 FACIL:50-244 Robert Emmet Ginna Nuclear Plant, Unit 1, Rochester G 05000244
 AUTH.NAME AUTHOR AFFILIATION
 DODGE,R.E. Rochester Gas & Electric Corp.
 MECREDY,R.C. Rochester Gas & Electric Corp.
 RECIP.NAME RECIPIENT AFFILIATION

SUBJECT: Monthly operating rept for Aug 1990 for RE Ginna Nuclear
 Power Plant.W/900919 ltr.

DISTRIBUTION CODE: IE24D COPIES RECEIVED:LTR 1 ENCL 1 SIZE: 5
 TITLE: Monthly Operating Report (per Tech Specs)

NOTES:License Exp date in accordance with 10CFR2,2.109(9/19/72). 05000244

	RECIPIENT ID CODE/NAME	COPIES LTTR ENCL	RECIPIENT ID CODE/NAME	COPIES LTTR ENCL
	PD1-3 LA	3 3	PD1-3 PD	1 1
	JOHNSON,A	1 1		
INTERNAL:	AEOD/DOA	1 1	AEOD/DSP/TPAB	1 1
	IRM TECH ADV	2 2	NRR/DLEQ/LPEB10	1 1
	NRR/DOEA/OEAB11	1 1	<u>REG FILE</u> 01	1 1
	RGN1	1 1		
EXTERNAL:	EG&G BRYCE,J.H	1 1	NRC PDR	1 1
	NSIC	1 1		

NOTE TO ALL "RIDS" RECIPIENTS:

PLEASE HELP US TO REDUCE WASTE! CONTACT THE DOCUMENT CONTROL DESK,
 ROOM P1-37 (EXT. 20079) TO ELIMINATE YOUR NAME FROM DISTRIBUTION
 LISTS FOR DOCUMENTS YOU DON'T NEED!

TOTAL NUMBER OF COPIES REQUIRED: LTTR 16 ENCL 16

cm R
 sub



ROCHESTER GAS AND ELECTRIC CORPORATION • 89 EAST AVENUE, ROCHESTER N.Y. 14649-0001

ROBERT C. MECREDY
Vice President
Ginna Nuclear Production

TELEPHONE
AREA CODE 716 546-2700



GINNA STATION

September 19, 1990

US Nuclear Regulatory Commission
Document Control Desk
Washington, DC 20555

Subject: Monthly Report for August, 1990
Operating Status Information
R. E. Ginna Nuclear Power Plant
Docket No. 50-244

Dear Sir:

Pursuant to our Technical Specification 6.9.1, attached herewith is the monthly operating status report for Ginna Station for the month of August, 1990.

Very truly yours,


Robert C. Mecredy

RCM/eeh

Attachments

cc: Mr. Thomas T. Martin NRC (1)

9009260068 900831
PDR ADCK 05000244
R PDC

IE24
4/1

OPERATING DATA REPORT

DOCKET NO. 50-244

DATE September 19, 1990

COMPLETED BY Robert E. Dodge
Robert E. Dodge

TELEPHONE (315) 524-4446 ext. 396

OPERATING STATUS

1. Unit Name: R.E. GINNA NUCLEAR POWER PLANT
2. Reporting Period: August, 1990
3. Licensed Thermal Power (MWt): 1520
4. Nameplate Rating (Gross MWe): 490
5. Design Electrical Rating (Net MWe): 470
6. Maximum Dependable Capacity (Gross MWe): 490
7. Maximum Dependable Capacity (Net MWe): 470
8. If Changes Occur in Capacity Ratings (Items Number 3 Through 7) Since Last Report, Give Reasons:

Notes: The unit operated at approximately 100% reactor power level for the entire report period.

9. Power Level to Which Restricted, If Any (Net MWe):
10. Reasons For Restrictions, If Any:

	This Month	Yr.-to-Date	Cumulative
11. Hours In Report Period	<u>744</u>	<u>5,831</u>	<u>182,417.45</u>
12. Number of Hours Reactor Was Critical	<u>744</u>	<u>4,737.84</u>	<u>143,083.98</u>
13. Reactor Reserve Shutdown Hours	<u>0</u>	<u>0</u>	<u>1,687.55 *</u>
14. Hours Generator On-Line	<u>744</u>	<u>4,704.5</u>	<u>140,545.88</u>
15. Unit Reserve Shutdown Hours	<u>0</u>	<u>0</u>	<u>8.5 *</u>
16. Gross Thermal Energy Generated (MWH)	<u>1,098,437</u>	<u>6,904,865</u>	<u>198,527,315</u>
17. Gross Electrical Energy Generated (MWH)	<u>366,461</u>	<u>2,329,030</u>	<u>65,362,375</u>
18. Net Electrical Energy Generated (MWH)	<u>348,305</u>	<u>2,214,993</u>	<u>62,032,906</u>
19. Unit Service Factor	<u>100</u>	<u>80.68</u>	<u>77.22</u>
20. Unit Availability Factor	<u>100</u>	<u>80.68</u>	<u>77.22</u>
21. Unit Capacity Factor (Using MDC Net)	<u>99.61</u>	<u>80.82</u>	<u>73.82</u>
22. Unit Capacity Factor (Using DER Net)	<u>99.61</u>	<u>80.82</u>	<u>73.82</u>
23. Unit Forced Outage Rate	<u>0</u>	<u>.96</u>	<u>6.18</u>

24. Shutdowns Scheduled Over Next 6 Months (Type, Date and Duration of Each):

Annual Refueling and Maintenance Shutdown: March 1991

25. If Shut Down At End Of Report Period, Estimated Date of Startup: May 7, 1990

26. Units In Test Status (Prior to Commercial Operation):	Forecast	Achieved
INITIAL CRITICALITY	<u> </u>	<u> </u>
INITIAL ELECTRICITY	<u> </u>	<u> </u>
COMMERCIAL OPERATION	<u> </u>	<u> </u>

*CUMULATIVE TOTAL COMMENCING JANUARY 1, 1975

AVERAGE DAILY UNIT POWER LEVEL

DOCKET NO. 50-244
 UNIT R.E. Ginna Nuclear Power Plant
 DATE September 19, 1990
 COMPLETED BY Robert E. Dodge
 Robert E. Dodge

TELEPHONE 1 (315) 524-4446 ext. 396

MONTH August, 1990

DAY AVERAGE DAILY POWER LEVEL
(MWe-Net)

1.	<u>461</u>
2.	<u>461</u>
3.	<u>461</u>
4.	<u>461</u>
5.	<u>461</u>
6.	<u>461</u>
7.	<u>460</u>
8.	<u>460</u>
9.	<u>460</u>
10.	<u>460</u>
11.	<u>461</u>
12.	<u>459</u>
13.	<u>459</u>
14.	<u>461</u>
15.	<u>461</u>
16.	<u>460</u>

DAY AVERAGE DAILY POWER LEVEL
(MWe-Net)

17.	<u>461</u>
18.	<u>460</u>
19.	<u>470</u>
20.	<u>478</u>
21.	<u>478</u>
22.	<u>478</u>
23.	<u>478</u>
24.	<u>478</u>
25.	<u>473</u>
26.	<u>468</u>
27.	<u>467</u>
28.	<u>465</u>
29.	<u>466</u>
30.	<u>466</u>
31.	<u>465</u>

INSTRUCTIONS

On this format, list the average daily unit power level in MWe-Net for each day in the reporting month. Compute to the nearest whole megawatt.

UNIT SHUTDOWN AND POWER REDUCTIONS

REPORT MONTH AUGUST 1990

DOCKET NO. 50-244
 UNIT NAME R.E. GINNA NUCLEAR POWER PLANT
 DATE September 19, 1990
 COMPLETED BY Robert E. Dodge
 TELEPHONE 315-524-4446 x-396
Ginna Station

No.	Date	Type 1	Duration (Hours)	Reason 2	Method of Shutting Down Reactor 3	Licensee Event Report #	System Code 4	Component Code 5	Cause & Corrective Action to Prevent Recurrence
									No unit shutdowns or power reductions during the report period.

1
 F: Forced
 S: Scheduled

2
 Reason:
 A-Equipment Failure (Explain)
 B-Maintenance or Test
 C-Refueling
 D-Regulatory Restriction
 E-Operator Training & License Examination
 F-Administrative
 G-Operational Error (Explain)
 H-Other (Explain)

3
 Method:
 1-Manual
 2-Manual Scram.
 3-Automatic Scram.
 4-Other (Explain)

4
 Exhibit G - Instructions for Preparation of Data Entry Sheets for Licensee Event Report (LER) File (NUREG-0161)

5
 Exhibit 1 - Same Source

NARRATIVE SUMMARY OF OPERATING EXPERIENCE

DOCKET NO. 50-244
UNIT R.E. Ginna Nuclear Power Plant
DATE September 19, 1990
COMPLETED BY Robert E. Dodge
TELEPHONE 1 (315) 524-4446 ext. 396

MONTH August, 1990

The unit operated at ~ 100% reactor power level for the entire report period.

