

ACCELERATED DISTRIBUTION DEMONSTRATION SYSTEM

REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR:9010230195 DOC.DATE: 90/10/10 NOTARIZED: NO DOCKET #
 FACIL:50-244 Robert Emmet Ginna Nuclear Plant, Unit 1, Rochester G 05000244
 AUTH.NAME AUTHOR AFFILIATION
 MECREDY,R.C. Rochester Gas & Electric Corp.
 RECIP.NAME RECIPIENT AFFILIATION
 JOHNSON,A.R. Project Directorate I-3

SUBJECT: Updates status of inoperable Fire Damper I-411-21-P.

DISTRIBUTION CODE: IE22D COPIES RECEIVED:LTR 1 ENCL 0 SIZE: 2
 TITLE: 50.73/50.9 Licensee Event Report (LER), Incident Rpt, etc.

NOTES:License Exp date in accordance with 10CFR2,2.109(9/19/72). 05000244

	RECIPIENT		COPIES			RECIPIENT		COPIES		
	ID CODE/NAME		LTR	ENCL		ID CODE/NAME		LTR	ENCL	
	PD1-3 LA		1	1		PD1-3 PD		1	1	
	JOHNSON,A		1	1						
INTERNAL:	ACNW		2	2		AEOD/DOA		1	1	
	AEOD/DSP/TPAB		1	1		AEOD/ROAB/DSP		2	2	
	NRR/DET/ECMB 9H		1	1		NRR/DET/EMEB 7E		1	1	
	NRR/DLPQ/LHFB11		1	1		NRR/DLPQ/LPEB10		1	1	
	NRR/DREP/PRPB11		2	2		NRR/DST/SELB 8D		1	1	
	NRR/DST/SICB 7E		1	1		NRR/DST/SPLB8D1		1	1	
	NRR/DST/SRXB 8E		1	1		REG FILE 02		1	1	
	RES/DSIR/EIB		1	1		RGN1 FILE 01		1	1	
EXTERNAL:	EG&G BRYCE,J.H		3	3		L ST LOBBY WARD		1	1	
	NRC PDR		1	1		NSIC MAYS,G		1	1	
	NSIC MURPHY,G.A		1	1		NUDOCS FULL TXT		1	1	

Cont No p249194189

NOTE TO ALL "RIDS" RECIPIENTS:

PLEASE HELP US TO REDUCE WASTE! CONTACT THE DOCUMENT CONTROL DESK,
 ROOM P1-37 (EXT. 20079) TO ELIMINATE YOUR NAME FROM DISTRIBUTION
 LISTS FOR DOCUMENTS YOU DON'T NEED!

TOTAL NUMBER OF COPIES REQUIRED: LTR 30 ENCL 30


MA 4
 web



ROCHESTER GAS AND ELECTRIC CORPORATION • 89 EAST AVENUE, ROCHESTER N.Y. 14649-0001

ROBERT C. MECREDY
Vice President
Ginna Nuclear Production

TELEPHONE
AREA CODE 716 546-2700



October 10, 1990

Mr. Allen R. Johnson
Project Directorate I-3
U.S. Nuclear Regulatory Commission
Document Control Desk
Washington, DC 20555

Subject: Change to Thirty (30) Day Special Report
Inoperable Fire Damper I-411-21-P
R.E. Ginna Nuclear Power Plant, Unit No. 1
Docket No. 50-244

Reference: Letter from R.C. Mecredy (RG&E) to A.R. Johnson (NRC)
Dated July 31, 1990.

Dear Mr. Johnson:

The purpose of this letter is to update the status of inoperable fire damper I-411-21-P. Ruskin, the manufacturer of this damper, has been contacted and asked to comment on a design to install a removable track to replace the one side track that interferes with removal of the charcoal drawers that are behind the damper. Their response was that they will have to submit this design to Underwriters Laboratory for review and comment/approval. We are in the process of contracting for this review at this time.

Since this review will take several weeks, we are, in parallel, preparing a design/installation package to replace this damper with a larger damper and opening. As a result, we will not lose the time that it will take to get the results from Underwriters Laboratory should the review come back that a removable side track is not an approved configuration.

In either instance, we will have the necessary modification designed and installed by July 31, 1991. The established hourly fire watch in accordance with Technical Specification 3.14.6.1 will remain in effect.

9010230193 901010
PDR ADOCK 05000244
S PDC

Handwritten: 10/16 1990
249194169

ROCHESTER GAS AND ELECTRIC CORP.

DATE 10/10/90

TO Mr. Allen R. Johnson

SHEET NO.

2

Very truly yours,


Robert C. Mecredy

xc: Ginna Senior Resident Inspector

U.S. Nuclear Regulatory Commission
Region 1
475 Allendale Road
King of Prussia, PA 19406