

# ACCELERATED DISTRIBUTION DEMONSTRATION SYSTEM

## REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR:9012310105 DOC.DATE: 90/12/20 NOTARIZED: NO DOCKET #  
 FACIL:50-244 Robert Emmet Ginna Nuclear Plant, Unit 1, Rochester G 05000244  
 AUTH.NAME AUTHOR AFFILIATION  
 MECREDY,R.C. Rochester Gas & Electric Corp.  
 RECIP.NAME RECIPIENT AFFILIATION

Document Control Branch (Document Control Desk)

SUBJECT: Notifies of postponement of EWR 4770 until results of analysis completed. Will continue weekly rodding of bubbler tubes, in accordance w/Tech Spec Table 4.1-1, Item 14.

DISTRIBUTION CODE: A001D COPIES RECEIVED: LTR 1 ENCL 0 SIZE: 2  
 TITLE: OR Submittal: General Distribution

NOTES: License Exp date in accordance with 10CFR2,2.109(9/19/72). 05000244

	RECIPIENT		COPIES			RECIPIENT		COPIES	
	ID CODE/NAME		LTTR	ENCL		ID CODE/NAME		LTTR	ENCL
	PD1-3 LA		1	1		PD1-3 PD		1	1
	JOHNSON, A		2	2					
INTERNAL:	NRR/DET/ECMB 9H		1	1		NRR/DET/ESGB		1	1
	NRR/DOEA/OTSB11		1	1		NRR/DST 8E2		1	1
	NRR/DST/SELB 8D		1	1		NRR/DST/SICB 7E		1	1
	NRR/DST/SRXB 8E		1	1		NUDOCS-ABSTRACT		1	1
	OC/LFMB		1	0		OGC/HDS2		1	0
	REG FILE <u>01</u>		1	1		RES/DSIR/EIB		1	1
EXTERNAL:	NRC PDR		1	1		NSIC		1	1

Cont NO 8249194206

NOTE TO ALL "RIDS" RECIPIENTS:

PLEASE HELP US TO REDUCE WASTE! CONTACT THE DOCUMENT CONTROL DESK, ROOM P1-37 (EXT. 20079) TO ELIMINATE YOUR NAME FROM DISTRIBUTION LISTS FOR DOCUMENTS YOU DON'T NEED!

TOTAL NUMBER OF COPIES REQUIRED: LTTR 18 ENCL 26-0


MA H  
 sub



ROCHESTER GAS AND ELECTRIC CORPORATION • 89 EAST AVENUE, ROCHESTER N.Y. 14649-0001

ROBERT C. MECREDY  
Vice President  
Ginna Nuclear Production

TELEPHONE  
AREA CODE 716 546-2700



December 20, 1990

U.S. Nuclear Regulatory Commission  
Document Control Desk  
Attn: Allen R. Johnson  
Project Directorate I-3  
Washington, D.C. 20555

Subject: Postponement of EWR 4770  
R.E. Ginna Nuclear Power Plant  
Docket No. 50-244

Dear Mr. Johnson:

In RG&E's November 17, 1989 letter from Robert Mecredy to William Russell, we stated that EWR 4770 was initiated to develop and install a new boric acid storage tank level monitoring system to replace the existing bubbler type. The reason for this modification, originally scheduled for the 1991 refueling outage, was to remove the need for weekly rodding of the bubbler tubes as preventive maintenance.

Subsequent to that time, RG&E has initiated a study which would allow deletion of the need for high concentration (12 weight percent) boric acid. Based on preliminary results, it appears that this analysis will be successful. We have thus postponed EWR 4770 until the results of the analysis are complete. At that time, we will determine if any modifications to the BAST level instrumentation should be made.

In the meantime, RG&E will continue the weekly rodding of the bubbler tubes, in accordance with Technical Specification Table 4.1-1, item 14.

Very truly yours,

  
Robert C. Mecredy

GJW/131

9012310105 901220  
PDR ADOCK 05000244  
P PDR

*Foot 1/0*  
*Cent 20*  
*12A9-19A206*

xc: Mr. Allen R. Johnson (Mail Stop 14D1)  
Project Directorate I-3  
Washington, D.C. 20555

U.S. Nuclear Regulatory Commission  
Region I  
475 Allendale Road  
King of Prussia, PA 19406

Ginna Senior Resident Inspector

