

# ACCELERATED DISTRIBUTION DEMONSTRATION SYSTEM

## REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR: 9101180066 DOC. DATE: 91/01/14 NOTARIZED: YES

.DOCKET #

FACIL:

50-244

AUTH. NAME

AUTHOR AFFILIATION

MECREDY, R.C.

Rochester Gas & Electric Corp.

RECIP. NAME

RECIPIENT AFFILIATION

JOHNSON, A.R.

Project Directorate I-3

SUBJECT: Forwards application for amend to License DPR-18, changing Tech Specs to limit containment internal pressure to 1 psig vs 6 psig per initial condition assumptions in containment integrity analysis.

DISTRIBUTION CODE: A001D COPIES RECEIVED: LTR 1 ENCL 1 SIZE: 2437  
TITLE: OR Submittal: General Distribution

NOTES:

RECIPIENT ID CODE/NAME	COPIES		RECIPIENT ID CODE/NAME	COPIES	
	LTTR	ENCL		LTTR	ENCL
LA	1	1	PD	1	1
PM	2	2			
INTERNAL: NRR/DET/ECMB 9H	1	1	NRR/DET/ESGB	1	1
NRR/DOEA/OTSB11	1	1	NRR/DST 8E2	1	1
NRR/DST/SELB 8D	1	1	NRR/DST/SICB 7E	1	1
NRR/DST/SRXB 8E	1	1	NUDOCS-ABSTRACT	1	1
OC/LFMB	1	0	OGC	1	0
REG FILE 01	1	1	RES/DSIR/EIB	1	1
EXTERNAL: NRC PDR	1	1	NSIC	1	1

Cont no p249194224

NOTE TO ALL "RIDS" RECIPIENTS:

PLEASE HELP US TO REDUCE WASTE! CONTACT THE DOCUMENT CONTROL DESK, ROOM P1-37 (EXT. 20079) TO ELIMINATE YOUR NAME FROM DISTRIBUTION LISTS FOR DOCUMENTS YOU DON'T NEED!

TOTAL NUMBER OF COPIES REQUIRED: LTTR 18 ENCL 16

AA/2  
wb






ROCHESTER GAS AND ELECTRIC CORPORATION • 89 EAST AVENUE, ROCHESTER N.Y. 14649-0001

ROBERT C. MECREDY  
Vice President  
Ginna Nuclear Production

TELEPHONE  
AREA CODE 716 546-2700



January 14, 1991

U.S. Nuclear Regulatory Commission  
Document Control Desk  
Attn: Mr. Allen R. Johnson  
PWR Project Directorate I-3  
Washington, D.C. 20555

Subject: Rochester Gas and Electric Corporation  
R.E. Ginna Nuclear Power Plant  
Docket No. 50-244

Dear Mr. Johnson:

Enclosed is an Application for Amendment to Operating License to amend Appendix A of that license to limit the containment internal pressure to 1 psig (versus the present 6 psig). This is consistent with the Ginna Station initial condition assumptions in our containment integrity analysis.

This application is identical to an application submitted October 16, 1985, with the exception that Enclosure 1, a report for the BAST Concentration Reduction, August 1985, has already been approved via issuance of Amendment No. 33, March 30, 1989.

This Amendment should become effective within 30 days following RG&E notification of approval by the NRC.

Very truly yours,

*Robert C. Mecredy*  
Robert C. Mecredy

GJW\137  
Enclosures

xc: Mr. Allen R. Johnson (Mail Stop 14D1)  
Project Directorate I-3  
Washington, D.C. 20555

Ms. Donna Ross  
New York State Energy Office

*Cent No*  
*9249194214*  
*Aool*  
*1/1*

9101180066 910114  
PDR ADQCK 05000244  
PDR

11-11-61

11-11-61

11-11-61

U.S. Nuclear Regulatory Commission  
Region I  
475 Allendale Road  
King of Prussia, PA 19406

Ginna Senior Resident Inspector

