

ACCELERATED DISTRIBUTION DEMONSTRATION SYSTEM

REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR: 9103250301 DOC.DATE: 91/02/28 NOTARIZED: NO DOCKET #
 FACIL: 50-244 Robert Emmet Ginna Nuclear Plant, Unit 1, Rochester G 05000244
 AUTH.NAME AUTHOR AFFILIATION
 DODGE, R.E. Rochester Gas & Electric Corp.
 MECREDY, R.C. Rochester Gas & Electric Corp.
 RECIP.NAME RECIPIENT AFFILIATION

SUBJECT: Monthly operating rept for Feb 1991 for RE Ginna Nuclear
 Power Plant.W/910315 ltr.

DISTRIBUTION CODE: IE24D COPIES RECEIVED: LTR 1 ENCL 1 SIZE: S
 TITLE: Monthly Operating Report (per Tech Specs)

NOTES: License Exp date in accordance with 10CFR2,2.109(9/19/72). 05000244

	RECIPIENT ID CODE/NAME	COPIES LTTR ENCL	RECIPIENT ID CODE/NAME	COPIES LTTR ENCL
	PD1-3 LA	3 3	PD1-3 PD	1 1
	JOHNSON, A	1 1		
INTERNAL:	AEOD/DOA	1 1	AEOD/DSP/TPAB	1 1
	NRR/DLPO/LPEB10	1 1	NRR/DOEA/OEAB	1 1
	<u>REG FILE</u> 01	1 1	RGN1	1 1
EXTERNAL:	EG&G BRYCE, J.H	1 1	NRC PDR	1 1
	NSIC	1 1		

NOTE TO ALL "RIDS" RECIPIENTS:


PLEASE HELP US TO REDUCE WASTE! CONTACT THE DOCUMENT CONTROL DESK,
 ROOM P1-37 (EXT. 20079) TO ELIMINATE YOUR NAME FROM DISTRIBUTION
 LISTS FOR DOCUMENTS YOU DON'T NEED!

TOTAL NUMBER OF COPIES REQUIRED: LTTR 14 ENCL 14

MR / wlt



ROCHESTER GAS AND ELECTRIC CORPORATION • 89 EAST AVENUE, ROCHESTER N.Y. 14649-0001



ROBERT C. MECREDY
Vice President
Ginna Nuclear Production

TELEPHONE
AREA CODE 716 546-2700

GINNA STATION

March 15, 1991


US Nuclear Regulatory Commission
Document Control Desk
Washington, DC 20555

Subject: Monthly Report for February, 1991
Operating Status Information
R. E. Ginna Nuclear Power Plant
Docket No. 50-244

Dear Sir:

Pursuant to our Technical Specification 6.9.1, attached herewith is the monthly operating status report for Ginna Station for the month of February, 1991.

Very truly yours,


Robert C. Mecredy

RCM/eeh

Attachments

cc: Mr. Thomas T. Martin NRC (1)

9103250301 910228
PDR ADCK 05000244
R PDR

IE24

OPERATING DATA REPORT

DOCKET NO. 50-244
 DATE March 15, 1991
 COMPLETED BY Robert E. Dodge

TELEPHONE (315) 524-4446 ext. 396

OPERATING STATUS

1. Unit Name: R.E. GINNA NUCLEAR POWER PLANT
2. Reporting Period: February, 1991
3. Licensed Thermal Power (MWt): 1520
4. Nameplate Rating (Gross MWe): 490
5. Design Electrical Rating (Net MWe): 470
6. Maximum Dependable Capacity (Gross MWe): 490
7. Maximum Dependable Capacity (Net MWe): 470
8. If Changes Occur in Capacity Ratings (Items Number 3 Through 7) Since Last Report, Give Reasons:

Notes: The unit operated at ~ 97% power level except for the event detailed on page 4 of this report.

9. Power Level to Which Restricted, If Any (Net MWe): _____
10. Reasons For Restrictions, If Any: _____

	This Month	Yr.-to-Date	Cumulative
11. Hours In Report Period	<u>672</u>	<u>1,416</u>	<u>186,762.45</u>
12. Number of Hours Reactor Was Critical	<u>672</u>	<u>1,416</u>	<u>147,155.31</u>
13. Reactor Reserve Shutdown Hours	<u>0</u>	<u>0</u>	<u>1,687.55</u>
14. Hours Generator On-Line	<u>672</u>	<u>1,416</u>	<u>144,584.38</u>
15. Unit Reserve Shutdown Hours	<u>0</u>	<u>0</u>	<u>8.5</u> *
16. Gross Thermal Energy Generated (MWH)	<u>988,894</u>	<u>2,085,005</u>	<u>204,435,702</u>
17. Gross Electrical Energy Generated (MWH)	<u>337,384</u>	<u>710,639</u>	<u>67,373,113</u>
18. Net Electrical Energy Generated (MWH)	<u>321,068</u>	<u>676,229</u>	<u>63,945,522</u>
19. Unit Service Factor	<u>100%</u>	<u>100%</u>	<u>77.58%</u>
20. Unit Availability Factor	<u>100%</u>	<u>100%</u>	<u>77.59%</u>
21. Unit Capacity Factor (Using MDC Net)	<u>101.66</u>	<u>101.609</u>	<u>74.29</u>
22. Unit Capacity Factor (Using DER Net)	<u>101.66</u>	<u>101.609</u>	<u>74.29</u>
23. Unit Forced Outage Rate	<u>0</u>	<u>0</u>	<u>6.27</u>

24. Shutdowns Scheduled Over Next 6 Months (Type, Date and Duration of Each):

Annual Refueling and Maintenance Shutdown: March 22, 1991 40 days

25. If Shut Down At End Of Report Period, Estimated Date of Startup:

26. Units In Test Status (Prior to Commercial Operation):	Forecast	Achieved
INITIAL CRITICALITY	_____	_____
INITIAL ELECTRICITY	_____	_____
COMMERCIAL OPERATION	_____	_____

*CUMULATIVE TOTAL COMMENCING JANUARY 1, 1975

AVERAGE DAILY UNIT POWER LEVEL

DOCKET NO. 50-244UNIT R.E. Ginna Nuclear Power PlantDATE March 15, 1991

COMPLETED BY

Robert E. DodgeTELEPHONE 1 (315) 524-4446 ext. 396MONTH February, 1991DAY AVERAGE DAILY POWER LEVEL
(MWe-Net)

1.	<u>482</u>
2.	<u>482</u>
3.	<u>482</u>
4.	<u>483</u>
5.	<u>482</u>
6.	<u>482</u>
7.	<u>483</u>
8.	<u>483</u>
9.	<u>483</u>
10.	<u>484</u>
11.	<u>483</u>
12.	<u>483</u>
13.	<u>484</u>
14.	<u>484</u>
15.	<u>466</u>
16.	<u>483</u>

DAY AVERAGE DAILY POWER LEVEL
(MWe-Net)

17.	<u>484</u>
18.	<u>483</u>
19.	<u>483</u>
20.	<u>482</u>
21.	<u>482</u>
22.	<u>483</u>
23.	<u>481</u>
24.	<u>483</u>
25.	<u>484</u>
26.	<u>484</u>
27.	<u>483</u>
28.	<u>483</u>
29.	<u>-</u>
30.	<u>-</u>
31.	<u>-</u>

INSTRUCTIONS

On this format, list the average daily unit power level in MWe-Net for each day in the reporting month. Compute to the nearest whole megawatt.

UNIT SHUTDOWN AND POWER REDUCTIONS

REPORT MONTH FEBRUARY 1991

DOCKET NO. 50-244

UNIT NAME R.E. GINNA NUCLEAR POWER PLANT

DATE March 15, 1991

COMPLETED BY Robert E. Dodge

TELEPHONE 315-524-4446 x-396
Ginna Station

No.	Date	Type 1	Duration (Hours)	Reason 2	Method of Shutting Down Reactor 3	Licensee Event Report #	System Code 4	Component Code 5	Cause & Corrective Action to Prevent Recurrence
91-1	02-15-91	F	2.5 hrs	D	-	91-001			An Unusual Event was declared at 0945 hours on February 15, 1991. Due to Technical Specifications 3.3.4 and 3.7. At 1123 hours the plant shutdown was terminated. On February 16, 1991 at 0130 hours the Unusual Event was terminated per EPIP 3-4.

1

F: Forced
S: Scheduled

2

Reason:
A-Equipment Failure (Explain)
B-Maintenance or Test
C-Refueling
D-Regulatory Restriction
E-Operator Training & License Examination
F-Administrative
G-Operational Error (Explain)
H-Other (Explain)

3

Method:
1-Manual
2-Manual Scram.
3-Automatic Scram.
4-Other (Explain)

4

Exhibit G - Instructions for Preparation of Data Entry Sheets for Licensee Event Report (LER) File (NUREG-0161)

5

Exhibit 1 - Same Source

NARRATIVE SUMMARY OF OPERATING EXPERIENCE

DOCKET NO. 50-244
UNIT R.E. Ginna Nuclear Power Plant
DATE March 15, 1991
COMPLETED BY *Robert E. Dodge*
Robert E. Dodge
TELEPHONE 1 (315) 524-4446 ext. 396

MONTH February 1991

The unit operated at ~ 97% power level for the report period with the exception of February 15. At 0945 and Unusual Event was declared. Loss of Bus 18 and two service water pumps. The plant shutdown commenced to comply with technical specifications.

Plant shutdown terminated at 1123 and at 1151 normal feed to Bus 18 was restored.

