

ACCELERATED DISTRIBUTION DEMONSTRATION SYSTEM

REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR: 9105230125 DOC. DATE: ~~91/04/30~~ NOTARIZED: NO DOCKET #
 FACIL: 50-244 Robert Emmet Ginna Nuclear Plant, Unit 1, Rochester G 05000244
 AUTH. NAME AUTHOR AFFILIATION
 DODGE, R.E. Rochester Gas & Electric Corp.
 MECREDY, R.C. Rochester Gas & Electric Corp.
 RECIP. NAME RECIPIENT AFFILIATION

SUBJECT: Monthly operating rept for Apr 1991 for R.E. Ginna Station.
 W/910515 ltr.

DISTRIBUTION CODE: IE24D COPIES RECEIVED: LTR 1 ENCL 1 SIZE: 5
 TITLE: Monthly Operating Report (per Tech Specs)

NOTES: License Exp date in accordance with 10CFR2,2.109(9/19/72). 05000244 /

	RECIPIENT ID CODE/NAME	COPIES LTTR ENCL	RECIPIENT ID CODE/NAME	COPIES LTTR ENCL
	PD1-3 LA	3 3	PD1-3 PD	1 1
	JOHNSON, A	1 1		
INTERNAL:	AEOD/DOA	1 1	AEOD/DSP/TPAB	1 1
	NRR/DLPO/LPEB10	1 1	NRR/DOEA/OEAB	1 1
	REG FILE 01	1 1	RGN1	1 1
EXTERNAL:	EG&G BRYCE, J.H	1 1	NRC PDR	1 1
	NSIC	1 1		

NOTE TO ALL "RIDS" RECIPIENTS:

PLEASE HELP US TO REDUCE WASTE! CONTACT THE DOCUMENT CONTROL DESK,
 ROOM P1-37 (EXT. 20079) TO ELIMINATE YOUR NAME FROM DISTRIBUTION
 LISTS FOR DOCUMENTS YOU DON'T NEED!

TOTAL NUMBER OF COPIES REQUIRED: LTTR 14 ENCL 14

mr lwt



ROCHESTER GAS AND ELECTRIC CORPORATION • 89 EAST AVENUE, ROCHESTER N.Y. 14649-0001



ROBERT C. MECREDY
Vice President
Ginna Nuclear Production

TELEPHONE
AREA CODE 716 546-2700

GINNA STATION

May 15, 1991


US Nuclear Regulatory Commission
Document Control Desk
Washington, DC 20555

Subject: Monthly Report for April, 1991
Operating Status Information
R. E. Ginna Nuclear Power Plant
Docket No. 50-244

Dear Sir:

Pursuant to our Technical Specification 6.9.1, attached herewith is the monthly operating status report for Ginna Station for the month of April, 1991.

Very truly yours,


Robert C. Mecredy

RCM/eeh

Attachments

cc: Mr. Thomas T. Martin NRC (1)

9105230125 910430
PDR ADOCK 05000244
R PDR

11
ZE24

OPERATING DATA REPORT

DOCKET NO. 50-244

DATE May 15, 1991

COMPLETED BY

Robert E. Dodge

TELEPHONE (315) 524-4446 ext. 396

OPERATING STATUS

1. Unit Name: R.E. GINNA NUCLEAR POWER PLANT
2. Reporting Period: April, 1991
3. Licensed Thermal Power (MWt): 1520
4. Nameplate Rating (Gross MWe): 490
5. Design Electrical Rating (Net MWe): 470
6. Maximum Dependable Capacity (Gross MWe): 490
7. Maximum Dependable Capacity (Net MWe): 470
8. If Changes Occur in Capacity Ratings (Items Number 3 Through 7) Since Last Report, Give Reasons:

Notes: The unit was shutdown for the 1991 Annual Refueling and Maintenance Outage.

9. Power Level to Which Restricted, If Any (Net MWe):
10. Reasons For Restrictions, If Any:

	This Month	Yr.-to-Date	Cumulative
11. Hours In Report Period	719**	2,879	188,225.45
12. Number of Hours Reactor Was Critical	0	1,933.23	147,672.54
13. Reactor Reserve Shutdown Hours	0	0	1,687.55 *
14. Hours Generator On-Line	0	1,932.75	145,101.13
15. Unit Reserve Shutdown Hours	0	0	8.5 *
16. Gross Thermal Energy Generated (MWH)	0	2,753,088	205,103,785
17. Gross Electrical Energy Generated (MWH)	0	938,665	67,601,139
18. Net Electrical Energy Generated (MWH)	0	891,990	64,161,283
19. Unit Service Factor	0	67.13%	77.25%
20. Unit Availability Factor	0	67.13%	77.26%
21. Unit Capacity Factor (Using MDC Net)	0	65.92%	73.95%
22. Unit Capacity Factor (Using DER Net)	0	65.92%	73.95%
23. Unit Forced Outage Rate	0	0 %	6.25%

24. Shutdowns Scheduled Over Next 6 Months (Type, Date and Duration of Each):

25. If Shut Down At End Of Report Period, Estimated Date of Startup: 05-10-91

26. Units In Test Status (Prior to Commercial Operation):	Forecast	Achieved
INITIAL CRITICALITY	_____	_____
INITIAL ELECTRICITY	_____	_____
COMMERCIAL OPERATION	_____	_____

*CUMULATIVE TOTAL COMMENCING JANUARY 1, 1975

**EASTERN STANDARD TIME TO EASTERN DAYLIGHT SAVINGS TIME

AVERAGE DAILY UNIT POWER LEVEL

DOCKET NO. 50-244
UNIT R.E. Ginna Nuclear Power Plant
DATE May 15, 1991

COMPLETED BY Robert E. Dodge
Robert E. Dodge

TELEPHONE 1 (315) 524-4446 ext. 396

MONTH April, 1991

DAY AVERAGE DAILY POWER LEVEL
(MWe-Net)

1.	<u>-3</u>
2.	<u>-3</u>
3.	<u>-3</u>
4.	<u>-3</u>
5.	<u>-3</u>
6.	<u>-3</u>
7.	<u>-4</u>
8.	<u>-3</u>
9.	<u>-3</u>
10.	<u>-3</u>
11.	<u>-3</u>
12.	<u>-2</u>
13.	<u>-2</u>
14.	<u>-2</u>
15.	<u>-2</u>
16.	<u>-2</u>

DAY AVERAGE DAILY POWER LEVEL
(MWe-Net)

17.	<u>-2</u>
18.	<u>-2</u>
19.	<u>-2</u>
20.	<u>-3</u>
21.	<u>-3</u>
22.	<u>-3</u>
23.	<u>-2</u>
24.	<u>-3</u>
25.	<u>-3</u>
26.	<u>-3</u>
27.	<u>-3</u>
28.	<u>-4</u>
29.	<u>-4</u>
30.	<u>-3</u>
31.	<u>-</u>

INSTRUCTIONS

On this format, list the average daily unit power level in MWe-Net for each day in the reporting month. Compute to the nearest whole megawatt.

UNIT SHUTDOWN AND POWER REDUCTIONS

REPORT MONTH APRIL 1991

DOCKET NO. 50-244

UNIT NAME R.E. GINNA NUCLEAR POWER PLANT

DATE May 15, 1991

COMPLETED BY Robert E. Dodge

TELEPHONE 315-524-4446 x-396

Ginna Station

No.	Date	Type 1	Duration (Hours)	Reason 2	Method of Shutting Down Reactor 3	Licensee Event Report #	System Code 4	Component Code 5	Cause & Corrective Action to Prevent Recurrence
	4-91	S	719	C					The unit was shutdown for Annual Refueling and Maintenance Outage. The unit remained shutdown at the end of the report period.

1

F: Forced
S: Scheduled

2

Reason:
A-Equipment Failure (Explain)
B-Maintenance or Test
C-Refueling
D-Regulatory Restriction
E-Operator Training & License Examination
F-Administrative
G-Operational Error (Explain)
H-Other (Explain)

3

Method:
1-Manual
2-Manual Scram.
3-Automatic Scram.
4-Other (Explain)

4

Exhibit G - Instructions for Preparation of Data Entry Sheets for Licensee Event Report (LER) File (NUREG-0161)

5

Exhibit 1 - Same Source

1869

NARRATIVE SUMMARY OF OPERATING EXPERIENCE

DOCKET NO. 50-244
UNIT R.E. Ginna Nuclear Power Plant
DATE May 15, 1991
COMPLETED BY Robert E. Dodge
TELEPHONE 1 (315) 524-4446 ext. 396

MONTH April 1991

The unit was shutdown for the Annual Refueling and Maintenance Outage. The unit remained shutdown at the end of the report period.

