

# ACCELERATED DISTRIBUTION DEMONSTRATION SYSTEM

## REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR: 9106180283 DOC. DATE: 91/06/07 NOTARIZED: NO DOCKET #  
 FACIL: 50-244 Robert Emmet Ginna Nuclear Plant, Unit 1, Rochester G 05000244

AUTH. NAME: AUTHORITY AFFILIATION  
 MECREDY, R.C. Rochester Gas & Electric Corp.  
 RECIP. NAME: RECIPIENT AFFILIATION  
 JOHNSON, A.R. Project Directorate I-3

SUBJECT: Forwards summary of test results re control rod worth measurements taken during Cycle 21 startup, per 900925 ltr summarizing telcon between util, Westinghouse & NRC.

DISTRIBUTION CODE: A001D COPIES RECEIVED: LTR 1 ENCL 0 SIZE: 2  
 TITLE: OR Submittal: General Distribution

NOTES: License Exp date in accordance with 10CFR2, 2.109(9/19/72). 05000244

	RECIPIENT ID CODE/NAME	COPIES		RECIPIENT ID CODE/NAME	COPIES	
		LTTR	ENCL		LTTR	ENCL
	PD1-3 LA	1	1	PD1-3 PD	1	1
	JOHNSON, A	2	2			
INTERNAL:	NRR/DET/ECMB 7D	1	1	NRR/DET/ESGB	1	1
	NRR/DOEA/OTSB11	1	1	NRR/DST 8E2	1	1
	NRR/DST/SELB 7E	1	1	NRR/DST/SICB8H7	1	1
	NRR/DST/SRXB 8E	1	1	NUDOCS-ABSTRACT	1	1
	OC/LFMB	1	0	OGC/HDS1	1	0
	REG FILE 01	1	1	RES/DSIR/EIB	1	1
EXTERNAL:	NRC PDR	1	1	NSIC	1	1

Cont NO  
 p249075100

NOTE TO ALL "RIDS" RECIPIENTS:

PLEASE HELP US TO REDUCE WASTE! CONTACT THE DOCUMENT CONTROL DESK, ROOM P1-37 (EXT. 20079) TO ELIMINATE YOUR NAME FROM DISTRIBUTION LISTS FOR DOCUMENTS YOU DON'T NEED!

TOTAL NUMBER OF COPIES REQUIRED: LTTR 18 ENCL 16


MA 4

ME CYS MONITORING MONITORING MONITORING

[illegible]



ROCHESTER GAS AND ELECTRIC CORPORATION • 89 EAST AVENUE, ROCHESTER N.Y. 14649-0001



ROBERT C. MECREDY  
Vice President  
Ginna Nuclear Production

TELEPHONE  
AREA CODE 716 546-2700

June 7, 1991

U.S. Nuclear Regulatory Commission  
Document Control Desk  
Attn: Allen R. Johnson  
Project Directorate I-3  
Washington, D.C. 20555

Subject: Results of Control Rod Worth Measurements  
Taken During Cycle 21 Startup  
R.E. Ginna Nuclear Power Plant  
Docket No. 50-244

Reference: 1. Letter from R. C. Mecredy (RG&E) to A. R. Johnson  
(NRC), dated September 25, 1990, "Summary of  
Telephone Call Concerning Control Rod Worth  
Measurements."

Dear Mr. Johnson:

Reference 1 summarized a telephone call between RG&E, Westinghouse, and the NRC. During that telephone call RG&E agreed to provide the NRC with the results of the modified boron end point test to measure RCCA bank worths. Attached is a summary of the test results. The test was performed during startup physics testing for Cycle 21.

Very truly yours,

*Robert C. Mecredy*  
Robert C. Mecredy

RWE/168  
Attachment


xc: Mr. Allen R. Johnson (Mail Stop 14D1)  
Project Directorate I-3  
Washington, D.C. 20555

U.S. Nuclear Regulatory Commission  
Region I  
475 Allendale Road  
King of Prussia, PA 19406

Ginna Senior Resident Inspector

*Handwritten notes:*  
A00/  
11/1  
Cert No  
1249 075100

9106180283 910607  
PDR ADOCK 05000244  
PDR



# R.E.Ginna Cycle 21 Bank Worth Data

Bank ID	Worth (ppm)	Error (%)	Worth (pcm)	Error (%)
D	86	1.2%	832.4	0.9%
B	80	-4.8%	758.6	-7.4%
C	89	0.0%	844.0	-2.1%
A	111	11.0%	1074.2	9.7%
S	177	9.9%	1715.6	9.7%
TOTAL	543	4.6%	5224.8	3.5%

