

# ACCELERATED DISTRIBUTION DEMONSTRATION SYSTEM

## REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR: 9107190147 DOC. DATE: ~~91/06/30~~ NOTARIZED: NO DOCKET #  
 FACIL: 50-244 Robert Emmet Ginna Nuclear Plant, Unit 1, Rochester G 05000244  
 AUTH. NAME AUTHOR AFFILIATION  
 DODGE, R.E. Rochester Gas & Electric Corp.  
 MECREDY, R.C. Rochester Gas & Electric Corp.  
 RECIP. NAME RECIPIENT AFFILIATION

SUBJECT: Monthly operating rept for June 1991 for RE Ginna Nuclear  
 Power Plant. W/910715 Ltr.

DISTRIBUTION CODE: IE24D COPIES RECEIVED: LTR 1 ENCL 1 SIZE: 5  
 TITLE: Monthly Operating Report (per Tech Specs)

NOTES: License Exp date in accordance with 10CFR2,2.109(9/19/72). 05000244 /

	RECIPIENT		COPIES			RECIPIENT		COPIES	
	ID CODE/NAME		LTTR	ENCL		ID CODE/NAME		LTTR	ENCL
	PD1-3 LA		3	3		PD1-3 PD		1	1
	JOHNSON, A		1	1					
INTERNAL:	AEOD/DOA		1	1		AEOD/DSP/TPAB		1	1
	NRR/DLPQ/LPEB10		1	1		NRR/DOEA/OEAB		1	1
	<del>REG FILE 041</del>		1	1		RGN1		1	1
EXTERNAL:	EG&G BRYCE, J.H		1	1		NRC PDR		1	1
	NSIC		1	1					

NOTE TO ALL "RIDS" RECIPIENTS:

PLEASE HELP US TO REDUCE WASTE! CONTACT THE DOCUMENT CONTROL DESK,  
 ROOM P1-37 (EXT. 20079) TO ELIMINATE YOUR NAME FROM DISTRIBUTION  
 LISTS FOR DOCUMENTS YOU DON'T NEED!


TOTAL NUMBER OF COPIES REQUIRED: LTTR 14 ENCL 14

MR





ROCHESTER GAS AND ELECTRIC CORPORATION • 89 EAST AVENUE, ROCHESTER N.Y. 14649-0001



ROBERT C. MECREDY  
Vice President  
Ginna Nuclear Production

TELEPHONE  
AREA CODE 716 546-2700

GINNA STATION

July 15, 1991


US Nuclear Regulatory Commission  
Document Control Desk  
Washington, DC 20555

Subject: Monthly Report for June, 1991  
Operating Status Information  
R. E. Ginna Nuclear Power Plant  
Docket No. 50-244

Dear Sir:

Pursuant to our Technical Specification 6.9.1, attached herewith is the monthly operating status report for Ginna Station for the month of June, 1991.

Very truly yours,

  
Robert C. Mecredy

RCM/eeh

Attachments

cc: Mr. Thomas T. Martin NRC (1)

9107190147 910630  
PDR ADCK 05000244  
RJR PDR

IE24  
11

## OPERATING DATA REPORT

DOCKET NO. 50-244  
 DATE July 15, 1991  
 COMPLETED BY Robert E. Dodge  
 Robert E. Dodge  
 TELEPHONE (315) 524-4446 ext. 396

## OPERATING STATUS

1. Unit Name: R.E. GINNA NUCLEAR POWER PLANT
2. Reporting Period: June 1991
3. Licensed Thermal Power (MWt): 1520
4. Nameplate Rating (Gross MWe): 490
5. Design Electrical Rating (Net MWe): 470
6. Maximum Dependable Capacity (Gross MWe): 490
7. Maximum Dependable Capacity (Net MWe): 470

Notes: The unit operated at approximately 100% reactor power level for the entire report period.

8. If Changes Occur in Capacity Ratings (Items Number 3 Through 7) Since Last Report, Give Reasons:

9. Power Level to Which Restricted, If Any (Net MWe):
10. Reasons For Restrictions, If Any:

	This Month	Yr.-to-Date	Cumulative
11. Hours In Report Period	720	4,343	189,689.45
12. Number of Hours Reactor Was Critical	720	3,174.65	148,193.96
13. Reactor Reserve Shutdown Hours	0	0	1,687.55 *
14. Hours Generator On-Line	720	3,143	146,311.38
15. Unit Reserve Shutdown Hours	0	0	8.5 *
16. Gross Thermal Energy Generated (MWH)	1,065,760	4,418,130	206,768,827
17. Gross Electrical Energy Generated (MWH)	360,011	1,500,094	68,162,568
18. Net Electrical Energy Generated (MWH)	342,367	1,424,458	64,693,751
19. Unit Service Factor	100%	72.37%	77.30%
20. Unit Availability Factor	100%	72.37%	77.30%
21. Unit Capacity Factor (Using MDC Net)	101.17%	69.78%	73.97%
22. Unit Capacity Factor (Using DER Net)	101.17%	69.78%	73.97%
23. Unit Forced Outage Rate	0	0.21%	6.21%

24. Shutdowns Scheduled Over Next 6 Months (Type, Date and Duration of Each):

25. If Shut Down At End Of Report Period, Estimated Date of Startup: 05-10-91

26. Units In Test Status (Prior to Commercial Operation):	Forecast	Achieved
INITIAL CRITICALITY	_____	_____
INITIAL ELECTRICITY	_____	_____
COMMERCIAL OPERATION	_____	_____

\*CUMULATIVE TOTAL COMMENCING JANUARY 1, 1975

## AVERAGE DAILY UNIT POWER LEVEL

DOCKET NO. 50-244  
UNIT R.E. Ginna Nuclear Power Plant  
DATE July, 15, 1991

COMPLETED BY Robert E. Dodge  
Robert E. Dodge

TELEPHONE 1 (315) 524-4446 ext. 396

MONTH June 1991

DAY AVERAGE DAILY POWER LEVEL  
(MWe-Net)

1.	<u>475</u>
2.	<u>476</u>
3.	<u>475</u>
4.	<u>476</u>
5.	<u>474</u>
6.	<u>475</u>
7.	<u>475</u>
8.	<u>474</u>
9.	<u>473</u>
10.	<u>472</u>
11.	<u>471</u>
12.	<u>472</u>
13.	<u>471</u>
14.	<u>471</u>
15.	<u>472</u>
16.	<u>472</u>

DAY AVERAGE DAILY POWER LEVEL  
(MWe-Net)

17.	<u>469</u>
18.	<u>470</u>
19.	<u>472</u>
20.	<u>468</u>
21.	<u>467</u>
22.	<u>473</u>
23.	<u>479</u>
24.	<u>478</u>
25.	<u>477</u>
26.	<u>476</u>
27.	<u>474</u>
28.	<u>470</u>
29.	<u>470</u>
30.	<u>473</u>
31.	<u>-</u>

## INSTRUCTIONS

On this format, list the average daily unit power level in MWe-Net for each day in the reporting month. Compute to the nearest whole megawatt.

# UNIT SHUTDOWN AND POWER REDUCTIONS

REPORT MONTH JUNE 1991

DOCKET NO. 50-244

UNIT NAME R.E. GINNA NUCLEAR POWER PLANT

DATE July 15, 1991

COMPLETED BY Robert E. Dodge

TELEPHONE 315-524-4446 ext. 396  
Ginna Station

No.	Date	Type 1	Duration (Hours)	Reason 2	Method of Shutting Down Reactor 3	Licensee Event Report #	System Code 4	Component Code 5	Cause & Corrective Action to Prevent Recurrence
									No unit shutdowns or power reductions this report period.

1

F: Forced  
S: Scheduled

2

Reason:  
A-Equipment Failure (Explain)  
B-Maintenance or Test  
C-Refueling  
D-Regulatory Restriction  
E-Operator Training & License Examination  
F-Administrative  
G-Operational Error (Explain)  
H-Other (Explain)

3

Method:  
1-Manual  
2-Manual Scram.  
3-Automatic Scram.  
4-Other (Explain)

4

Exhibit G - Instructions for Preparation of Data Entry Sheets for Licensee Event Report (LER) File (NUREG-0161)

5

Exhibit 1 - Same Source



NARRATIVE SUMMARY OF OPERATING EXPERIENCE

DOCKET NO. 50-244  
UNIT R.E. Ginna Nuclear Power Plant  
DATE July 15, 1991  
COMPLETED BY Robert E. Dodge  
TELEPHONE 1 (315) 524-4446 ext. 396

MONTH June 1991

The unit operated at approximately 100% reactor power level for the entire report period.