

ACCELERATED DISTRIBUTION DEMONSTRATION SYSTEM

REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR: 9108270089 DOC. DATE: ~~91/07/31~~ NOTARIZED: NO DOCKET #
 FACIL: 50-244 Robert Emmet Ginna Nuclear Plant, Unit 1, Rochester G 05000244
 AUTH. NAME AUTHOR AFFILIATION
 DODGE, R.E. Rochester Gas & Electric Corp.
 MECREDY, R.C. Rochester Gas & Electric Corp.
 RECIP. NAME RECIPIENT AFFILIATION

SUBJECT: Monthly operating ~~rept~~ for Jul 1991 for R.E. Ginna Nuclear
 Power Station. W 910815 tr.

DISTRIBUTION CODE: IE24D COPIES RECEIVED: LTR 1 ENCL 1 SIZE: 5
 TITLE: Monthly Operating Report (per Tech Specs)

NOTES: License Exp date in accordance with 10CFR2,2.109(9/19/72). 05000244 /

	RECIPIENT		COPIES			RECIPIENT		COPIES		
	ID CODE/NAME		LTTR	ENCL		ID CODE/NAME		LTTR	ENCL	
	PD1-3 LA		3	3		PD1-3 PD		1	1	
	JOHNSON, A		1	1						
INTERNAL:	AEOD/DOA		1	1		AEOD/DSP/TPAB		1	1	
	<u>NRR-DTPO/LPEB10</u>		1	1		NRR/DOEA/OEAB		1	1	
	REG FILE 01		1	1		RGN1		1	1	
EXTERNAL:	EG&G BRYCE, J.H		1	1		NRC PDR		1	1	
	NSIC		1	1						

NOTE TO ALL "RIDS" RECIPIENTS:


PLEASE HELP US TO REDUCE WASTE! CONTACT THE DOCUMENT CONTROL DESK,
 ROOM P1-37 (EXT. 20079) TO ELIMINATE YOUR NAME FROM DISTRIBUTION
 LISTS FOR DOCUMENTS YOU DON'T NEED!

TOTAL NUMBER OF COPIES REQUIRED: LTTR 14 ENCL 14

MR



ROCHESTER GAS AND ELECTRIC CORPORATION • 89 EAST AVENUE, ROCHESTER N.Y. 14649-0001



ROBERT C. MECREDY
Vice President
Ginna Nuclear Production

TELEPHONE
AREA CODE 716 546-2700

GINNA STATION

August 15, 1991

US Nuclear Regulatory Commission
Document Control Desk
Washington, DC 20555

Subject: Monthly Report for July, 1991
Operating Status Information
R. E. Ginna Nuclear Power Plant
Docket No. 50-244

Dear Sir:

Pursuant to our Technical Specification 6.9.1, attached herewith is the monthly operating status report for Ginna Station for the month of July, 1991.


Very truly yours,


Robert C. Mecredy

RCM/eeh

Attachments

cc: Mr. Thomas T. Martin NRC (1)



7624 11

OPERATING DATA REPORT

DOCKET NO. 50-244

DATE August 15, 1991

COMPLETED BY Robert E. Dodge
Robert E. Dodge

TELEPHONE (315) 524-4446 ext. 396

OPERATING STATUS

1. Unit Name: R.E. GINNA NUCLEAR POWER PLANT
2. Reporting Period: July 1991
3. Licensed Thermal Power (MWt): 1520
4. Nameplate Rating (Gross MWe): 490
5. Design Electrical Rating (Net MWe): 470
6. Maximum Dependable Capacity (Gross MWe): 490
7. Maximum Dependable Capacity (Net MWe): 470
8. If Changes Occur in Capacity Ratings (Items Number 3 Through 7) Since Last Report, Give Reasons:

Notes: The unit operated at approximately 100% reactor power level for the entire report period.

9. Power Level to Which Restricted, If Any (Net MWe):
10. Reasons For Restrictions, If Any:

	This Month	Yr.-to-Date	Cumulative
11. Hours In Report Period	744	5,087	190,433.45
12. Number of Hours Reactor Was Critical	744	3,918.65	149,657.96
13. Reactor Reserve Shutdown Hours	0	0	1,687.55 *
14. Hours Generator On-Line	744	3,887	147,055.38
15. Unit Reserve Shutdown Hours	0	0	8.5 *
16. Gross Thermal Energy Generated (MWH)	1,100,696	5,518,826	207,869,523
17. Gross Electrical Energy Generated (MWH)	367,365	1,867,459	68,529,933
18. Net Electrical Energy Generated (MWH)	348,830	1,773,288	65,042,581
19. Unit Service Factor	100%	76.41%	77.38%
20. Unit Availability Factor	100%	76.41%	77.39%
21. Unit Capacity Factor (Using MDC Net)	99.76%	74.17%	74.08%
22. Unit Capacity Factor (Using DER Net)	99.76%	74.17%	74.08%
23. Unit Forced Outage Rate	0	0.17%	6.18%

24. Shutdowns Scheduled Over Next 6 Months (Type, Date and Duration of Each):

25. If Shut Down At End Of Report Period, Estimated Date of Startup: 05-10-91

26. Units In Test Status (Prior to Commercial Operation):	Forecast	Achieved
INITIAL CRITICALITY	_____	_____
INITIAL ELECTRICITY	_____	_____
COMMERCIAL OPERATION	_____	_____

*CUMULATIVE TOTAL COMMENCING JANUARY 1, 1975

1944

AVERAGE DAILY UNIT POWER LEVEL

DOCKET NO. 50-244
UNIT R.E. Ginna Nuclear Power Plant
DATE August 15, 1991

COMPLETED BY Robert E. Dodge
Robert E. Dodge

TELEPHONE 1 (315) 524-4446 ext. 396

MONTH July 1991

DAY AVERAGE DAILY POWER LEVEL
(MWe-Net)


1.	<u>473</u>
2.	<u>477</u>
3.	<u>479</u>
4.	<u>480</u>
5.	<u>479</u>
6.	<u>479</u>
7.	<u>479</u>
8.	<u>474</u>
9.	<u>469</u>
10.	<u>468</u>
11.	<u>466</u>
12.	<u>464</u>
13.	<u>468</u>
14.	<u>467</u>
15.	<u>465</u>
16.	<u>465</u>

DAY AVERAGE DAILY POWER LEVEL
(MWe-Net)

17.	<u>464</u>
18.	<u>464</u>
19.	<u>463</u>
20.	<u>462</u>
21.	<u>460</u>
22.	<u>460</u>
23.	<u>459</u>
24.	<u>457</u>
25.	<u>458</u>
26.	<u>457</u>
27.	<u>459</u>
28.	<u>459</u>
29.	<u>463</u>
30.	<u>475</u>
31.	<u>466</u>

INSTRUCTIONS

On this format, list the average daily unit power level in MWe-Net for each day in the reporting month. Compute to the nearest whole megawatt.



UNIT SHUTDOWN AND POWER REDUCTIONS

REPORT MONTH JULY 1991

DOCKET NO. 50-244

UNIT NAME R.E. GINNA NUCLEAR POWER PLANT

DATE August 15, 1991

COMPLETED BY Robert E. Dodge

TELEPHONE 315-524-4446 x-396

Ginna Station

No.	Date	Type 1	Duration (Hours)	Reason 2	Method of Shutting Down Reactor 3	Licensee Event Report #	System Code 4	Component Code 5	Cause & Corrective Action to Prevent Recurrence
									No unit shutdowns or power reductions this report period.

1

F: Forced
S: Scheduled

2

Reason:
A-Equipment Failure (Explain)
B-Maintenance or Test
C-Refueling
D-Regulatory Restriction
E-Operator Training & License Examination
F-Administrative
G-Operational Error (Explain)
H-Other (Explain)

3

Method:
1-Manual
2-Manual Scram.
3-Automatic Scram.
4-Other (Explain)

4

Exhibit G - Instructions for Preparation of Data Entry Sheets for Licensee Event Report (LER) File (NUREG-0161)

5

Exhibit 1 - Same Source

NARRATIVE SUMMARY OF OPERATING EXPERIENCE

DOCKET NO. 50-244
UNIT R.E. Ginna Nuclear Power Plant
DATE August 15, 1991
COMPLETED BY Robert E. Dodge
TELEPHONE 1 (315) 524-4446 ext. 396

MONTH July 1991

The unit operated at approximately 100% reactor power level for the entire report period.



10/10/10

10/10/10