

ACCELERATED DISTRIBUTION DEMONSTRATION SYSTEM

REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR: 9202240387 DOC. DATE: 92/01/31 NOTARIZED: NO DOCKET #
 FACIL: 50-244 Robert Emmet Ginna Nuclear Plant, Unit 1, Rochester G 05000244
 AUTH. NAME AUTHOR AFFILIATION
 DODGE, R.E. Rochester Gas & Electric Corp.
 MECREDY, R.C. Rochester Gas & Electric Corp.
 RECIP. NAME RECIPIENT AFFILIATION

SUBJECT: Monthly operating rept for Jan 1992 for RE Ginna Nuclear
 Power Plant. W/920218 ltr.

DISTRIBUTION CODE: IE24D COPIES RECEIVED: LTR 1 ENCL 1 SIZE: 5
 TITLE: Monthly Operating Report (per Tech Specs)

NOTES: License Exp date in accordance with 10CFR2,2.109(9/19/72). 05000244

	RECIPIENT		COPIES			RECIPIENT		COPIES	
	ID CODE/NAME		LTTR	ENCL		ID CODE/NAME		LTTR	ENCL
	PD1-3 LA		3	3		PD1-3 PD		1	1
	JOHNSON, A		1	1					
INTERNAL:	AEOD/DOA		1	1		AEOD/DSP/TPAB		1	1
	NRR/DEPQ/LPEB10		1	1		NRR/DOEA/OEAB		1	1
	REG FILE 01		1	1		RGN1		1	1
EXTERNAL:	EG&G BRYCE, J.H		1	1		NRC PDR		1	1
	NSIC		1	1					

NOTE TO ALL "RIDS" RECIPIENTS:


PLEASE HELP US TO REDUCE WASTE! CONTACT THE DOCUMENT CONTROL DESK,
 ROOM P1-37 (EXT. 20079) TO ELIMINATE YOUR NAME FROM DISTRIBUTION
 LISTS FOR DOCUMENTS YOU DON'T NEED!

TOTAL NUMBER OF COPIES REQUIRED: LTTR 14 ENCL 14

MOF
[Signature]



ROCHESTER GAS AND ELECTRIC CORPORATION • 89 EAST AVENUE, ROCHESTER N.Y. 14649-0001



ROBERT C. MECREDY
Vice President
Ginna Nuclear Production

TELEPHONE
AREA CODE 716 546-2700

GINNA STATION

February 18, 1992

US Nuclear Regulatory Commission
Document Control Desk
Washington, DC 20555

Subject: Monthly Report for January, 1992
Operating Status Information
R. E. Ginna Nuclear Power Plant
Docket No. 50-244

Dear Sir:

Pursuant to our Technical Specification 6.9.1, attached herewith is the monthly operating status report for Ginna Station for the month of January, 1992.

Very truly yours,


Robert C. Mecredy

RCM/deb

Attachments

cc: Mr. Thomas T. Martin NRC (1)

9202240387 920131
PDR ADOCK 05000244
R 05000244 PDR

IFB
11

OPERATING DATA REPORT

DOCKET NO. 50-244
 DATE February 18, 1992
 COMPLETED BY Robert E. Dodge
 Robert E. Dodge

TELEPHONE (315) 524-4446 ext. 396

OPERATING STATUS

1. Unit Name: R.E. GINNA NUCLEAR POWER PLANT
2. Reporting Period: January 1992
3. Licensed Thermal Power (MWt): 1520
4. Nameplate Rating (Gross MWe): 490
5. Design Electrical Rating (Net MWe): 470
6. Maximum Dependable Capacity (Gross MWe): 490
7. Maximum Dependable Capacity (Net MWe): 470
8. If Changes Occur in Capacity Ratings (Items Number 3 Through 7) Since Last Report, Give Reasons:

Notes: The unit operated at approximately 98% power level for the entire report period.

9. Power Level to Which Restricted, If Any (Net MWe): _____
10. Reasons For Restrictions, If Any: _____

	This Month	Yr.-to-Date	Cumulative
			**
11. Hours In Report Period	<u>744</u>	<u>744</u>	<u>194,850.45</u>
12. Number of Hours Reactor Was Critical	<u>744</u>	<u>744</u>	<u>154,074.96</u>
13. Reactor Reserve Shutdown Hours	<u>0</u>	<u>0</u>	<u>1,687.55 *</u>
14. Hours Generator On-Line	<u>744</u>	<u>744</u>	<u>151,449.38</u>
15. Unit Reserve Shutdown Hours	<u>0</u>	<u>0</u>	<u>8.5 *</u>
16. Gross Thermal Energy Generated (MWH)	<u>1,106,865</u>	<u>1,106,865</u>	<u>214,321,378</u>
17. Gross Electrical Energy Generated (MWH)	<u>375,904</u>	<u>375,904</u>	<u>70,705,511</u>
18. Net Electrical Energy Generated (MWH)	<u>357,651</u>	<u>357,651</u>	<u>67,110,198</u>
19. Unit Service Factor	<u>100%</u>	<u>100%</u>	<u>77.89%</u>
20. Unit Availability Factor	<u>100%</u>	<u>100%</u>	<u>77.89%</u>
21. Unit Capacity Factor (Using MDC Net)	<u>102.28%</u>	<u>102.28%</u>	<u>74.67%</u>
22. Unit Capacity Factor (Using DER Net)	<u>102.28%</u>	<u>102.28%</u>	<u>74.67%</u>
23. Unit Forced Outage Rate	<u>0%</u>	<u>0%</u>	<u>6.02%</u>

24. Shutdowns Scheduled Over Next 6 Months (Type, Date and Duration of Each):
Annual Refueling and Maintenance Outage: Starting March 27, 1992, Duration: 40 days

25. If Shut Down At End Of Report Period, Estimated Date of Startup: 05-10-91
 26. Units In Test Status (Prior to Commercial Operation):
- | | | |
|----------------------|----------|----------|
| | Forecast | Achieved |
| INITIAL CRITICALITY | _____ | _____ |
| INITIAL ELECTRICITY | _____ | _____ |
| COMMERCIAL OPERATION | _____ | _____ |

*CUMULATIVE TOTAL COMMENCING JANUARY 1, 1975

**CUMULATIVE TOTAL COMMENCING NOVEMBER 8, 1969

AVERAGE DAILY UNIT POWER LEVEL

DOCKET NO. 50-244
UNIT R.E. Ginna Nuclear Power Plant
DATE February 18, 1992
COMPLETED BY Robert E. Dodge

TELEPHONE 1 (315) 524-4446 ext. 396

MONTH January 1992

DAY AVERAGE DAILY POWER LEVEL
(MWe-Net)

1.	<u>478</u>
2.	<u>478</u>
3.	<u>479</u>
4.	<u>478</u>
5.	<u>478</u>
6.	<u>478</u>
7.	<u>478</u>
8.	<u>478</u>
9.	<u>479</u>
10.	<u>479</u>
11.	<u>479</u>
12.	<u>479</u>
13.	<u>479</u>
14.	<u>480</u>
15.	<u>479</u>
16.	<u>479</u>

DAY AVERAGE DAILY POWER LEVEL
(MWe-Net)

17.	<u>479</u>
18.	<u>479</u>
19.	<u>478</u>
20.	<u>479</u>
21.	<u>479</u>
22.	<u>479</u>
23.	<u>479</u>
24.	<u>479</u>
25.	<u>478</u>
26.	<u>478</u>
27.	<u>478</u>
28.	<u>478</u>
29.	<u>479</u>
30.	<u>479</u>
31.	<u>479</u>

INSTRUCTIONS

On this format, list the average daily unit power level in MWe-Net for each day in the reporting month. Compute to the nearest whole megawatt.

UNIT SHUTDOWN AND POWER REDUCTIONS

REPORT MONTH JANUARY 1992

DOCKET NO. 50-244

UNIT NAME R.E. GINNA NUCLEAR POWER PLANT

DATE February 18, 1992

COMPLETED BY Robert E. Dodge

TELEPHONE 315-524-4446 ext. 396
GINNA Station

No.	Date	Type 1	Duration (Hours)	Reason 2	Method of Shutting Down Reactor 3	Licensee Event Report #	System Code 4	Component Code 5	Cause & Corrective Action to Prevent Recurrence
									No power reductions for this month.

1

F: Forced
S: Scheduled

2

Reason:
A-Equipment Failure (Explain)
B-Maintenance or Test
C-Refueling
D-Regulatory Restriction
E-Operator Training & License Examination
F-Administrative
G-Operational Error (Explain)
H-Other (Explain)

3

Method:
1-Manual
2-Manual Scram.
3-Automatic Scram.
4-Other (Explain)

4

Exhibit G - Instructions
for Preparation of Data
Entry Sheets for Licensee
Event Report (LER) File (NUREG-
0161)

5

Exhibit 1 - Same Source

NARRATIVE SUMMARY OF OPERATING EXPERIENCE

DOCKET NO. 50-244
UNIT R.E. Ginna Nuclear Power Plant
DATE February 18, 1992
COMPLETED BY Robert E. Dodge
TELEPHONE 1 (315) 524-4446 ext. 396

MONTH January 1992

The unit operated at approximately 98% reactor power level for the entire report period.