

ACCELERATED DISTRIBUTION DEMONSTRATION SYSTEM

REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR: 9204170010 DOC. DATE: 92/03/31 NOTARIZED: NO DOCKET #
 FACIL: 50-244 Robert Emmet Ginna Nuclear Plant, Unit 1, Rochester G 05000244
 AUTH. NAME AUTHOR AFFILIATION
 DODGE, R.E. Rochester Gas & Electric Corp.
 MECREDY, R.C. Rochester Gas & Electric Corp.
 RECIP. NAME RECIPIENT AFFILIATION

SUBJECT: Monthly operating rept for Mar 1992 for RE Ginna Nuclear
 Power Plant. W/920415 ltr.

DISTRIBUTION CODE: IE24D COPIES RECEIVED: LTR 1 ENCL 1 SIZE: 5
 TITLE: Monthly Operating Report (per Tech Specs)

NOTES: License Exp date in accordance with 10CFR2,2.109(9/19/72). 05000244 /

RECIPIENT ID CODE/NAME	COPIES LTTR ENCL	RECIPIENT ID CODE/NAME	COPIES LTTR ENCL
PD1-3 LA	3 3	PD1-3 PD	1 1
JOHNSON, A	1 1		
INTERNAL: AEOD/DOA	1 1	AEOD/DSP/TPAB	1 1
NRR/DLPO/LPEB10	1 1	NRR/DOEA/OEAB	1 1
<u>REG FILE</u> 01	1 1	RGN1	1 1
EXTERNAL: EG&G BRYCE, J.H	1 1	NRC PDR	1 1
NSIC	1 1		

Cont NO p845731155

NOTE TO ALL "RIDS" RECIPIENTS:


PLEASE HELP US TO REDUCE WASTE! CONTACT THE DOCUMENT CONTROL DESK,
 ROOM P1-37 (EXT. 20079) TO ELIMINATE YOUR NAME FROM DISTRIBUTION
 LISTS FOR DOCUMENTS YOU DON'T NEED!

TOTAL NUMBER OF COPIES REQUIRED: LTTR 14 ENCL 14

MDP
[Signature]



ROCHESTER GAS AND ELECTRIC CORPORATION • 89 EAST AVENUE, ROCHESTER N.Y. 14649-0001



ROBERT C. MECREDY
Vice President
Ginna Nuclear Production

TELEPHONE
AREA CODE 716 546-2700

GINNA STATION

April 15, 1992

US Nuclear Regulatory Commission
Document Control Desk
Washington, DC 20555

Subject: Monthly Report for March, 1992
Operating Status Information
R. E. Ginna Nuclear Power Plant
Docket No. 50-244

Dear Sir:

Pursuant to our Technical Specification 6.9.1, attached herewith is the monthly operating status report for Ginna Station for the month of March, 1992.


Very truly yours,


Robert C. Mecredy

RCM/deb

Attachments

cc: Mr. Thomas T. Martin NRC (1)



Ext No 1645701155
IE24
11

OPERATING DATA REPORT

DOCKET NO. 50-244

DATE April 15, 1992

COMPLETED BY Robert E. Dodge
Robert E. Dodge

TELEPHONE (315) 524-4446 ext. 396

OPERATING STATUS

1. Unit Name: R.E. GINNA NUCLEAR POWER PLANT
2. Reporting Period: March 1992
3. Licensed Thermal Power (MWt): 1520
4. Nameplate Rating (Gross MWe): 490
5. Design Electrical Rating (Net MWe): 470
6. Maximum Dependable Capacity (Gross MWe): 490
7. Maximum Dependable Capacity (Net MWe): 470
8. If Changes Occur in Capacity Ratings (Items Number 3 Through 7) Since Last Report, Give Reasons:

Notes: The unit operated at approximately 97% power level for the entire report period. The unit was removed from service on 3-27-92 for the Annual Refueling and maintenance.

9. Power Level to Which Restricted, If Any (Net MWe): _____
10. Reasons For Restrictions, If Any: _____

	This Month	Yr.-to-Date	Cumulative
			**
11. Hours In Report Period	<u>744</u>	<u>2184</u>	<u>196,290.45</u>
12. Number of Hours Reactor Was Critical	<u>631.30</u>	<u>2021.47</u>	<u>155,343.43</u>
13. Reactor Reserve Shutdown Hours	<u>0</u>	<u>0</u>	<u>1,687.55 *</u>
14. Hours Generator On-Line	<u>625.75</u>	<u>1938.75</u>	<u>152,689.13</u>
15. Unit Reserve Shutdown Hours	<u>0</u>	<u>0</u>	<u>1687.55 *</u>
16. Gross Thermal Energy Generated (MWH)	<u>868,877</u>	<u>2,756,352</u>	<u>215,970,865</u>
17. Gross Electrical Energy Generated (MWH)	<u>293,653</u>	<u>931,728</u>	<u>71,261,335</u>
18. Net Electrical Energy Generated (MWH)	<u>278,439</u>	<u>883,027</u>	<u>67,635,574</u>
19. Unit Service Factor	<u>84.11%</u>	<u>90.83%</u>	<u>77.95%</u>
20. Unit Availability Factor	<u>84.11%</u>	<u>90.83%</u>	<u>77.95%</u>
21. Unit Capacity Factor (Using MDC Net)	<u>79.63%</u>	<u>86.02%</u>	<u>74.69%</u>
22. Unit Capacity Factor (Using DER Net)	<u>79.63%</u>	<u>86.02%</u>	<u>74.69%</u>
23. Unit Forced Outage Rate	<u>1.50%</u>	<u>4.41%</u>	<u>6.03%</u>

24. Shutdowns Scheduled Over Next 6 Months (Type, Date and Duration of Each):
Annual Refueling and Maintenance Outage: Starting March 27, 1992, Duration: 43 days

25. If Shut Down At End Of Report Period, Estimated Date of Startup: 05-07-92
 26. Units In Test Status (Prior to Commercial Operation):
- | | | |
|----------------------|----------|----------|
| | Forecast | Achieved |
| INITIAL CRITICALITY | _____ | _____ |
| INITIAL ELECTRICITY | _____ | _____ |
| COMMERCIAL OPERATION | _____ | _____ |

*CUMULATIVE TOTAL COMMENCING JANUARY 1, 1975

**CUMULATIVE TOTAL COMMENCING NOVEMBER 8, 1969

AVERAGE DAILY UNIT POWER LEVEL

DOCKET NO. 50-244
UNIT R.E. Ginna Nuclear Power Plant
DATE April 15, 1992
COMPLETED BY Robert E. Dodge
Robert E. Dodge

TELEPHONE 1 (315) 524-4446 ext. 396

MONTH March 1992

DAY AVERAGE DAILY POWER LEVEL
(MWe-Net)

1.	<u>54</u>
2.	<u>110</u>
3.	<u>304</u>
4.	<u>475</u>
5.	<u>476</u>
6.	<u>475</u>
7.	<u>476</u>
8.	<u>476</u>
9.	<u>476</u>
10.	<u>478</u>
11.	<u>477</u>
12.	<u>477</u>
13.	<u>478</u>
14.	<u>477</u>
15.	<u>477</u>
16.	<u>476</u>

DAY AVERAGE DAILY POWER LEVEL
(MWe-Net)

17.	<u>476</u>
18.	<u>475</u>
19.	<u>474</u>
20.	<u>473</u>
21.	<u>475</u>
22.	<u>476</u>
23.	<u>475</u>
24.	<u>475</u>
25.	<u>475</u>
26.	<u>476</u>
27.	<u>138</u>
28.	<u>-12</u>
29.	<u>-11</u>
30.	<u>-11</u>
31.	<u>-6</u>

INSTRUCTIONS

On this format, list the average daily unit power level in MWe-Net for each day in the reporting month. Compute to the nearest whole megawatt.

1944

UNIT SHUTDOWN AND POWER REDUCTIONS

REPORT MONTH March

DOCKET NO. 50-244
 UNIT NAME R.E. GINNA NUCLEAR POWER PLANT
 DATE April 15, 1992
 COMPLETED BY Robert E. Dodge
 TELEPHONE (315)-524-4446 Ext 396

No.	Date	Type 1	Duration (Hours)	Reason 2	Method of Shutting Down Reactor 3	Licensee Event Report #	System Code 4	Component Code 5	Cause & Corrective Action to Prevent Recurrence
92-04	3-27-92	S	-	C	1	-	-	-	The Unit was shutdown on March 27 for the Annual Refueling and Maintenance Outage it remained shutdown at the end of the report period.

1

F: Forced
S: Scheduled

2

Reason:
 A-Equipment Failure (Explain)
 B-Maintenance or Test
 C-Refueling
 D-Regulatory Restriction
 E-Operator Training & License Examination
 F-Administrative
 G-Operational Error (Explain)
 H-Other (Explain)

3

Method:
 1-Manual
 2-Manual Scram.
 3-Automatic Scram.
 4-Other (Explain)

4

Exhibit G - Instructions for Preparation of Data Entry Sheets for Licensee Event Report (LER) File (NUREG-0161)

5

Exhibit 1 - Same Source

NARRATIVE SUMMARY OF OPERATING EXPERIENCE

DOCKET NO. 50-244
UNIT R.E. Ginna Nuclear Power Plant
DATE April 15, 1992
COMPLETED BY Robert E. Dodge
TELEPHONE 1 (315) 524-4446 ext. 396

MONTH March 1992

The unit returned to service on 3-1-92 and operated at approximately 97% Reactor Power. On 3-27-92 the unit was removed from service for the Annual Refueling and maintenance outage.