

UNITED STATES OF AMERICA
NUCLEAR REGULATORY COMMISSION

In the Matter of

Rochester Gas and Electric Corporation
(R.E. Ginna Nuclear Power Plant)

)
)
) Docket No. 50-244
)
)

APPLICATION FOR AMENDMENT
TO OPERATING LICENSE

Pursuant to Section 50.90 of the regulations of the U.S. Nuclear Regulatory Commission (the "Commission"), Rochester Gas and Electric Corporation ("RG&E"), holder of Facility Operating License No. DPR-18, hereby requests a change to that license and an amendment to Appendix A of that license pursuant to the guidance provided in Generic Letters 86-10 and 88-12.

This proposed amendment will (1) institute the standard license condition for the Fire Protection Program, (2) removes requirements for fire protection systems from Technical Specifications (TS), (3) removes fire brigade staffing requirements from TS, and (4) adds administrative controls to TS that are consistent with those for other programs implemented by the license condition. The submittal includes the update to the Updated Final Safety Analysis Report (UFSAR) to include the fire protection program removed from Technical Specifications. This proposed amendment is considered to be an improvement to the Technical Specifications.

The proposed Technical Specification change is set forth in Attachment A to this Application. Proposed changes to the operating license are set forth in Attachment B. A safety evaluation is set forth in Attachment C. This evaluation also demonstrates that the proposed change does not involve a significant change in the types or a significant increase in the amounts of effluents or any change in the authorized power level of the facility. As


9204290435 920421
PDR ADOCK 05000244
P PDR




demonstrated in Attachment C, the proposed change does not involve a significant hazards consideration. Proposed changes to the UFSAR are set forth in Attachment D. Marked-up pages of the current Technical Specifications are set forth in Attachment E for informational purposes. This evaluation also demonstrates that the proposed change does not involve a significant change in the fire protection program.

WHEREFORE, Applicant respectfully requests that Appendix A to Facility Operating License No. DPR-18 be amended in the form attached hereto as Attachment A.

Rochester Gas and Electric Corporation


Robert C. Mecredy
Vice President, Ginna Nuclear Production

Subscribed and sworn to before me
on this 24 day of April, 1992


MARIE C. VILLENEUVE
Notary Public, State of New York
Monroe County
Commission Expires October 31, 1992

THE UNIVERSITY OF CHICAGO
LIBRARY
540 EAST 58TH STREET
CHICAGO, ILL. 60637