

ACCELERATED DISTRIBUTION DEMONSTRATION SYSTEM

REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR:9205060105 DOC.DATE: 92/04/23 NOTARIZED: YES DOCKET #
 FACIL:50-244 Robert Emmet Ginna Nuclear Plant, Unit 1, Rochester G 05000244
 AUTH.NAME AUTHOR AFFILIATION
 MECREDY,R.C. Rochester Gas & Electric Corp.
 RECIP.NAME RECIPIENT AFFILIATION
 JOHNSON,A.R. Project Directorate I-3

SUBJECT: Forwards application for amend to License DPR-18,changing
 TSS to redefine snubber visual insp schedule,per Generic Ltr
 90-09 guidance.

DISTRIBUTION CODE: A001D COPIES RECEIVED:LTR/ ENCL 1 SIZE: 2+17
 TITLE: OR Submittal: General Distribution

NOTES:License Exp date in accordance with 10CFR2,2.109(9/19/72). 05000244 /

| RECIPIENT ID CODE/NAME | COPIES | | RECIPIENT ID CODE/NAME | COPIES | |
|---------------------------|--------|------|---------------------------|--------|------|
| | LTTR | ENCL | | LTTR | ENCL |
| PD1-3 LA | 1 | 1 | PD1-3 PD | 1 | 1 |
| JOHNSON,A | 2 | 2 | | | |
| INTERNAL: NRR/DET/ECMB 7D | 1 | 1 | NRR/DET/ESGB | 1 | 1 |
| NRR/DOEA/OTSB11 | 1 | 1 | NRR/DST 8E2 | 1 | 1 |
| NRR/DST/SELB 7E | 1 | 1 | NRR/DST/SICB8H7 | 1 | 1 |
| NRR/DST/SRXB 8E | 1 | 1 | NUDOCS-ABSTRACT | 1 | 1 |
| OC/LEMB | 1 | 0 | OGC/HDS1 | 1 | 0 |
| REG FILE 01 | 1 | 1 | RES/DSIR/EIB | 1 | 1 |
| EXTERNAL: NRC PDR | 1 | 1 | NSIC | 1 | 1 |

NOTE TO ALL "RIDS" RECIPIENTS:

PLEASE HELP US TO REDUCE WASTE! CONTACT THE DOCUMENT CONTROL DESK,
 ROOM P1-37 (EXT. 20079) TO ELIMINATE YOUR NAME FROM DISTRIBUTION
 LISTS FOR DOCUMENTS YOU DON'T NEED!


TOTAL NUMBER OF COPIES REQUIRED: LTTR 18 ENCL 16

R
I
D
S
/
A
D
D
S

AA-4
JMS



ROCHESTER GAS AND ELECTRIC CORPORATION • 89 EAST AVENUE, ROCHESTER N.Y. 14649-0001



ROBERT C. MECREDY
Vice President
Ginna Nuclear Production

TELEPHONE
AREA CODE 716 546-2700

April 23, 1992

U.S. Nuclear Regulatory Commission
Document Control Desk
Attn: Mr. Allen R. Johnson
PWR Project Directorate I-3
Washington, D.C. 20555

Subject: Rochester Gas and Electric Corporation
R.E. Ginna Nuclear Power Plant
Docket No. 50-244

Ref.: (a) Generic Letter 90-09, "Alternative
Requirements For Snubber Visual Inspection
Intervals and Corrective Actions" dated
December 11, 1990

(b) Generic Letter 91-04, "Changes in Technical
Specification Surveillance Intervals to
Accommodate a 24-Month Fuel Cycle", dated April
2, 1991

Dear Mr. Johnson:

Enclosed is an Application for Amendment to Operating License
No. DPR-18 to amend Appendix A of that license to redefine the
snubber visual inspection schedule pursuant to guidance con-
tained in reference (a). Further, an updated bases section was
included to address the provisions of Generic Letter 90-09. In
accordance with reference (b) an evaluation of the proposed
change was performed. The evaluation confirmed that historical
maintenance and surveillance data does not invalidate an
extension to the existing inspection interval.

In accordance with reference (a), the NRC will determine the
number of the license amendment that implements this proposed
change. The first inspection interval determined using the
criteria in reference (a) shall be based upon the previous
inspection interval as established by the requirements in
effect before the amendment that implements this change.

This proposed Amendment should be considered effective 60 days
after RG&E receipt of NRC approval.

Very truly yours,

Robert C. Mecredy
Robert C. Mecredy

0600004

GJW\145
Enclosures

9205060105 920423
PDR ADCK 05000244
P PDR

*Cent No
PDR 5731162
A001
111*

xc: Mr. Allen R. Johnson (Mail Stop 14D1)
Project Directorate I-3
Washington, D.C. 20555

Ms. Donna Ross
New York State Energy Office

U.S. Nuclear Regulatory Commission
Region I
475 Allendale Road
King of Prussia, PA 19406

Ginna Senior Resident Inspector