

ACCELERATED DISTRIBUTION DEMONSTRATION SYSTEM

REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR: 9206240172 DOC. DATE: 92/05/31 NOTARIZED: NO DOCKET #
 FACIL: 50-244 Robert Emmet Ginna Nuclear Plant, Unit 1, Rochester G 05000244
 AUTH. NAME AUTHOR AFFILIATION
 DODGE, R.E. Rochester Gas & Electric Corp.
 MECREDY, R.C. Rochester Gas & Electric Corp.
 RECIP. NAME RECIPIENT AFFILIATION

SUBJECT: Monthly operating rept for June 1992 for RE Ginna NPP.W/
 920616 ltr.

DISTRIBUTION CODE: IE24D COPIES RECEIVED: LTR 1 ENCL 1 SIZE: 5
 TITLE: Monthly Operating Report (per Tech Specs)

NOTES: License Exp date in accordance with 10CFR2,2.109(9/19/72). 05000244

RECIPIENT ID CODE/NAME	COPIES LTTR ENCL	RECIPIENT ID CODE/NAME	COPIES LTTR ENCL
PD1-3 LA	3 3	PD1-3 PD	1 1
JOHNSON, A	1 1		
INTERNAL: AEOD/DOA	1 1	AEOD/DSP/TPAB	1 1
NRR/DEFO/REB10	1 1	NRR/DOEA/OEAB	1 1
<u>REG FILE</u> 01	1 1	RGN1	1 1
EXTERNAL: EG&G BRYCE, J.H	1 1	NRC PDR	1 1
NSIC	1 1		

Cont p748978411

NOTE TO ALL "RIDS" RECIPIENTS:


PLEASE HELP US TO REDUCE WASTE! CONTACT THE DOCUMENT CONTROL DESK,
 ROOM P1-37 (EXT. 20079) TO ELIMINATE YOUR NAME FROM DISTRIBUTION
 LISTS FOR DOCUMENTS YOU DON'T NEED!

TOTAL NUMBER OF COPIES REQUIRED: LTTR 14 ENCL 14

MOR
[Signature]



ROCHESTER GAS AND ELECTRIC CORPORATION • 89 EAST AVENUE, ROCHESTER N.Y. 14649-0001



ROBERT C. MECREDY
Vice President
Ginna Nuclear Production

TELEPHONE
AREA CODE 716 546-2700

GINNA STATION

June 16, 1992

US Nuclear Regulatory Commission
Document Control Desk
Washington, DC 20555

Subject: Monthly Report for May 1992
Operating Status Information
R. E. Ginna Nuclear Power Plant
Docket No. 50-244

Dear Sir:

Pursuant to our Technical Specification 6.9.1, attached herewith is the monthly operating status report for Ginna Station for the month of May 1992.

Very truly yours,


Robert C. Mecredy

Attachments

c: Mr. Thomas T. Martin NRC (1)

240104

9206240172 920616
PDR ADDCK 05000244
R PDR

Ent No P748978411
IFRA
11

OPERATING DATA REPORT

DOCKET NO. 50-244
 DATE June 15, 1992
 COMPLETED BY Robert E. Dodge
 TELEPHONE (315) 524-4446 ext. 396

OPERATING STATUS

1. Unit Name: R.E. GINNA NUCLEAR POWER PLANT
2. Reporting Period: May 1992
3. Licensed Thermal Power (MWt): 1520
4. Nameplate Rating (Gross MWe): 490
5. Design Electrical Rating (Net MWe): 470
6. Maximum Dependable Capacity (Gross MWe): 490
7. Maximum Dependable Capacity (Net MWe): 470
8. If Changes Occur in Capacity Ratings (Items Number 3 Through 7) Since Last Report, Give Reasons:

Notes: The unit was placed on the line on May 11, 1992 at 2212 and remained there at the end of the report period.

9. Power Level to Which Restricted, If Any (Net MWe):
10. Reasons For Restrictions, If Any:

	This Month	Yr.-to-Date	Cumulative
11. Hours In Report Period	744	3647	197,753.45
12. Number of Hours Reactor Was Critical	536.62	2549.09	155,880.05
13. Reactor Reserve Shutdown Hours	0	0	1,687.55
14. Hours Generator On-Line	481.75	2465.50	153,170.88
15. Unit Reserve Shutdown Hours	0	0	8.5
16. Gross Thermal Energy Generated (MWH)	610,650	3,367,002	216,581,515
17. Gross Electrical Energy Generated (MWH)	207,876	1,139,604	71,469,211
18. Net Electrical Energy Generated (MWH)	196,657	1,079,684	67,832,231
19. Unit Service Factor	64.75%	67.60%	77.61%
20. Unit Availability Factor	64.75%	67.60%	77.62%
21. Unit Capacity Factor (Using MDC Net)	56.24%	62.99%	74.34%
22. Unit Capacity Factor (Using DER Net)	56.24%	62.99%	74.34%
23. Unit Forced Outage Rate	0	3.58%	6.01%

24. Shutdowns Scheduled Over Next 6 Months (Type, Date and Duration of Each):

25. If Shut Down At End Of Report Period, Estimated Date of Startup: 05-09-92

26. Units In Test Status (Prior to Commercial Operation):	Forecast	Achieved
INITIAL CRITICALITY		
INITIAL ELECTRICITY		
COMMERCIAL OPERATION		

*CUMULATIVE TOTAL COMMENCING JANUARY 1, 1975

**CUMULATIVE TOTAL COMMENCING NOVEMBER 8, 1969

AVERAGE DAILY UNIT POWER LEVEL

DOCKET NO. 50-244
UNIT R.E. Ginna Nuclear Power Plant
DATE June 15, 1992
COMPLETED BY Robert E. Dodge
Robert E. Dodge

TELEPHONE 1 (315) 524-4446 ext. 396

MONTH May 1992

DAY AVERAGE DAILY POWER LEVEL
(MWe-Net)

1.	<u>-4</u>
2.	<u>-4</u>
3.	<u>-9</u>
4.	<u>-9</u>
5.	<u>-12</u>
6.	<u>-15</u>
7.	<u>-14</u>
8.	<u>-14</u>
9.	<u>-14</u>
10.	<u>-15</u>
11.	<u>-12</u>
12.	<u>106</u>
13.	<u>119</u>
14.	<u>257</u>
15.	<u>275</u>
16.	<u>294</u>

DAY AVERAGE DAILY POWER LEVEL
(MWe-Net)

17.	<u>451</u>
18.	<u>478</u>
19.	<u>478</u>
20.	<u>478</u>
21.	<u>477</u>
22.	<u>477</u>
23.	<u>476</u>
24.	<u>474</u>
25.	<u>474</u>
26.	<u>477</u>
27.	<u>478</u>
28.	<u>480</u>
29.	<u>479</u>
30.	<u>480</u>
31.	<u>480</u>

INSTRUCTIONS

On this format, list the average daily unit power level in MWe-Net for each day in the reporting month. Compute to the nearest whole megawatt.

UNIT SHUTDOWN AND POWER REDUCTIONS

DOCKET NO. 50-244
 UNIT NAME R.E. GINNA NUCLEAR POWER PLANT
 DATE June 15, 1992
 COMPLETED BY _____
 TELEPHONE (315)524-4446 Ext. 396

REPORT MONTH May 1992

No.	Date	Type 1	Duration (Hours)	Reason 2	Method of Shutting Down Reactor 3	Licensee Event Report #	System Code 4	Component Code 5	Cause & Corrective Action to Prevent Recurrence
									The unit was placed on the line May 11 at 2212 and remained on the line at the end of report period.

1
 F: Forced
 S: Scheduled

2
 Reason:
 A-Equipment Failure (Explain)
 B-Maintenance or Test
 C-Refueling
 D-Regulatory Restriction
 E-Operator Training & License Examination
 F-Administrative
 G-Operational Error (Explain)
 H-Other (Explain)

3
 Method:
 1-Manual
 2-Manual Scram.
 3-Automatic Scram.
 4-Other (Explain)

4
 Exhibit G - Instructions
 for Preparation of Data
 Entry Sheets for Licensee
 Event Report (LER) File (NUREG-
 0161)

5
 Exhibit 1 - Same Source

NARRATIVE SUMMARY OF OPERATING EXPERIENCE.

DOCKET NO. 50-244
UNIT R.E. Ginna Nuclear Power Plant
DATE June 15, 1992
COMPLETED BY *Robert E. Dodge*
Robert E. Dodge
TELEPHONE 1 (315) 524-4446 ext. 396

MONTH May, 1992

The unit was placed on the line on May 11 at 2212 following the Annual Refueling and Maintenance Outage..