

ACCELERATED DISTRIBUTION DEMONSTRATION SYSTEM

REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR:9207220319 DOC.DATE: 92/06/30 NOTARIZED: NO DOCKET #
 FACIL:50-244 Robert Emmet Ginna Nuclear Plant, Unit 1, Rochester G 05000244
 AUTH.NAME . AUTHOR AFFILIATION
 DODGE,R.E. Rochester Gas & Electric Corp.
 MECREDY,R.C. Rochester Gas & Electric Corp.
 RECIP.NAME RECIPIENT AFFILIATION

SUBJECT: Monthly operating rept for June 1992 for GNPP.W/920715 ltr.

DISTRIBUTION CODE: IE24D COPIES RECEIVED:LTR 1 ENCL 1 SIZE: 5
 TITLE: Monthly Operating Report (per Tech Specs)

NOTES:License Exp date in accordance with 10CFR2,2.109(9/19/72). 05000244

RECIPIENT ID CODE/NAME	COPIES LTTR ENCL	RECIPIENT ID CODE/NAME	COPIES LTTR ENCL
PD1-3 LA	3 3	PD1-3 PD	1 1
JOHNSON,A	1 1		
INTERNAL: AEOD/DOA	1 1	AEOD/DSP/TPAB	1 1
NRR/DLPQ/LPEB10	1 1	NRR/DOEA/OEAB	1 1
<u>REG FILE</u> 01	1 1	RGN1	1 1
EXTERNAL: EG&G BRYCE,J.H	1 1	NRC PDR	1 1
NSIC	1 1		

Cont NO
 p748978423

NOTE TO ALL "RIDS" RECIPIENTS:

PLEASE HELP US TO REDUCE WASTE! CONTACT THE DOCUMENT CONTROL DESK,
 ROOM P1-37 (EXT. 20079) TO ELIMINATE YOUR NAME FROM DISTRIBUTION
 LISTS FOR DOCUMENTS YOU DON'T NEED!

TOTAL NUMBER OF COPIES REQUIRED: LTTR 14 ENCL 14



ROCHESTER GAS AND ELECTRIC CORPORATION • 89 EAST AVENUE, ROCHESTER N.Y. 14649-0001



ROBERT C. MECREDY
Vice President
Ginna Nuclear Production

TELEPHONE
AREA CODE 716 546-2700

GINNA STATION

July 15, 1992


US Nuclear Regulatory Commission
Document Control Desk
Washington, DC 20555

Subject: Monthly Report for June, 1992
Operating Status Information
R. E. Ginna Nuclear Power Plant
Docket No. 50-244

Dear Sir:

Pursuant to our Technical Specification 6.9.1, attached herewith is the monthly operating status report for Ginna Station for the month of June, 1992.

Very truly yours,


Robert C. Mecredy

RCM/eeh

Attachments

cc: Mr. Thomas T. Martin NRC (1)

220048

9207220319 920630
PDR ADDCK 05000244
R PDR

Ent No
P748976A23
IF24
11

OPERATING DATA REPORT

-1-

DOCKET NO. 50-244
 DATE July 15, 1992
 COMPLETED BY Robert E. Dodge
 Robert E. Dodge

TELEPHONE (315) 524-4446 ext. 396

OPERATING STATUS

1. Unit Name: R.E. GINNA NUCLEAR POWER PLANT
2. Reporting Period: June 1992
3. Licensed Thermal Power (MWt): 1520
4. Nameplate Rating (Gross MWe): 490
5. Design Electrical Rating (Net MWe): 470
6. Maximum Dependable Capacity (Gross MWe): 490
7. Maximum Dependable Capacity (Net MWe): 470
8. If Changes Occur in Capacity Ratings (Items Number 3 Through 7) Since Last Report, Give Reasons:

Notes: The unit operated at approx.
 97% reactor power level except
 for the event detailed on
 page 4 of this report.

9. Power Level to Which Restricted, If Any (Net MWe): _____
10. Reasons For Restrictions, If Any: _____

	This Month	Yr.-to-Date	Cumulative
			**
11. Hours In Report Period	720	4,367	198,473.45
12. Number of Hours Reactor Was Critical	667.62	3,216.71	156,547.67
13. Reactor Reserve Shutdown Hours	0	0	1,687.55 *
14. Hours Generator On-Line	655.25	3,120.75	153,826.13
15. Unit Reserve Shutdown Hours	0	0	8.5 *
16. Gross Thermal Energy Generated (MWH)	948,520	4,315,522	217,530,035
17. Gross Electrical Energy Generated (MWH)	321,700	1,461,304	71,790,911
18. Net Electrical Energy Generated (MWH)	305,850	1,385,534	68,138,081
19. Unit Service Factor	91%	71.46%	77.66%
20. Unit Availability Factor	91%	71.46%	77.66%
21. Unit Capacity Factor (Using MDC Net)	90.4%	67.50%	74.40%
22. Unit Capacity Factor (Using DER Net)	90.4%	67.50%	74.40%
23. Unit Forced Outage Rate	9.0%	4.77%	6.02%

24. Shutdowns Scheduled Over Next 6 Months (Type, Date and Duration of Each):

25. If Shut Down At End Of Report Period, Estimated Date of Startup: 05-09-92

26. Units In Test Status (Prior to Commercial Operation):	Forecast	Achieved
INITIAL CRITICALITY	_____	_____
INITIAL ELECTRICITY	_____	_____
COMMERCIAL OPERATION	_____	_____

*CUMULATIVE TOTAL COMMENCING JANUARY 1, 1975

**CUMULATIVE TOTAL COMMENCING NOVEMBER 8, 1969

AVERAGE DAILY UNIT POWER LEVEL

DOCKET NO. 50-244
 UNIT R.E. Ginna Nuclear Power Plant
 DATE July 15, 1992
 COMPLETED BY Robert E. Dodge
 Robert E. Dodge

TELEPHONE 1 (315) 524-4446 ext. 396

MONTH June 1992

DAY AVERAGE DAILY POWER LEVEL
(MWe-Net)

1.	<u>478</u>
2.	<u>479</u>
3.	<u>478</u>
4.	<u>478</u>
5.	<u>479</u>
6.	<u>479</u>
7.	<u>479</u>
8.	<u>478</u>
9.	<u>105</u>
10.	<u>-9</u>
11.	<u>-6</u>
12.	<u>236</u>
13.	<u>440</u>
14.	<u>475</u>
15.	<u>476</u>
16.	<u>476</u>

DAY AVERAGE DAILY POWER LEVEL
(MWe-Net)

17.	<u>478</u>
18.	<u>480</u>
19.	<u>480</u>
20.	<u>478</u>
21.	<u>478</u>
22.	<u>478</u>
23.	<u>478</u>
24.	<u>478</u>
25.	<u>478</u>
26.	<u>477</u>
27.	<u>476</u>
28.	<u>476</u>
29.	<u>477</u>
30.	<u>475</u>
31.	<u>-</u>

INSTRUCTIONS

On this format, list the average daily unit power level in MWe-Net for each day in the reporting month. Compute to the nearest whole megawatt.

UNIT SHUTDOWN AND POWER REDUCTIONS

REPORT MONTH JUNE 1992

DOCKET NO. 50-244

UNIT NAME: R.E. GINNA NUCLEAR POWER PLANT

DATE: July 15, 1992

COMPLETED BY: Robert E. Dodge

TELEPHONE: (315)524-4446 ext. 396
Ginna Station

No.	Date	Type 1	Duration (Hours)	Reason 2	Method of Shutting Down Reactor 3	Licensee Event Report #	System Code 4	Component Code 5	Cause & Corrective Action to Prevent Recurrence
92-05	6-9-92	F	42.48	A	1	-	-	-	Rupture in a Preseparator Tank. Ultrasonic testing of both tanks review of corrosion control program. Repairs made to A & B Preseparator Tanks.

1

F: Forced
S: Scheduled

2

Reason:
A-Equipment Failure (Explain)
B-Maintenance or Test
C-Refueling
D-Regulatory Restriction
E-Operator Training & License Examination
F-Administrative
G-Operational Error (Explain)
H-Other (Explain)

3

Method:
1-Manual
2-Manual Scram.
3-Automatic Scram.
4-Other (Explain)

4

Exhibit G - Instructions for Preparation of Data Entry Sheets for Licensee Event Report (LER) File (NUREG-0161)

5

Exhibit 1 - Same Source

NARRATIVE SUMMARY OF OPERATING EXPERIENCE

DOCKET NO. 50-244
UNIT R.E. Ginna Nuclear Power Plant
DATE July 15, 1992
COMPLETED BY Robert E. Dodge
TELEPHONE 1 (315) 524-4446 ext. 396

MONTH June, 1992

The unit was removed from service on June 9, 1992 at 0612 following a rupture in the "A" Preseparator Tank. The unit returned to service on June 11, 1992 at 2300 and remained on the line at the end of the report period.

