

ACCELERATED DISTRIBUTION DEMONSTRATION SYSTEM

REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR: 9208180027 DOC. DATE: ~~92/07/31~~ NOTARIZED: NO DOCKET #
FACIL: 50-244 Robert Emmet Ginna Nuclear Plant, Unit 1, Rochester G 05000244
AUTH. NAME AUTHOR AFFILIATION
DODGE, R. E. Rochester Gas & Electric Corp.
MECREDY, R. C. Rochester Gas & Electric Corp.
RECIP. NAME RECIPIENT AFFILIATION

SUBJECT: Monthly operating rept for Jul 1992 for RE Ginna Nuclear
Power Plant. W/920814 ltr.

DISTRIBUTION CODE: IE24D COPIES RECEIVED: LTR 1 ENCL 1 SIZE: 5
TITLE: Monthly Operating Report (per Tech Specs)

NOTES: License Exp date in accordance with 10CFR2.2.109(9/19/72). 05000244

| | RECIPIENT ID CODE/NAME | COPIES LTTR ENCL | RECIPIENT ID CODE/NAME | COPIES LTTR ENCL |
|-----------|---------------------------|---------------------|---------------------------|---------------------|
| | PD1-3 LA | 3 3 | PD1-3 PD | 1 1 |
| | JOHNSON, A | 1 1 | | |
| INTERNAL: | AEOD/DOA | 1 1 | AEOD/DSP/TPAB | 1 1 |
| | NRR/DLPG/LPEB10 | 1 1 | NRR/DOEA/OEAB | 1 1 |
| | <u>REG FILE</u> 01 | 1 1 | RGN1 | 1 1 |
| EXTERNAL: | EG&G BRYCE, J. H | 1 1 | NRC PDR | 1 1 |
| | NSIC | 1 1 | | |

Cont #

P748978444

NOTE TO ALL "RIDS" RECIPIENTS:


PLEASE HELP US TO REDUCE WASTE! CONTACT THE DOCUMENT CONTROL DESK,
ROOM P1-37 (EXT. 20079) TO ELIMINATE YOUR NAME FROM DISTRIBUTION
LISTS FOR DOCUMENTS YOU DON'T NEED!

TOTAL NUMBER OF COPIES REQUIRED: LTTR 14 ENCL 14

MR



ROCHESTER GAS AND ELECTRIC CORPORATION • 89 EAST AVENUE, ROCHESTER N.Y. 14649-0001



ROBERT C. MECREDY
Vice President
Ginna Nuclear Production

TELEPHONE
AREA CODE 716 546-2700

GINNA STATION

August 14, 1992


US Nuclear Regulatory Commission
Document Control Desk
Washington, DC 20555

Subject: Monthly Report for July, 1992
Operating Status Information
R. E. Ginna Nuclear Power Plant
Docket No. 50-244

Dear Sir:

Pursuant to our Technical Specification 6.9.1, attached herewith is the monthly operating status report for Ginna Station for the month of July, 1992.

Very truly yours,


Robert C. Mecredy

RCM/

Attachments

cc: Mr. Thomas T. Martin NRC (1)

*cert #
p 748978444*

9208180027 920731
PDR ADCK 05000244
R PDR

JE24 11

OPERATING DATA REPORT

-1-

DOCKET NO. 50-244
 DATE August 14, 1992
 COMPLETED BY Robert E. Dodge
 Robert E. Dodge

TELEPHONE (315) 524-4446 ext. 396

OPERATING STATUS

1. Unit Name: R.E. GINNA NUCLEAR POWER PLANT
2. Reporting Period: July 1992
3. Licensed Thermal Power (MWt): 1520
4. Nameplate Rating (Gross MWe): 490
5. Design Electrical Rating (Net MWe): 470
6. Maximum Dependable Capacity (Gross MWe): 490
7. Maximum Dependable Capacity (Net MWe): 470
8. If Changes Occur in Capacity Ratings (Items Number 3 Through 7) Since Last Report, Give Reasons:

Notes: The unit operated at approx.
 97% reactor power level for
 the entire report period.

9. Power Level to Which Restricted, If Any (Net MWe): _____
10. Reasons For Restrictions, If Any: _____

| | This Month | Yr.-to-Date | Cumulative |
|---|------------|-------------|-------------|
| | | | ** |
| 11. Hours In Report Period | 744 | 5,111 | 199,217.45 |
| 12. Number of Hours Reactor Was Critical | 744 | 3,960.71 | 157,291.67 |
| 13. Reactor Reserve Shutdown Hours | 0 | 0 | 1,687.55 * |
| 14. Hours Generator On-Line | 744 | 3,864.75 | 154,570.13 |
| 15. Unit Reserve Shutdown Hours | 0 | 0 | 8.5 * |
| 16. Gross Thermal Energy Generated (MWH) | 1,097,720 | 5,413,242 | 218,627,755 |
| 17. Gross Electrical Energy Generated (MWH) | 371,098 | 1,832,402 | 72,162,009 |
| 18. Net Electrical Energy Generated (MWH) | 352,761 | 1,738,295 | 68,490,842 |
| 19. Unit Service Factor | 100% | 75.62% | 77.75% |
| 20. Unit Availability Factor | 100% | 75.62% | 77.75% |
| 21. Unit Capacity Factor (Using MDC Net) | 100.88% | 72.36% | 74.50% |
| 22. Unit Capacity Factor (Using DER Net) | 100.88% | 72.36% | 74.50% |
| 23. Unit Forced Outage Rate | 0% | 3.89% | 6.00% |

24. Shutdowns Scheduled Over Next 6 Months (Type, Date and Duration of Each):

25. If Shut Down At End Of Report Period, Estimated Date of Startup: 05-09-92

| | | |
|---|----------|----------|
| 26. Units In Test Status (Prior to Commercial Operation): | Forecast | Achieved |
| INITIAL CRITICALITY | _____ | _____ |
| INITIAL ELECTRICITY | _____ | _____ |
| COMMERCIAL OPERATION | _____ | _____ |

*CUMULATIVE TOTAL COMMENCING JANUARY 1, 1975

**CUMULATIVE TOTAL COMMENCING NOVEMBER 8, 1969

AVERAGE DAILY UNIT POWER LEVEL

DOCKET NO. 50-244
UNIT R.E. Ginna Nuclear Power Plant
DATE August 14, 1992
COMPLETED BY Robert E. Dodge

TELEPHONE 1 (315) 524-4446 ext. 396

MONTH July 1992

DAY AVERAGE DAILY POWER LEVEL
(MWe-Net)

| | |
|-----|------------|
| 1. | <u>474</u> |
| 2. | <u>447</u> |
| 3. | <u>476</u> |
| 4. | <u>480</u> |
| 5. | <u>479</u> |
| 6. | <u>476</u> |
| 7. | <u>473</u> |
| 8. | <u>474</u> |
| 9. | <u>474</u> |
| 10. | <u>473</u> |
| 11. | <u>475</u> |
| 12. | <u>474</u> |
| 13. | <u>473</u> |
| 14. | <u>473</u> |
| 15. | <u>474</u> |
| 16. | <u>474</u> |

DAY AVERAGE DAILY POWER LEVEL
(MWe-Net)

| | |
|-----|------------|
| 17. | <u>474</u> |
| 18. | <u>474</u> |
| 19. | <u>474</u> |
| 20. | <u>473</u> |
| 21. | <u>471</u> |
| 22. | <u>472</u> |
| 23. | <u>473</u> |
| 24. | <u>479</u> |
| 25. | <u>479</u> |
| 26. | <u>479</u> |
| 27. | <u>475</u> |
| 28. | <u>472</u> |
| 29. | <u>472</u> |
| 30. | <u>472</u> |
| 31. | <u>472</u> |

INSTRUCTIONS

On this format, list the average daily unit power level in MWe-Net for each day in the reporting month. Compute to the nearest whole megawatt.

UNIT SHUTDOWN AND POWER REDUCTIONS

REPORT MONTH JULY 1992

DOCKET NO. 50-244

UNIT NAME: R.E. GINNA NUCLEAR POWER PLANT

DATE: August 14, 1992

COMPLETED BY: Robert E. Dodge

Ginna Station

TELEPHONE: 524-4446 ext. 396

| No. | Date | Type 1 | Duration (Hours) | Reason 2 | Method of Shutting Down Reactor 3 | Licensee Event Report # | System Code 4 | Component Code 5 | Cause & Corrective Action to Prevent Recurrence |
|-------|---------|--------|------------------|----------|-----------------------------------|-------------------------|---------------|------------------|---|
| 92-06 | 7-02-92 | S | 10.20 | B | - | - | - | - | Planned maintenance on transmission lines. |

1

F: Forced
S: Scheduled

2

Reason:
A-Equipment Failure (Explain)
B-Maintenance or Test
C-Refueling
D-Regulatory Restriction
E-Operator Training & License Examination
F-Administrative
G-Operational Error (Explain)
H-Other (Explain)

3

Method:
1-Manual
2-Manual Scram.
3-Automatic Scram.
4-Other (Explain)

4

Exhibit G - Instructions for Preparation of Data Entry Sheets for Licensee Event Report (LER) File (NUREG-0161)

5

Exhibit 1 - Same Source

100-100000

100-100000

NARRATIVE SUMMARY OF OPERATING EXPERIENCE

DOCKET NO. 50-244
UNIT R.E. Ginna Nuclear Power Plant
DATE August 14, 1992
COMPLETED BY Robert E. Dodge
TELEPHONE 1 (315) 524-4446 ext. 396

MONTH July, 1992

The unit operated at approximately 97% Reactor Power Level for the month of July, with the exception on July 2.

A power reduction to 74% occurred due to a planned maintenance on transmission lines and returned to full power on July 3 and remained there at the end of the report period.