

# ACCELERATED DISTRIBUTION DEMONSTRATION SYSTEM

## REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR: 9209160131 DDC DATE: 92/08/31 NOTARIZED: NO DOCKET #  
FACIL: 50-244 Robert Emmet Ginna Nuclear Plant, Unit 1, Rochester G 05000244  
AUTH. NAME AUTHOR AFFILIATION  
DODGE, R. E. Rochester Gas & Electric Corp.  
MECREDY, R. C. Rochester Gas & Electric Corp.  
RECIP. NAME RECIPIENT AFFILIATION

SUBJECT: Monthly operating rept for Aug 1992 for GNPP.W/920914 ltr.

DISTRIBUTION CODE: IE24D COPIES RECEIVED: LTR 1 ENCL 1 SIZE: 5  
TITLE: Monthly Operating Report (per Tech Specs)

NOTES: License Exp date in accordance with 10CFR2.2.109(9/19/72). 05000244

RECIPIENT ID CODE/NAME	COPIES LTTR ENCL	RECIPIENT ID CODE/NAME	COPIES LTTR ENCL
PD1-3 LA	3 3	PD1-3 PD	1 1
JOHNSON, A	1 1		
INTERNAL: AEOD/DOA	1 1	AEOD/DSP/TPAB	1 1
NRR/DLPQ/LPEB10	1 1	NRR/DOEA/OEAB	1 1
<u>REG FILE</u> 01	1 1	RGN1	1 1
EXTERNAL: EG&G BRYCE, J. H	1 1	NRC PDR	1 1
NSIC	1 1		

Cont NO P 034044 136

NOTE TO ALL "RIDS" RECIPIENTS:

PLEASE HELP US TO REDUCE WASTE! CONTACT THE DOCUMENT CONTROL DESK.  
ROOM P1-37 (EXT. 504-2065) TO ELIMINATE YOUR NAME FROM DISTRIBUTION  
LISTS FOR DOCUMENTS YOU DON'T NEED!

TOTAL NUMBER OF COPIES REQUIRED: LTTR 14 ENCL 14

MOR  
Jed



ROCHESTER GAS AND ELECTRIC CORPORATION • 89 EAST AVENUE, ROCHESTER N.Y. 14649-0001



ROBERT C. MECREDY  
Vice President  
Ginna Nuclear Production

TELEPHONE  
AREA CODE 716 546-2700

GINNA STATION

September 14, 1992

US Nuclear Regulatory Commission  
Document Control Desk  
Washington, DC 20555

Subject: Monthly Report for August, 1992  
Operating Status Information  
R. E. Ginna Nuclear Power Plant  
Docket No. 50-244

Dear Sir:

Pursuant to our Technical Specification 6.9.1, attached herewith is the monthly operating status report for Ginna Station for the month of August, 1992.

Very truly yours,

*Robert C. Mecredy*  
Robert C. Mecredy

RCM/

Attachments

cc: Mr. Thomas T. Martin NRC (1)

9209160131 920831  
PDR ADDCK 05000244  
R PDR



*Cent No 1034044136*  
*IE24*  
*11*



Handwritten text, possibly a signature or date, located in the bottom left corner.

Handwritten text, possibly a signature or date, located in the bottom right corner.

# OPERATING DATA REPORT

-1-

DOCKET NO. 50-244  
 DATE September 14, 1992  
 COMPLETED BY Robert E. Dodge  
 TELEPHONE (315) 524-4446 ext. 396

## OPERATING STATUS

1. Unit Name: R.E. GINNA NUCLEAR POWER PLANT
2. Reporting Period: August, 1992
3. Licensed Thermal Power (MWt): 1520
4. Nameplate Rating (Gross MWe): 490
5. Design Electrical Rating (Net MWe): 470
6. Maximum Dependable Capacity (Gross MWe): 490
7. Maximum Dependable Capacity (Net MWe): 470
8. If Changes Occur in Capacity Ratings (Items Number 3 Through 7) Since Last Report, Give Reasons:

Notes: The unit operated at approx.  
 97% reactor power level for  
 the entire report period.

9. Power Level to Which Restricted, If Any (Net MWe): \_\_\_\_\_
10. Reasons For Restrictions, If Any: \_\_\_\_\_

	This Month	Yr.-to-Date	Cumulative **
11. Hours In Report Period	744	5,855	199,961.45
12. Number of Hours Reactor Was Critical	744	4,704.71	158,035.67
13. Reactor Reserve Shutdown Hours	0	0	1,687.55 *
14. Hours Generator On-Line	744	4,608.75	155,314.13
15. Unit Reserve Shutdown Hours	0	0	8.5 *
16. Gross Thermal Energy Generated (MWH)	1,101,108	6,514,350	219,728,863
17. Gross Electrical Energy Generated (MWH)	370,207	2,202,609	72,532,216
18. Net Electrical Energy Generated (MWH)	351,756	2,090,051	68,842,598
19. Unit Service Factor	100%	78.71%	77.83%
20. Unit Availability Factor	100%	78.71%	77.83%
21. Unit Capacity Factor (Using MDC Net)	100.59%	75.95%	74.60%
22. Unit Capacity Factor (Using DER Net)	100.59%	75.95%	74.60%
23. Unit Forced Outage Rate	0%	3.28%	5.97%

24. Shutdowns Scheduled Over Next 6 Months (Type, Date and Duration of Each):

25. If Shut Down At End Of Report Period, Estimated Date of Startup:

26. Units In Test Status (Prior to Commercial Operation):	Forecast	Achieved
INITIAL CRITICALITY	_____	_____
INITIAL ELECTRICITY	_____	_____
COMMERCIAL OPERATION	_____	_____

\*CUMULATIVE TOTAL COMMENCING JANUARY 1, 1975

\*\*CUMULATIVE TOTAL COMMENCING NOVEMBER 8, 1969

## AVERAGE DAILY UNIT POWER LEVEL

DOCKET NO. 50-244  
UNIT R.E. Ginna Nuclear Power Plant  
DATE September 14, 1992  
COMPLETED BY Robert E. Dodge

TELEPHONE 1 (315) 524-4446 ext. 396

MONTH August, 1992

DAY AVERAGE DAILY POWER LEVEL  
(MWe-Net)

1.	<u>473</u>
2.	<u>472</u>
3.	<u>471</u>
4.	<u>471</u>
5.	<u>472</u>
6.	<u>471</u>
7.	<u>472</u>
8.	<u>473</u>
9.	<u>473</u>
10.	<u>474</u>
11.	<u>472</u>
12.	<u>470</u>
13.	<u>471</u>
14.	<u>473</u>
15.	<u>473</u>
16.	<u>478</u>

DAY AVERAGE DAILY POWER LEVEL  
(MWe-Net)

17.	<u>479</u>
18.	<u>478</u>
19.	<u>474</u>
20.	<u>472</u>
21.	<u>472</u>
22.	<u>472</u>
23.	<u>469</u>
24.	<u>471</u>
25.	<u>470</u>
26.	<u>470</u>
27.	<u>469</u>
28.	<u>472</u>
29.	<u>471</u>
30.	<u>471</u>
31.	<u>472</u>

## INSTRUCTIONS

On this format, list the average daily unit power level in MWe-Net for each day in the reporting month. Compute to the nearest whole megawatt.

# UNIT SHUTDOWN AND POWER REDUCTIONS

REPORT MONTH AUGUST 1992

DOCKET NO. 50-244

UNIT NAME: R.E. GINNA NUCLEAR POWER PLANT

DATE: September 14, 1992

COMPLETED BY: Robert E. Dodge

TELEPHONE: 315-524-4446 ext. 396  
Ginna Station

No.	Date	Type 1	Duration (Hours)	Reason 2	Method of Shutting Down Reactor 3	Licensee Event Report #	System Code 4	Component Code 5	Cause & Corrective Action to Prevent Recurrence
									No unit shutdown or power reductions this report period.

1  
F: Forced  
S: Scheduled

2  
Reason:  
A-Equipment Failure (Explain)  
B-Maintenance or Test  
C-Refueling  
D-Regulatory Restriction  
E-Operator Training & License Examination  
F-Administrative  
G-Operational Error (Explain)  
H-Other (Explain)

3  
Method:  
1-Manual  
2-Manual Scram.  
3-Automatic Scram.  
4-Other (Explain)

4  
Exhibit G - Instructions  
for Preparation of Data  
Entry Sheets for Licensee  
Event Report (LER) File (NUREG-  
0161)

5  
Exhibit 1 - Same Source

NARRATIVE SUMMARY OF OPERATING EXPERIENCE

DOCKET NO. 50-244  
UNIT R.E. Ginna Nuclear Power Plant  
DATE September 14, 1992  
COMPLETED BY *Robert E. Dodge*  
Robert E. Dodge  
TELEPHONE 1 (315) 524-4446 ext. 396

MONTH August, 1992

The unit operated at approximately 97% Reactor Power Level for the entire report period.