

ACCELERATED DISTRIBUTION DEMONSTRATION SYSTEM

REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR: 9210050344 DOC. DATE: 92/09/15 NOTARIZED: YES DOCKET #
FACIL: 50-244 Robert Emmet Ginna Nuclear Plant, Unit 1, Rochester G 05000244
AUTH. NAME AUTHOR AFFILIATION
MECREDY, R.C. Rochester Gas & Electric Corp.
RECIP. NAME RECIPIENT AFFILIATION
JOHNSON, A.R. Project Directorate I-3

SUBJECT: Forwards application for amend to license DPR-18, revising
app A including TS 3.1.1.4, 3.1.1.6 & 4.3.4 & adding site
specific sections in response to GL 90-06.

DISTRIBUTION CODE: A019D COPIES RECEIVED: LTR 1 ENCL 1 SIZE: 2 + 28
TITLE: Generic Ltr 90-06 Resolution of GE 70N94 PORVs & Block Valve Reliabil

NOTES: License Exp date in accordance with 10CFR2, 2.109(9/19/72). 05000244

| RECIPIENT ID CODE/NAME | COPIES LTTR ENCL | RECIPIENT ID CODE/NAME | COPIES LTTR ENCL |
|-----------------------------|---------------------|---------------------------|---------------------|
| PD1-3 LA | 1 1 | PD1-3 PD | 1 1 |
| JOHNSON, A | 1 1 | | |
| INTERNAL: KIRKWOOD, R. NLS3 | 1 1 | NRR/EMEB | 1 1 |
| NRR/SRXB | 1 1 | PICKETT, D 13H15 | 1 1 |
| REG FILE 01 | 1 1 | RES/DSIR/EIB | 1 1 |
| RES/DSIR/RPSIB | 1 1 | | |
| EXTERNAL: NRC. PDR | 1 1 | NUDOCS-ABSTRACT | 1 1 |

Cent. # 0034044137


NOTE TO ALL "RIDS" RECIPIENTS:

PLEASE HELP US TO REDUCE WASTE! CONTACT THE DOCUMENT CONTROL DESK.
ROOM P1-37 (EXT. 504-2065) TO ELIMINATE YOUR NAME FROM DISTRIBUTION
LISTS FOR DOCUMENTS YOU DON'T NEED!

TOTAL NUMBER OF COPIES REQUIRED: LTTR 12 ENCL 12



ROCHESTER GAS AND ELECTRIC CORPORATION • 89 EAST AVENUE, ROCHESTER N.Y. 14649-0001



ROBERT C. MECREDY
Vice President
Ginna Nuclear Production

TELEPHONE
AREA CODE 716 546-2700

September 15, 1992

U.S. Nuclear Regulatory Commission
Document Control Desk
Attn: Mr. Allen R. Johnson
PWR Project Directorate I-3
Washington, D.C. 20555

Subject: Rochester Gas and Electric Corporation
R.E. Ginna Nuclear Power Plant
Docket No. 50-244

Ref.(a): Generic Letter 90-06, Resolution of Generic Issue 70,
'Power-Operated Relief Valve and Block Valve Reliability'
and Generic Issue 94 'Additional Low-Temperature
Overpressure Protection for Light-Water Reactors'

Dear Mr. Johnson:

Enclosed is an Application for Amendment to Operating License No. DPR-18 to amend Appendix A of that license to satisfy Rochester Gas and Electric Corporation's (RG&E's) commitment to revise the Technical Specifications consistent with our April 18, 1991 response to reference (a) pursuant to 10CFR50.54(f). On April 30, 1991, we forwarded a letter to your attention confirming our commitment to upgrade PORVs/control circuits to meet environmentally qualified (EQ) conditions during the 1992 Refueling Outage. Per discussions on January 16, 1992, we informed you that additional time was required, until the 1993 Refueling Outage, to modify the EQ portion of the PORVs.

Consistent with our response to Generic Letter 90-06, the proposed Amendment revises Technical Specification Sections 3.1.1.4, 3.1.1.6, 4.3.4 and adds site specific basis sections to address the generic letter. Technical Specification Section 3.1.1.4 will be deleted; however, the provisions of the specification will be relocated under proposed Specification 3.1.1.6. This revision continues to ensure that existing and proposed limiting conditions of operation are met. The proposed revision also eliminates the need to duplicate identical requirements under two individual specifications. Similarly, Surveillance Requirement 4.3.5.6 will be renumbered and relocated under the provisions of Specification Section 4.3.4, Relief Valves. This administrative change also ensures consistency with proposed Specification 3.1.1.6. Further, as a result of the insertion of the lengthy basis sections described in the generic letter, several sections within Ginna Technical Specifications were rearranged to accommodate the additional information. Rearrangement of the basis sections are

cert # p 034 044 137

9210050344 920915
PDR ADDOCK 05000244
P PDR

A019 11


100-20087

considered to be administrative in nature and promote clarity.

Specification section 3.1.1.3 will be revised to address limiting conditions for operation above cold shutdown. This proposed change is conservative and considered to be an administrative change.

This proposed Amendment should be considered effective 30 days after receipt of the Commission's approval.

Very truly yours,



Robert C. Mecredy

GAL\161

Enclosures

xc: Mr. Allen R. Johnson (Mail Stop 14D1)
Project Directorate I-3
Washington, D.C. 20555

Ms. Donna Ross
New York State Energy Office

U.S. Nuclear Regulatory Commission
Region I
475 Allendale Road
King of Prussia, PA 19406

Ginna Senior Resident Inspector