

UNITED STATES OF AMERICA
NUCLEAR REGULATORY COMMISSION

In the Matter of)

Rochester Gas and Electric Corporation)
(R.E. Ginna Nuclear Power Plant))

) Docket No. 50-244
)
)

APPLICATION FOR AMENDMENT
TO OPERATING LICENSE

Pursuant to Section 50.90 of the regulations of the U.S. Nuclear Regulatory Commission (the "Commission"), Rochester Gas and Electric Corporation ("RG&E"), holder of Facility Operating License No. DPR-18, hereby requests that the Technical Specifications set forth in Appendix A to that license be amended. This request for change in Technical Specifications is submitted to satisfy Rochester Gas and Electric Corporation's commitment to revise the Technical Specifications consistent with our April 18, 1991, response to Generic Letter 90-06, "Resolution of Generic Issue 70, 'Power-Operated Relief Valve and Block Valve Reliability,' and Generic Issue 94, 'Additional Low-Temperature Overpressure Protection for Light-Water Reactors,' pursuant to 10CFR50.54(f)." The proposed Amendment revises Technical Specifications Sections 3.1.1.4, 3.1.1.6, 4.3.4 and adds site specific basis sections to address the generic letter.

Technical Specification 3.1.1.4 was deleted and relocated under the provisions of proposed Specification 3.1.1.6. This revision continues to ensure that the existing and proposed limiting conditions of operation are met. The proposed revision also eliminates the need to duplicate identical requirements under two individual specifications. Similarly, Surveillance Requirement 4.3.5.6 will be renumbered and relocated under the provisions of Specification Section 4.3.4, Relief Valves. This administrative change also

7210050354 720715
PDR ADDCK 05000244
PDR


4544
PDR

ensures consistency with proposed Specification 3.1.1.6. Specification section 3.1.1.3 will be revised to address limiting conditions for operation above cold shutdown. This proposed change is conservative and considered to be an administrative change.

The proposed Technical Specification change is set forth in Attachment A to this Application. A safety evaluation is set forth in Attachment B. This evaluation also demonstrates that the proposed change does not involve a significant change in the types or a significant increase in the amounts of effluents or any change in the authorized power level of the facility. As demonstrated in Attachment B, the proposed change does not involve a significant hazards consideration.

WHEREFORE, Applicant respectfully requests that Appendix A to Facility Operating License No. DPR-18 be amended in the form attached hereto as Attachment A.

Rochester Gas and Electric Corporation


Robert C. Mccredy
Vice President, Ginna Nuclear Production

Subscribed and sworn to before me
on this 15th day of September,
1992.



MARIE C. VILLENEUVE
Notary Public, State of New York
Monroe County
Commission Expires October 31, 1992

11 3 3

11 3 3
b
11 3 3