

# ACCELERATED DISTRIBUTION DEMONSTRATION SYSTEM

## REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR:9211240118 DOC.DATE: 92/10/31 NOTARIZED: NO DOCKET #  
 FACIL:50-244 Robert Emmet Ginna Nuclear Plant, Unit 1, Rochester G 05000244  
 AUTH.NAME AUTHOR AFFILIATION  
 DODGE,R.E. Rochester Gas & Electric Corp.  
 MECREDY,R.C. Rochester Gas & Electric Corp.  
 RECIP.NAME RECIPIENT AFFILIATION

SUBJECT: Monthly operating rept for Oct 1992 for RE Ginna Nuclear  
 Power Plant.W/921115 ltr.

DISTRIBUTION CODE: IE24D COPIES RECEIVED:LTR 1 ENCL 1 SIZE: 5  
 TITLE: Monthly Operating Report (per Tech Specs)

NOTES:License Exp date in accordance with 10CFR2,2.109(9/19/72). 05000244

RECIPIENT ID CODE/NAME	COPIES		RECIPIENT ID CODE/NAME	COPIES	
	LTR	ENCL		LTR	ENCL
PD1-3 LA	3	3	PD1-3 PD	1	1
JOHNSON,A	1	1			
INTERNAL: AEOD/DOA	1	1	AEOD/DSP/TPAB	1	1
NRR/DLEQ/LPEB10	1	1	NRR/DOEA/OEAB	1	1
<u>REG FILE</u> 01	1	1	RGN1	1	1
EXTERNAL: EG&G BRYCE,J.H	1	1	NRC PDR	1	1
NSIC	1	1			

*Cont #*  
*0034044170*

NOTE TO ALL "RIDS" RECIPIENTS:

PLEASE HELP US TO REDUCE WASTE! CONTACT THE DOCUMENT CONTROL DESK.  
 ROOM P1-37 (EXT. 504-2065) TO ELIMINATE YOUR NAME FROM DISTRIBUTION  
 LISTS FOR DOCUMENTS YOU DON'T NEED!


TOTAL NUMBER OF COPIES REQUIRED: LTR 14 ENCL 14

*MOR*  
*CH*





ROCHESTER GAS AND ELECTRIC CORPORATION • 89 EAST AVENUE, ROCHESTER N.Y. 14649-0001



ROBERT C. MECREDY  
Vice President  
Ginna Nuclear Production

TELEPHONE  
AREA CODE 716 546-2700

GINNA STATION

November 15, 1992

US Nuclear Regulatory Commission  
Document Control Desk  
Washington, DC 20555

Subject: Monthly Report for October, 1992  
Operating Status Information  
R. E. Ginna Nuclear Power Plant  
Docket No. 50-244

Dear Sir:

Pursuant to our Technical Specification 6.9.1, attached herewith is the monthly operating status report for Ginna Station for the month of October, 1992.

Very truly yours,

*Robert C. Mecredy*  
Robert C. Mecredy

RCM/

Attachments

cc: Mr. Thomas T. Martin NRC (1)

*cert #  
p 024 044170*

9211240118 921031  
PDR ADDCK 05000244  
R PDR

*IE24*

## OPERATING DATA REPORT

DOCKET NO. 50-244

DATE November 15, 1992

COMPLETED BY Robert E. Dodge  
Robert E. Dodge

TELEPHONE (315) 524-4446 ext. 396

OPERATING STATUS

1. Unit Name: R.E. GINNA NUCLEAR POWER PLANT
2. Reporting Period: October, 1992
3. Licensed Thermal Power (MWt): 1520
4. Nameplate Rating (Gross MWe): 490
5. Design Electrical Rating (Net MWe): 470
6. Maximum Dependable Capacity (Gross MWe): 490
7. Maximum Dependable Capacity (Net MWe): 470
8. If Changes Occur in Capacity Ratings (Items Number 3 Through 7) Since Last Report, Give Reasons:

Notes: The unit operated at approx.  
97% reactor power level for  
the entire report period.

9. Power Level to Which Restricted, If Any (Net MWe):

10. Reasons For Restrictions, If Any:

	This Month	Yr.-to-Date	Cumulative
			**
11. Hours In Report Period	745***	7,320	201,426.45
12. Number of Hours Reactor Was Critical	745	6,169.71	159,500.67
13. Reactor Reserve Shutdown Hours	0	0	1,687.55 *
14. Hours Generator On-Line	745	6,073.75	156,779.13
15. Unit Reserve Shutdown Hours	0	0	8.5 *
16. Gross Thermal Energy Generated (MWH)	1,103,684	8,677,792	221,892,305
17. Gross Electrical Energy Generated (MWH)	375,437	2,935,534	73,265,141
18. Net Electrical Energy Generated (MWH)	357,045	2,786,749	69,539,296
19. Unit Service Factor	100%	82.97%	77.99%
20. Unit Availability Factor	100%	82.97%	77.99%
21. Unit Capacity Factor (Using MDC Net)	101.97%	81.00%	74.80%
22. Unit Capacity Factor (Using DER Net)	101.97%	81.00%	74.80%
23. Unit Forced Outage Rate	0%	2.51%	5.92%

24. Shutdowns Scheduled Over Next 6 Months (Type, Date and Duration of Each):

Refueling and Maintenance - March 19, 1993 45 days

25. If Shut Down At End Of Report Period, Estimated Date of Startup:

26. Units In Test Status (Prior to Commercial Operation):

Forecast

Achieved

INITIAL CRITICALITY

INITIAL ELECTRICITY

COMMERCIAL OPERATION

\*CUMULATIVE TOTAL COMMENCING JANUARY 1, 1975

\*\*CUMULATIVE TOTAL COMMENCING NOVEMBER 8, 1969

\*\*\*CHANGE FROM EASTERN DAYLIGHT SAVINGS TIME TO EASTERN STANDARD TIME

2000-2001

2000-2001

## AVERAGE DAILY UNIT POWER LEVEL

DOCKET NO. 50-244  
 UNIT R.E. Ginna Nuclear Power Plant  
 DATE November 15, 1992  
 COMPLETED BY Robert E. Dodge  
 Robert E. Dodge

TELEPHONE 1 (315) 524-4446 ext. 396

MONTH October, 1992

DAY AVERAGE DAILY POWER LEVEL  
(MWe-Net)

1.	<u>478</u>
2.	<u>478</u>
3.	<u>478</u>
4.	<u>478</u>
5.	<u>478</u>
6.	<u>478</u>
7.	<u>478</u>
8.	<u>478</u>
9.	<u>479</u>
10.	<u>479</u>
11.	<u>479</u>
12.	<u>478</u>
13.	<u>478</u>
14.	<u>478</u>
15.	<u>478</u>
16.	<u>478</u>

DAY AVERAGE DAILY POWER LEVEL  
(MWe-Net)

17.	<u>479</u>
18.	<u>479</u>
19.	<u>479</u>
20.	<u>479</u>
21.	<u>479</u>
22.	<u>478</u>
23.	<u>479</u>
24.	<u>479</u>
25.	<u>479</u>
26.	<u>479</u>
27.	<u>479</u>
28.	<u>480</u>
29.	<u>480</u>
30.	<u>479</u>
31.	<u>479</u>

## INSTRUCTIONS

On this format, list the average daily unit power level in MWe-Net for each day in the reporting month. Compute to the nearest whole megawatt.

# UNIT SHUTDOWN AND POWER REDUCTIONS

REPORT MONTH OCTOBER 1992

DOCKET NO. 50-244  
 UNIT NAME R.E. GINNA NUCLEAR POWER PLANT  
 DATE November 15, 1992  
 COMPLETED BY Robert E. Dodge  
 TELEPHONE 315-524-4446 ext. 396  
Ginna Station

No.	Date	Type 1	Duration (Hours)	Reason 2	Method of Shutting Down Reactor 3	Licensee Event Report #	System Code 4	Component Code 5	Cause & Corrective Action to Prevent Recurrence
									No power reduction for the month of October.

1

F: Forced  
S: Scheduled

2

Reason:  
 A-Equipment Failure (Explain)  
 B-Maintenance or Test  
 C-Refueling  
 D-Regulatory Restriction  
 E-Operator Training & License Examination  
 F-Administrative  
 G-Operational Error (Explain)  
 H-Other (Explain)

3

Method:  
 1-Manual  
 2-Manual Scram.  
 3-Automatic Scram.  
 4-Other (Explain)

4

Exhibit G - Instructions for Preparation of Data Entry Sheets for Licensee Event Report (LER) File (NUREG-0161)

5

Exhibit 1 - Same Source

# NARRATIVE SUMMARY OF OPERATING EXPERIENCE

DOCKET NO. 50-244  
UNIT R.E. Ginna Nuclear Power Plant  
DATE November 15, 1992  
COMPLETED BY Robert E. Dodge  
TELEPHONE 1 (315) 524-4446 ext. 396

MONTH October, 1992

The unit operated at approximately 97% Reactor Power Level for the month of October and remained there at the end of the report period.