ACCELERATED DOCUMENT DISTRIBUTION SYSTEM

REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR:9303180290 DOC.DATE: 93/02/28 NOTARIZED: NO DOCKET #
FACIL:50-244 Robert Emmet Ginna Nuclear Plant, Unit 1, Rochester G 05000244
AUTH.NAME AUTHOR AFFILIATION
DODGE,R. Rochester Gas & Electric Corp.
MECREDY,R.C. Rochester Gas & Electric Corp.
RECIP.NAME RECIPIENT AFFILIATION

SUBJECT: Monthly operating rept for Feb 1993 for RE Ginna Nuclear Power Plant.W/930311 ltr.

DISTRIBUTION CODE: IE24D COPIES RECEIVED:LTR 1 ENCL 1 SIZE: 5
TITLE: Monthly Operating Report (per Tech Specs)

NOTES:License Exp date in accordance with 10CFR2,2.109(9/19/72). 05000244

	RECIPIENT ID CODE/NAME	COPIES LTTR	COPIES ENCL	RECIPIENT ID CODE/NAME	COPIES LTTR	COPIES ENCL
	PD1-3 LA	3	3	PD1-3 PD	1	1
	JOHNSON,A	1	1			
INTERNAL:	AEOD/DOA	1	1	AEOD/DSP/TPAB	1	1
	NRR/DORS/OEAB	1	1	NRR/DRIL/RPEB	1	1
	REG FILE 01	1	1	RGN1	1	1
EXTERNAL:	EG&G BRYCE,J.H	1	1	NRC PDR	1	1
	NSIC	1	1			

Cat NO P2378467 92

NOTE TO ALL "RIDS" RECIPIENTS:

PLEASE HELP US TO REDUCE WASTE! CONTACT THE DOCUMENT CONTROL DESK, ROOM P1-37 (EXT. 504-2065) TO ELIMINATE YOUR NAME FROM DISTRIBUTION LISTS FOR DOCUMENTS YOU DON'T NEED!

TOTAL NUMBER OF COPIES REQUIRED: LTTR 14 ENCL 14

RIDS/ADDS

ROCHESTER GAS AND ELECTRIC CORPORATION ○ 89 EAST AVENUE, ROCHESTER N.Y. 14649-0001

ROBERT C. MECREDY
Vice President
Ginna Nuclear Production

TELEPHONE
AREA CODE 716 546-2700

GINNA STATION

March 11, 1993

US Nuclear Regulatory Commission
Document Control Desk
Washington, DC 20555

Subject: Monthly Report for February, 1993
Operating Status Information
R. E. Ginna Nuclear Power Plant
Docket No. 50-244

Dear Sir:

Pursuant to our Technical Specification 6.9.1, attached herewith is the monthly operating status report for Ginna Station for the month of February, 1993.

Very truly yours,

Robert C. Mecredy

RCM/

Attachments

cc: Mr. Thomas T. Martin NRC (1)

Cert No P237846792

180002

9303180290 930228
PDR ADOCK 05000244
R PDR

IE24
1/1

OPERATING DATA REPORT

DOCKET NO. 50-244
DATE March 11, 1993
COMPLETED BY Bruce Lockhart for Robert Dodge
Robert E. Dodge

TELEPHONE (315) 524-4446 ext. 396

OPERATING STATUS

1. Unit Name: R.E. GINNA NUCLEAR POWER PLANT
2. Reporting Period: February, 1993
3. Licensed Thermal Power (MWt): 1520
4. Nameplate Rating (Gross MWe): 490
5. Design Electrical Rating (Net MWe): 470
6. Maximum Dependable Capacity (Gross MWe): 490
7. Maximum Dependable Capacity (Net MWe): 470
8. If Changes Occur in Capacity Ratings (Items Number 3 Through 7) Since Last Report, Give Reasons:

Notes: The reactor power level averaged 98% for the entire report period.

9. Power Level to Which Restricted, If Any (Net MWe):
10. Reasons For Restrictions, If Any:

		This Month	Yr.-to-Date	Cumulative **	
11.	Hours In Report Period	672	1,416	204,306.45	
12.	Number of Hours Reactor Was Critical	672	1,416	162,380.67	
13.	Reactor Reserve Shutdown Hours	0	0	1,687.55	*
14.	Hours Generator On-Line	672	1,416	159,659.13	
15.	Unit Reserve Shutdown Hours	0	0	8.5	*
16.	Gross Thermal Energy Generated (MWH)	1,004,079	2,104,166	226,147,919	
17.	Gross Electrical Energy Generated (MWH)	342,024	716,403	74,714,207	
18.	Net Electrical Energy Generated (MWH)	325,412	681,353	70,917,284	
19.	Unit Service Factor	100%	100%	78.30%	
20.	Unit Availability Factor	100%	100%	78.31%	
21.	Unit Capacity Factor (Using MDC Net)	103.03%	102.38%	75.18%	
22.	Unit Capacity Factor (Using DER Net)	103.03%	102.38%	75.18%	
23.	Unit Forced Outage Rate	0	0	5.82%	

24. Shutdowns Scheduled Over Next 6 Months (Type, Date and Duration of Each):
Refueling and Maintenance - March 12, 1993 45 days

25. If Shut Down At End Of Report Period, Estimated Date of Startup:

26. Units In Test Status (Prior to Commercial Operation):

	Forecast	Achieved
INITIAL CRITICALITY		
INITIAL ELECTRICITY		
COMMERCIAL OPERATION		

*CUMULATIVE TOTAL COMMENCING JANUARY 1, 1975
**CUMULATIVE TOTAL COMMENCING NOVEMBER 8, 1969

AVERAGE DAILY UNIT POWER LEVEL

DOCKET NO. 50-244
UNIT R.E. Ginna Nuclear Power Plant
DATE March 11, 1993
COMPLETED BY Joyce Lochner for Robert Dodge
Robert E. Dodge

TELEPHONE 1 (315) 524-4446 ext. 396

MONTH January, 1993

DAY	AVERAGE DAILY POWER LEVEL (MWe-Net)	DAY	AVERAGE DAILY POWER LEVEL (MWe-Net)
1.	484	17.	483
2.	484	18.	484
3.	485	19.	484
4.	485	20.	485
5.	485	21.	485
6.	484	22.	485
7.	485	23.	483
8.	485	24.	484
9.	485	25.	484
10.	485	26.	484
11.	485	27.	484
12.	485	28.	484
13.	484	29.	-
14.	484	30.	-
15.	484	31.	-
16.	484		

INSTRUCTIONS

On this format, list the average daily unit power level in MWe-Net for each day in the reporting month. Compute to the nearest whole megawatt.

DOCKET NO. 50-244
UNIT NAME R.E. GINNA NUCLEAR POWER PLANT
DATE March 11, 1993
COMPLETED BY Joyce Lochner for Robert Dodge
Robert E. Dodge
TELEPHONE (315) 524-4446 ext. 396

UNIT SHUTDOWN AND POWER REDUCTIONS

REPORT MONTH FEBRUARY 1993

No.	Date	Type [1]	Duration (Hours)	Reason [2]	Method of Shutting Down Reactor [3]	Licensee Event Report #	System Code [4]	Component Code [5]	Cause & Corrective Action to Prevent Recurrence
									No power reduction for the month of February.

1
F: Forced
S: Scheduled

2
Reason:
A-Equipment Failure (Explain)
B-Maintenance or Test
C-Refueling
D-Regulatory Restriction
E-Operator Training & License Examination
F-Administrative
G-Operational Error (Explain)
H-Other (Explain)

3
Method:
1-Manual
2-Manual Scram.
3-Automatic Scram.
4-Other (Explain)

4
Exhibit G - Instructions for Preparation of Data Entry Sheets for Licensee Event Report (LER) File (NUREG-0161)

5
Exhibit 1 - Same Source

REV. 4/85 49-89

NARRATIVE SUMMARY OF OPERATING EXPERIENCE

DOCKET NO. 50-244
UNIT R.E. Ginna Nuclear Power Plant
DATE March 11, 1993
COMPLETED BY Joyce Lockner for Robert Dodge
Robert E. Dodge

TELEPHONE 1 (315) 524-4446 ext. 396

MONTH February, 1993

The unit operated at approximately 98% reactor power level for the month of February.