

ACCELERATED DOCUMENT DISTRIBUTION SYSTEM

REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR: 9304090207 DOC. DATE: 93/04/05 NOTARIZED: YES DOCKET #
 FACIL: 50-244 Robert Emmet Ginna Nuclear Plant, Unit 1, Rochester G 05000244
 AUTH. NAME AUTHOR AFFILIATION
 MECREDY, R.C. Rochester Gas & Electric Corp.
 RECIP. NAME RECIPIENT AFFILIATION
 JOHNSON, A.R. Project Directorate I-3

SUBJECT: Forwards application for amend to License DPR-18, revising TS
 to remove containment isolation valve Table 3.6-1 & maintain
 required listing in updated FSAR.

DISTRIBUTION CODE: A001D COPIES RECEIVED: LTR 1 ENCL 1 SIZE: 2+13
 TITLE: OR Submittal: General Distribution

NOTES: License Exp date in accordance with 10CFR2,2.109(9/19/72). 05000244 /

	RECIPIENT		COPIES			RECIPIENT		COPIES		
	ID CODE/NAME		LTTR	ENCL		ID CODE/NAME		LTTR	ENCL	
	PD1-3 LA		1	1		PD1-3 PD		1	1	
	JOHNSON, A		2	2						
INTERNAL:	NRR/DE/EELB		1	1		NRR/DORS/OTSB		1	1	
	NRR/DRCH/HICB		1	1		NRR/DSSA/SCSB		1	1	
	NRR/DSSA/SPLB		1	1		NRR/DSSA/SRXB		1	1	
	NUDOCS-ABSTRACT		1	1		OC/LEMB		1	0	
	OGC/HDS1		1	0		REG FILE	01	1	1	
EXTERNAL:	NRC PDR		1	1		NSIC		1	1	

Cont # P237846797

NOTE TO ALL "RIDS" RECIPIENTS:

PLEASE HELP US TO REDUCE WASTE! CONTACT THE DOCUMENT CONTROL DESK,
 ROOM P1-37 (EXT. 504-2065) TO ELIMINATE YOUR NAME FROM DISTRIBUTION
 LISTS FOR DOCUMENTS YOU DON'T NEED!

TOTAL NUMBER OF COPIES REQUIRED: LTTR 16 ENCL 14



ROCHESTER GAS AND ELECTRIC CORPORATION • 89 EAST AVENUE, ROCHESTER N.Y. 14649-0001



ROBERT C. MECREDY
Vice President
Ginna Nuclear Production

TELEPHONE
AREA CODE 716 546-2700

April 5, 1993

U.S. Nuclear Regulatory Commission
Document Control Desk
Attn: Allen R. Johnson
Project Directorate I-3
Washington, D.C. 20555

Subject: Application for Amendment to Facility Operating License
Rochester Gas and Electric Corporation
R.E. Ginna Nuclear Power Plant
Docket No. 50-244

Reference: (a) Letter from R.C. Mecredy, RG&E, to A.R. Johnson,
NRC, Subject: *Removal of the Table of Containment
Isolation Valves from Technical Specifications*,
dated November 30, 1992.

Dear Mr. Johnson:

Rochester Gas and Electric (RG&E) has proposed (Reference a) to revise the Ginna Station Technical Specifications to remove Containment Isolation Valve Table 3.6-1 and maintain the required listing in the UFSAR. However, this request, affecting many containment isolation and testing issues, has not yet been approved. Therefore, RG&E requests that a limited number of specific changes be made to Technical Specification Table 3.6-1 to support the Integrated Leak Rate Test (ILRT) which is to be conducted during the 1993 Refueling Outage. NRC approval of these changes is required prior to filling and venting the reactor coolant system which is currently scheduled for April 14, 1993. The proposed Amendment should be considered effective within 30 days after RG&E receipt of NRC approval.

Very truly yours,

Robert C. Mecredy

MDF\518

090034

9304090207	930405
PDR	ADOCK 05000244
P	PDR

Clrf# P237 846 797

4001 11



1950
JAN 10 1950
RECEIVED
U.S. DEPARTMENT OF AGRICULTURE
WASHINGTON, D.C.

xc: Mr. Allen R. Johnson (Mail Stop 14D1)
Project Directorate I-3
Washington, D.C. 20555

Ms. Donna Ross
New York State Energy Office

U.S. Nuclear Regulatory Commission
Region I
475 Allendale Road
King of Prussia, PA 19406

Ginna Senior Resident Inspector