

ACCELERATED DOCUMENT DISTRIBUTION SYSTEM

REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR:9304210162 DOC.DATE: 93/03/31 NOTARIZED: NO DOCKET #
 FACIL:50-244 Robert Emmet Ginna Nuclear Plant, Unit 1, Rochester G 05000244
 AUTH.NAME AUTHOR AFFILIATION
 DODGE,R.E. Rochester Gas & Electric Corp.
 MECREDY,R.C. Rochester Gas & Electric Corp.
 RECIP.NAME RECIPIENT AFFILIATION

SUBJECT: Monthly operating rept for Mar 1993 for RE Ginna Nuclear
 Power Plant.W/930412 ltr.

DISTRIBUTION CODE: IE24D COPIES RECEIVED:LTR 1 ENCL 1 SIZE: 5
 TITLE: Monthly Operating Report (per Tech Specs)

NOTES:License Exp date in accordance with 10CFR2,2.109(9/19/72). 05000244

RECIPIENT ID CODE/NAME	COPIES LTTR ENCL	RECIPIENT ID CODE/NAME	COPIES LTTR ENCL
PD1-3 LA	3 3	PD1-3 PD	1 1
JOHNSON,A	1 1		
INTERNAL: AEOD/DOA	1 1	AEOD/DSP/TPAB	1 1
NRR/DORS/OEAB	1 1	NRR/DRIL/RPEB	1 1
<u>REG FILE</u> 01	1 1	RGN1	1 1
EXTERNAL: EG&G BRYCE,J.H	1 1	NRC PDR	1 1
NSIC	1 1		

Cont NO P237846808

NOTE TO ALL "RIDS" RECIPIENTS:

PLEASE HELP US TO REDUCE WASTE! CONTACT THE DOCUMENT CONTROL DESK,
 ROOM P1-37 (EXT. 504-2065) TO ELIMINATE YOUR NAME FROM DISTRIBUTION
 LISTS FOR DOCUMENTS YOU DON'T NEED!

TOTAL NUMBER OF COPIES REQUIRED: LTTR 14 ENCL 14

mmw rpt



ROCHESTER GAS AND ELECTRIC CORPORATION • 89 EAST AVENUE, ROCHESTER N.Y. 14649-0001



ROBERT C. MECREDY
Vice President
Ginna Nuclear Production

TELEPHONE
AREA CODE 716 546-2700

GINNA STATION

April 12, 1993

US Nuclear Regulatory Commission
Document Control Desk
Washington, DC 20555

Subject: Monthly Report for March, 1993
Operating Status Information
R. E. Ginna Nuclear Power Plant
Docket No. 50-244

Dear Sir:

Pursuant to our Technical Specification 6.9.1,
attached herewith is the monthly operating status report
for Ginna Station for the month of March, 1993.

Very truly yours,


Robert C. Mecredy

RCM/jkl

Attachments

cc: Mr. Thomas T. Martin NRC (1)

210062

9304210162 930331
PDR ADDCK 05000244
R PDR

Cent No 1237846808
LEPA
11

810085

OPERATING DATA REPORT

DOCKET NO. 50-244

DATE April 12, 1993

COMPLETED BY Robert E. Dodge
Robert E. Dodge

TELEPHONE (315) 524-4446 ext. 396

OPERATING STATUS

1. Unit Name: R.E. GINNA NUCLEAR POWER PLANT
2. Reporting Period: March, 1993
3. Licensed Thermal Power (Mwt): 1520
4. Nameplate Rating (Gross MWe): 490
5. Design Electrical Rating (Net MWe): 470
6. Maximum Dependable Capacity (Gross MWe): 490
7. Maximum Dependable Capacity (Net MWe): 470
8. If Changes Occur in Capacity Ratings (Items Number 3 Through 7) Since Last Report, Give Reasons:

Notes: The unit was shutdown on March 12 for the Annual Refueling and Maintenance Outage.

9. Power Level to Which Restricted, If Any (Net MWe):
10. Reasons For Restrictions, If Any:

	This Month	Yr.-to-Date	Cumulative **
11. Hours In Report Period	744	2,160	205,050.45
12. Number of Hours Reactor Was Critical	278.47	1,694.47	162,659.14
13. Reactor Reserve Shutdown Hours	0	0	1,687.55 *
14. Hours Generator On-Line	278.25	1,694.25	159,937.38
15. Unit Reserve Shutdown Hours	0	0	8.5 *
16. Gross Thermal Energy Generated (MWH)	386,820	2,490,986	226,534,739
17. Gross Electrical Energy Generated (MWH)	131,622	848,025	74,845,829
18. Net Electrical Energy Generated (MWH)	124,832	806,185	71,042,116
19. Unit Service Factor	37.40%	78.44%	78.15%
20. Unit Availability Factor	37.40%	78.44%	78.16%
21. Unit Capacity Factor (Using MDC Net)	35.70%	78.41%	75.04%
22. Unit Capacity Factor (Using DER Net)	35.70%	78.41%	75.04%
23. Unit Forced Outage Rate	0 %	0 %	5.8 %

24. Shutdowns Scheduled Over Next 6 Months (Type, Date and Duration of Each):

25. If Shut Down At End Of Report Period, Estimated Date of Startup: April 25, 1993

26. Units In Test Status (Prior to Commercial Operation):	Forecast	Achieved
INITIAL CRITICALITY	_____	_____
INITIAL ELECTRICITY	_____	_____
COMMERCIAL OPERATION	_____	_____

*CUMULATIVE TOTAL COMMENCING JANUARY 1, 1975

**CUMULATIVE TOTAL COMMENCING NOVEMBER 8, 1969

AVERAGE DAILY UNIT POWER LEVEL

DOCKET NO. 50-244
 UNIT R.E. Ginna Nuclear Power Plant
 DATE April 12, 1993
 COMPLETED BY Robert E. Dodge

TELEPHONE (315) 524-4446 ext. 396

MONTH March, 1993

DAY AVERAGE DAILY POWER LEVEL
(MWe-Net)

1.	<u>482</u>
2.	<u>479</u>
3.	<u>472</u>
4.	<u>466</u>
5.	<u>460</u>
6.	<u>455</u>
7.	<u>449</u>
8.	<u>444</u>
9.	<u>439</u>
10.	<u>434</u>
11.	<u>432</u>
12.	<u>194</u>
13.	<u>-</u>
14.	<u>-</u>
15.	<u>-</u>
16.	<u>-</u>

DAY AVERAGE DAILY POWER LEVEL
(MWe-Net)

17.	<u>-</u>
18.	<u>-</u>
19.	<u>-</u>
20.	<u>-</u>
21.	<u>-</u>
22.	<u>-</u>
23.	<u>-</u>
24.	<u>-</u>
25.	<u>-</u>
26.	<u>-</u>
27.	<u>-</u>
28.	<u>-</u>
29.	<u>-</u>
30.	<u>-</u>
31.	<u>-</u>

INSTRUCTIONS

On this format, list the average daily unit power level in MWe-Net for each day in the reporting month. Compute to the nearest whole megawatt.

UNIT SHUTDOWN AND POWER REDUCTIONS

REPORT MONTH March

DOCKET NO. 50-244

UNIT NAME R.E. GINNA NUCLEAR POWER PLANT

DATE April 12, 1993

COMPLETED BY Robert Dodge

TELEPHONE (315) 524-4446 ext. 396

No.	Date	Type 1	Duration (Hours)	Reason 2	Method of Shutting Down Reactor 3	Licensee Event Report #	System Code 4	Component Code 5	Cause & Corrective Action to Prevent Recurrence
93-02	3-12-93	S	-	C	1	-	-	-	The unit was shutdown on March 12 for the Annual Refueling and Maintenance Outage. Estimated outage: 42 days.

1
F: Forced
S: Scheduled

2
Reason:
A-Equipment Failure (Explain)
B-Maintenance or Test
C-Refueling
D-Regulatory Restriction
E-Operator Training & License Examination
F-Administrative
G-Operational Error (Explain)
H-Other (Explain)

3
Method:
1-Manual
2-Manual Scram.
3-Automatic Scram.
4-Other (Explain)

4
Exhibit G - Instructions for Preparation of Data Entry Sheets for Licensee Event Report (LER) File (NUREG-0161)

5
Exhibit 1 - Same Source

NARRATIVE SUMMARY OF OPERATING EXPERIENCE

DOCKET NO. 50-244
UNIT R.E. Ginna Nuclear Power Plant
DATE April 12, 1993
COMPLETED BY *Robert E. Dodge*
Robert E. Dodge
TELEPHONE (315) 524-4446 ext. 396

MONTH March, 1993

On March 12, the unit was removed from service for the Annual Refueling and Maintenance Outage. Estimated outage: 42 days.