

ACCELERATED DOCUMENT DISTRIBUTION SYSTEM

REGULATED INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR: 9308170205 DOC. DATE: 93/07/31 NOTARIZED: NO DOCKET #
FACIL: 50-244 Robert Emmet Ginna Nuclear Plant, Unit 1, Rochester G 05000244
AUTH. NAME AUTHOR AFFILIATION
DODGE, R.E. Rochester Gas & Electric Corp.
MECREDY, R.C. Rochester Gas & Electric Corp.
RECIP. NAME RECIPIENT AFFILIATION

SUBJECT: Monthly operating rept for Jul 1993 for RE Ginna Nuclear
Power Plant.W/930811 ltr.

DISTRIBUTION CODE: IE24D COPIES RECEIVED: LTR 1 ENCL 1 SIZE: 5
TITLE: Monthly Operating Report (per Tech Specs)

NOTES: License Exp date in accordance with 10CFR2,2.109(9/19/72). 05000244 /

	RECIPIENT ID CODE/NAME	COPIES LTTR ENCL	RECIPIENT ID CODE/NAME	COPIES LTTR ENCL
	PD1-3 LA	3 3	PD1-3 PD	1 1
	JOHNSON, A	1 1		
INTERNAL:	AEOD/DOA	1 1	AEOD/DSP/TPAB	1 1
	NRR/DORS/OEAB	1 1	NRR/DRIL/RPEB	1 1
	<u>REG FILE</u> 01	1 1	RGN1	1 1
EXTERNAL:	EG&G BRYCE, J.H	1 1	NRC PDR	1 1
	NSIC	1 1		


NOTE TO ALL "RIDS" RECIPIENTS:

PLEASE HELP US TO REDUCE WASTE! CONTACT THE DOCUMENT CONTROL DESK,
ROOM P1-37 (EXT. 504-2065) TO ELIMINATE YOUR NAME FROM DISTRIBUTION
LISTS FOR DOCUMENTS YOU DON'T NEED!

TOTAL NUMBER OF COPIES REQUIRED: LTTR 14 ENCL 14



ROCHESTER GAS AND ELECTRIC CORPORATION • 89 EAST AVENUE, ROCHESTER N.Y. 14649-0001



ROBERT C. MECREDY
Vice President
Ginna Nuclear Production

TELEPHONE
AREA CODE 716 546-2700

GINNA STATION

August 11, 1993

US Nuclear Regulatory Commission
Document Control Desk
Washington, DC 20555

Subject: Monthly Report for July, 1993
Operating Status Information
R. E. Ginna Nuclear Power Plant
Docket No. 50-244

Dear Sir:

Pursuant to our Technical Specification 6.9.1,
attached herewith is the monthly operating status report
for Ginna Station for the month of July, 1993.

Very truly yours,

Robert C. Mecredy
Vice President
Ginna Nuclear Production

JAW: jkl

Attachments

c: Mr. Thomas T. Martin NRC (1)

9308170205 930731
PDR ADDCK 05000244
R PDR

JE24

140002

OPERATING DATA REPORT

DOCKET NO. 50-244

DATE August 11, 1993

COMPLETED BY

Robert E. Dodge
Robert E. Dodge

TELEPHONE (315) 524-4446 Ext. 396

OPERATING STATUS

1. Unit Name: R.E. GINNA NUCLEAR POWER PLANT
2. Reporting Period: July, 1993
3. Licensed Thermal Power (MWt): 1520
4. Nameplate Rating (Gross MWe): 490
5. Design Electrical Rating (Net MWe): 470
6. Maximum Dependable Capacity (Gross MWe): 490
7. Maximum Dependable Capacity (Net MWe): 470
8. If Changes Occur in Capacity Ratings (Items Number 3 Through 7) Since Last Report, Give Reasons:

Notes: The unit operated at 98% power level for the entire month of July.

9. Power Level to Which Restricted, If Any (Net MWe): _____
10. Reasons For Restrictions, If Any: _____

	This Month	Yr.-to-Date	Cumulative **
11. Hours In Report Period	744	5,087	207,977.45
12. Number of Hours Reactor Was Critical	744	4,034.29	164,998.96
13. Reactor Reserve Shutdown Hours	0	0	1,687.55 *
14. Hours Generator On-Line	744	3,998.25	162,241.38
15. Unit Reserve Shutdown Hours	0	0	8.5 *
16. Gross Thermal Energy Generated (MWH)	1,105,566	5,817,031	229,860,784
17. Gross Electrical Energy Generated (MWH)	370,010	1,969,630	75,967,434
18. Net Electrical Energy Generated (MWH)	351,243	1,871,036	72,106,967
19. Unit Service Factor	100%	78.60%	78.16%
20. Unit Availability Factor	100%	78.60%	78.16%
21. Unit Capacity Factor (Using MDC Net)	100.45%	78.26%	75.07%
22. Unit Capacity Factor (Using DER Net)	100.45%	78.26%	75.07%
23. Unit Forced Outage Rate	0 %	0 %	5.73%

24. Shutdowns Scheduled Over Next 6 Months (Type, Date and Duration of Each):

25. If Shut Down At End Of Report Period, Estimated Date of Startup

26. Units In Test Status (Prior to Commercial Operation):	Forecast	Achieved
INITIAL CRITICALITY	_____	_____
INITIAL ELECTRICITY	_____	_____
COMMERCIAL OPERATION	_____	_____

*CUMULATIVE TOTAL COMMENCING JANUARY 1, 1975

**CUMULATIVE TOTAL COMMENCING NOVEMBER 8, 1969

AVERAGE DAILY UNIT POWER LEVEL

DOCKET NO. 50-244
UNIT R.E. Ginna Nuclear Power Plant
DATE August 11, 1993
COMPLETED BY Robert E. Dodge

TELEPHONE (315) 524-4446 Ext. 396

MONTH July, 1993

DAY AVERAGE DAILY POWER LEVEL
(MWe-Net)

1.	<u>475</u>
2.	<u>481</u>
3.	<u>482</u>
4.	<u>481</u>
5.	<u>481</u>
6.	<u>481</u>
7.	<u>480</u>
8.	<u>480</u>
9.	<u>476</u>
10.	<u>472</u>
11.	<u>469</u>
12.	<u>466</u>
13.	<u>466</u>
14.	<u>468</u>
15.	<u>467</u>
16.	<u>467</u>

DAY AVERAGE DAILY POWER LEVEL
(MWe-Net)

17.	<u>468</u>
18.	<u>468</u>
19.	<u>469</u>
20.	<u>469</u>
21.	<u>468</u>
22.	<u>469</u>
23.	<u>470</u>
24.	<u>469</u>
25.	<u>469</u>
26.	<u>471</u>
27.	<u>471</u>
28.	<u>470</u>
29.	<u>469</u>
30.	<u>469</u>
31.	<u>469</u>

INSTRUCTIONS

On this format, list the average daily unit power level in MWe-Net for each day in the reporting month. Compute to the nearest whole megawatt.

UNIT SHUTDOWN AND POWER REDUCTIONS

REPORT MONTH July

DOCKET NO. 50-244

UNIT NAME R.E. GINNA NUCLEAR POWER PLANT

DATE August 11, 1993

COMPLETED BY Robert E. Dodge

TELEPHONE (315) 524-4446, Ext. 396

No.	Date	Type 1	Duration (Hours)	Reason 2	Method of Shutting Down Reactor 3	Licensee Event Report #	System Code 4	Component Code 5	Cause & Corrective Action to Prevent Recurrence
									No power reduction for the month of July.

1
F: Forced
S: Scheduled

2
Reason:
A-Equipment Failure (Explain)
B-Maintenance or Test
C-Refueling
D-Regulatory Restriction
E-Operator Training & License Examination
F-Administrative
G-Operational Error (Explain)
H-Other (Explain)

3
Method:
1-Manual
2-Manual Scram.
3-Automatic Scram.
4-Other (Explain)

4
Exhibit G - Instructions
for Preparation of Data
Entry Sheets for Licensee
Event Report (LER) File (NUREG-
0161)

5
Exhibit 1 - Same Source

NARRATIVE SUMMARY OF OPERATING EXPERIENCE

DOCKET NO. 50-244
UNIT R.E. Ginna Nuclear Power Plant
DATE August 11, 1993
COMPLETED BY Robert E. Dodge
Robert E. Dodge

TELEPHONE (315) 524-4446 Ext. 396

MONTH July, 1993

The unit operated at approximately 98% reactor power level for the month of July.

