

ACCELERATED DISTRIBUTION DEMONSTRATION SYSTEM

REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR:9404190284 DOC.DATE: 94/03/31 NOTARIZED: NO DOCKET #
 FACIL:50-244 Robert Emmet Ginna Nuclear Plant, Unit 1, Rochester G 05000244
 AUTH.NAME AUTHOR AFFILIATION
 PLOOF,R. Rochester Gas & Electric Corp.
 WIDAY,J.A. Rochester Gas & Electric Corp.
 RECIP.NAME RECIPIENT AFFILIATION

SUBJECT: Monthly operating rept for Mar 1994 for Ginna Nuclaer Power
 Plant.W/940411 ltr.

DISTRIBUTION CODE: IE24D COPIES RECEIVED:LTR 1 ENCL 1 SIZE: 5
 TITLE: Monthly Operating Report (per Tech Specs)

NOTES:License Exp date in accordance with 10CFR2,2.109(9/19/72). 05000244

	RECIPIENT		COPIES		
	ID CODE/NAME	PD1-3 PD	LTR	ENCL	
INTERNAL:	AEOD/DOA	1	1	1	
	NRR/DORS/OEAB	1	1	1	
	<u>REG FILE</u> 01	1	1	1	
EXTERNAL:	EG&G BRYCE,J.H	1	1	1	
	NSIC	1	1	1	

NOTE TO ALL "RIDS" RECIPIENTS:

PLEASE HELP US TO REDUCE WASTE! CONTACT THE DOCUMENT CONTROL DESK,
 ROOM P1-37 (EXT. 20079) TO ELIMINATE YOUR NAME FROM DISTRIBUTION
 LISTS FOR DOCUMENTS YOU DON'T NEED!

TOTAL NUMBER OF COPIES REQUIRED: LTR 11 ENCL 11



ROCHESTER GAS AND ELECTRIC CORPORATION • 89 EAST AVENUE, ROCHESTER, N.Y. 14649-0001

JOSEPH A. WIDAY
Plant Manager
Ginna Nuclear Plant

GINNA STATION

TELEPHONE
AREA CODE 716 546-2700

April 11, 1994

US Nuclear Regulatory Commission
Document Control Desk
Washington, DC 20555

Subject: Monthly Report for March, 1994
Operating Status Information
R. E. Ginna Nuclear Power Plant
Docket No. 50-244

Dear Sir:

Pursuant to our Technical Specification 6.9.1,
attached herewith is the monthly operating status report
for Ginna Station for the month of March, 1994.

Very truly yours,


Joseph A. Widay
Joseph A. Widay
Plant Manager

JAW:tjn

Attachments

c: Mr. Thomas T. Martin NRC (1)

200010



TEPA
11

OPERATING DATA REPORT

DOCKET NO. 50-244

DATE April 11, 1994

COMPLETED BY

Ronald Ploof

TELEPHONE (315) 524-4446 Ext. 673

OPERATING STATUS

1. Unit Name: R.E. GINNA NUCLEAR POWER PLANT
2. Reporting Period: March, 1994
3. Licensed Thermal Power (Mwt): 1520
4. Nameplate Rating (Gross MWe): 490
5. Design Electrical Rating (Net MWe): 470
6. Maximum Dependable Capacity (Gross MWe): 490
7. Maximum Dependable Capacity (Net MWe): 470
8. If Changes Occur in Capacity Ratings (Items Number 3 Through 7) Since Last Report, Give Reasons:

Notes: The unit entered its annual refueling outage as scheduled.

9. Power Level to Which Restricted, If Any (Net MWe):
10. Reasons For Restrictions, If Any:

	This Month	Yr.-to-Date	Cumulative **
11. Hours In Report Period	744	2160	213,408
12. Number of Hours Reactor Was Critical	83	1499	170,026
13. Reactor Reserve Shutdown Hours	0	0	1,688 *
14. Hours Generator On-Line	83	1499	167,251.38
15. Unit Reserve Shutdown Hours	0	0	8.5 *
16. Gross Thermal Energy Generated (MWH)	116,893	2,203,684	237,159,697
17. Gross Electrical Energy Generated (MWH)	39,702	750,070	78,433,429
18. Net Electrical Energy Generated (MWH)	37,476	712,434	74,447,807
19. Unit Service Factor	11.16%	69.40%	78.37%
20. Unit Availability Factor	11.16%	69.40%	78.38%
21. Unit Capacity Factor (Using MDC Net)	10.72%	70.18%	75.36%
22. Unit Capacity Factor (Using DER Net)	10.72%	70.18%	70.18%
23. Unit Forced Outage Rate	0%	0 %	5.64%

24. Shutdowns Scheduled Over Next 6 Months (Type, Date and Duration of Each):
Refueling and Maintenance, March 4, 1994 - duration: 41 days.

25. If Shut Down At End of Report Period, Estimated Date of Startup: April 14, 1994.		
26. Units In Test Status (Prior to Commercial Operation):	Forecast	Achieved
INITIAL CRITICALITY	_____	_____
INITIAL ELECTRICITY	_____	_____
COMMERCIAL OPERATION	_____	_____

* CUMULATIVE TOTAL COMMENCING JANUARY 1, 1975
** CUMULATIVE TOTAL COMMENCING NOVEMBER 8, 1969

AVERAGE DAILY UNIT POWER LEVEL

DOCKET NO: 50-244UNIT: R.E. Ginna Nuclear Power PlantDATE: April 11, 1994

COMPLETED BY: _____

Ronald Ploof

TELEPHONE: (315) 524-4446 Ext. 673MONTH March, 1994DAY AVERAGE DAILY POWER LEVEL
(MWe-Net)

1.	<u>480</u>
2.	<u>479</u>
3.	<u>476</u>
4.	<u>290</u>
5.	<u>0</u>
6.	<u>0</u>
7.	<u>0</u>
8.	<u>0</u>
9.	<u>0</u>
10.	<u>0</u>
11.	<u>0</u>
12.	<u>0</u>
13.	<u>0</u>
14.	<u>0</u>
15.	<u>0</u>
16.	<u>0</u>

DAY AVERAGE DAILY POWER LEVEL
(MWe-Net)

17.	<u>0</u>
18.	<u>0</u>
19.	<u>0</u>
20.	<u>0</u>
21.	<u>0</u>
22.	<u>0</u>
23.	<u>0</u>
24.	<u>0</u>
25.	<u>0</u>
26.	<u>0</u>
27.	<u>0</u>
28.	<u>0</u>
29.	<u>0</u>
30.	<u>0</u>
31.	<u>0</u>

INSTRUCTIONS

On this format, list the average daily unit power level in MWe-Net for each day in reporting month. Compute to the nearest whole megawatt.

UNIT SHUTDOWN AND POWER REDUCTIONS

DOCKET NO. 50-244
 UNIT NAME R.E. GINNA NUCLEAR POWER PLANT
 DATE 4/11/94
 COMPLETED BY _____
 TELEPHONE (315) 524-4446 Ext. 673

REPORT MONTH March

No.	Date	Type 1	Duration (Hours)	Reason 2	Method of Shutting Down Reactor 3	Licensee Event Report #	System Code 4	Component Code 5	Cause & Corrective Action to Prevent Recurrence
94-03	4/4/94	S	1681	C	1	---	--	---	Annual Refueling

1
 F: Forced
 S: Scheduled

2
 Reason:
 A-Equipment Failure (Explain)
 B-Maintenance or Test
 C-Refueling
 D-Regulatory Restriction
 E-Operator Training & License Examination
 F-Administrative
 G-Operational Error (Explain)
 H-Other (Explain)

3
 Method:
 1-Manual
 2-Manual Scram.
 3-Automatic Scram.
 4-Other (Explain)

4
 Exhibit G - Instructions
 for Preparation of Data
 Entry Sheets for Licensee
 Event Report (LER) File (NUREG-
 0161)

5
 Exhibit 1 - Same Source

NARRATIVE SUMMARY OF OPERATING EXPERIENCE

DOCKET NO: 50-244

UNIT: R.E. Ginna Nuclear Power Plant

DATE: April 11, 1994

COMPLETED BY: Ronald Ploof

TELEPHONE: (315) 524-4446 Ext. 673

MONTH March, 1994

During the first 4 days of March the average power level was 98%. On March 4, the unit was taken off line as scheduled for its annual maintenance and refueling outage.