

ACCELERATED DISTRIBUTION DEMONSTRATION SYSTEM

REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR:9405190105 DOC.DATE: 94/04/30 NOTARIZED: NO DOCKET #
FACIL:50-244 Robert Emmet Ginna Nuclear Plant, Unit 1, Rochester G 05000244
AUTH.NAME AUTHOR AFFILIATION
PLOOF, R.D. Rochester Gas & Electric Corp.
WIDAY, J.A. Rochester Gas & Electric Corp.
RECIP.NAME RECIPIENT AFFILIATION

SUBJECT: Monthly operating rept for Apr 1994 for RE Ginna Nuclear
Power Plant.W/940510 ltr.

DISTRIBUTION CODE: IE24D COPIES RECEIVED:LTR 1 ENCL 1 SIZE: 5
TITLE: Monthly Operating Report (per Tech Specs)

NOTES:License Exp date in accordance with 10CFR2,2.109(9/19/72). 05000244

| RECIPIENT ID CODE/NAME | COPIES LTTR ENCL | RECIPIENT ID CODE/NAME | COPIES LTTR ENCL |
|---------------------------|---------------------|---------------------------|---------------------|
| PD1-3 PD | 1 1 | JOHNSON, A | 1 1 |
| INTERNAL: AEOD/DOA | 1 1 | AEOD/DSP/TPAB | 1 1 |
| NRR/DORS/OEAB | 1 1 | NRR/DRIL/RPEB | 1 1 |
| <u>REG FILE</u> 01 | 1 1 | RGN1 | 1 1 |
| EXTERNAL: EG&G BRYCE, J.H | 1 1 | NRC PDR | 1 1 |
| NSIC | 1 1 | | |

NOTE TO ALL "RIDS" RECIPIENTS:

PLEASE HELP US TO REDUCE WASTE! CONTACT THE DOCUMENT CONTROL DESK,
ROOM P1-37 (EXT. 20079) TO ELIMINATE YOUR NAME FROM DISTRIBUTION
LISTS FOR DOCUMENTS YOU DON'T NEED!

TOTAL NUMBER OF COPIES REQUIRED: LTTR 11 ENCL 11



ROCHESTER GAS AND ELECTRIC CORPORATION • 89 EAST AVENUE, ROCHESTER, N.Y. 14649-0001

JOSEPH A. WIDAY
Plant Manager
Ginna Nuclear Plant

TELEPHONE
AREA CODE 716 546-2700

GINNA STATION

May 10, 1994

US Nuclear Regulatory Commission
Document Control Desk
Washington, DC 20555

Subject: Monthly Report for April, 1994
Operating Status Information
R. E. Ginna Nuclear Power Plant
Docket No. 50-244

Dear Sir:

Pursuant to our Technical Specification 6.9.1,
attached herewith is the monthly operating status report
for Ginna Station for the month of April, 1994.

Very truly yours,


Joseph A. Widay
Joseph A. Widay
Plant Manager

JAW:tjn

Attachments

c: Mr. Thomas T. Martin NRC (1)

180129
190010



TEDA
11

OPERATING DATA REPORT

-1-

DOCKET N 50-244

DATE May 11, 1994

COMPLETED BY _____

Ronald D. Ploof

TELEPHON (315) 524-4446 Ext.67

OPERATING STATUS

1. Unit N R.E. GINNA NUCLEAR POWER PLANT

Notes:

2. Reporting Period April, 1994

3. Licensed Thermal Power (MWt): 1520

4. Nameplate Rating (Gross MWe): 490

5. Design Electric Rating (Net MWe): 470

6. Maximum Dependable Capacity (Gr 490

7. Maximum Dependable Capacity (Ne 470

8. If Changes Occur in Capacity Rating (Items Number 3 Through 7) Since Last Report, Give Reason:

9. Power Level to Which Restricted, If Any (Net MWe):

10. Reason For Restrictions, If Any:

| | This Month | Yr.-to-Date | Cumulative** |
|--|-----------------|------------------|--------------------|
| 11. Hours in Reported Period | <u>720.0</u> | <u>2855.9</u> | <u>214103.9</u> |
| 12. Number of hours Reactor Was Critical | <u>301.2</u> | <u>1800.5</u> | <u>170326.9</u> |
| 13. Reactor Reserve Shutdown Hours | <u>0.0</u> | <u>0.0</u> | <u>1688.0 *</u> |
| 14. Hours Generator On-line | <u>247.4</u> | <u>1910.8</u> | <u>167662.8</u> |
| 15. Unit Reserve Shutdown Hours | <u>0.0</u> | <u>0.0</u> | <u>8.5 *</u> |
| 16. Gross Thermal Energy Generated (MWH) | <u>283107.0</u> | <u>2486791.0</u> | <u>237442804.0</u> |
| 17. Gross Electrical Energy Generated (MWH) | <u>94581.0</u> | <u>844651.0</u> | <u>78528010.0</u> |
| 18. Net Electrical Energy Generated (MWH) | <u>88952.0</u> | <u>801386.0</u> | <u>74536759.0</u> |
| 19. Unit Service Factor (%) | <u>34.4</u> | <u>66.9</u> | <u>78.3</u> |
| 20. Unit Availability Factor (%) | <u>34.4</u> | <u>66.9</u> | <u>78.3</u> |
| 21. Unit Capacity Factor (using MDC Net) (%) | <u>26.3</u> | <u>59.7</u> | <u>75.2</u> |
| 22. Unit Capacity Factor (using DER Net) (%) | <u>26.3</u> | <u>59.7</u> | <u>75.2</u> |
| 23. Unit Forced Outage Rate (%) | <u>6.2</u> | <u>2.3</u> | <u>5.6</u> |

24. Shutdowns Scheduled Over Next 6 Months (Type, Date and Duration of Each):

25. If Shutdown At End of Report Period, Estimate Date of Startup:

26. Units in Test Status (Prior to Commercial Operation):

Forecast

Achieved

INITIAL CRITICALITY

INITIAL ELECTRICITY

COMMERCIAL OPERATION

* CUMULATIVE TOTAL COMMENCING JANUARY 1, 1975

** CUMULATIVE TOTAL COMMENCING NOVEMBER 8, 1969

AVERAGE DAILY UNIT POWER LEVEL

DOCKET NO: 50-244

UNIT: R.E. Ginna Nuclear Power Plant

DATE: May 10, 1994

COMPLETED BY: Ronald Ploof
Ronald Ploof

TELEPHONE: (315) 524-4446 Ext. 673

MONTH April, 1994

DAY AVERAGE DAILY POWER LEVEL
(MWe-Net)

| | |
|-----|-----------|
| 1. | <u>-1</u> |
| 2. | <u>-1</u> |
| 3. | <u>-1</u> |
| 4. | <u>-1</u> |
| 5. | <u>-1</u> |
| 6. | <u>-1</u> |
| 7. | <u>-2</u> |
| 8. | <u>-1</u> |
| 9. | <u>-1</u> |
| 10. | <u>-1</u> |
| 11. | <u>-1</u> |
| 12. | <u>-1</u> |
| 13. | <u>-1</u> |
| 14. | <u>-1</u> |
| 15. | <u>-2</u> |
| 16. | <u>-8</u> |

DAY AVERAGE DAILY POWER LEVEL
(MWe-Net)

| | |
|-----|------------|
| 17. | <u>-8</u> |
| 18. | <u>3</u> |
| 19. | <u>168</u> |
| 20. | <u>309</u> |
| 21. | <u>429</u> |
| 22. | <u>462</u> |
| 23. | <u>480</u> |
| 24. | <u>482</u> |
| 25. | <u>482</u> |
| 26. | <u>132</u> |
| 27. | <u>54</u> |
| 28. | <u>11</u> |
| 29. | <u>194</u> |
| 30. | <u>479</u> |
| 31. | <u>---</u> |

INSTRUCTIONS

On this format, list the average daily unit power level in MWe-Net for each day in reporting month. Compute to the nearest whole megawatt.

1944

UNIT SHUTDOWN AND POWER REDUCTIONS

DOCKET NO. 50-244
 UNIT NAME: R.E. GINNA NUCLEAR POWER PLANT
 DATE: May 10, 1994
 COMPLETED BY: Ronald Ploof
 TELEPHONE: 315-524-4446 X673

REPORT MONTH April

| No. | Date | Type 1 | Duration (Hours) | Reason 2 | Method of Shutting Down Reactor 3 | Licensee Event Report # | System Code 4 | Component Code 5 | Cause & Corrective Action to Prevent Recurrence |
|-------|---------|--------|------------------|----------|-----------------------------------|-------------------------|---------------|------------------|---|
| 94-04 | 4-26-94 | F | 15.6 | B | 1 | --- | -- | --- | Steam leak on HP Turbine instrument fitting, longer fitting installed. |
| 94-05 | 4-27-94 | F | 11.5 | A | 3 | 94-008 | JB | LCV | Main feedwater regulating valve failed to move. Replaced positioners style. |

1
 F: Forced
 S: Scheduled

2
 Reason:
 A-Equipment Failure (Explain)
 B-Maintenance or Test
 C-Refueling
 D-Regulatory Restriction
 E-Operator Training & License Examination
 F-Administrative
 G-Operational Error (Explain)
 H-Other (Explain)

3
 Method:
 1-Manual
 2-Manual Scram.
 3-Automatic Scram.
 4-Other (Explain)

4
 Exhibit G - Instructions for Preparation of Data Entry Sheets for Licensee Event Report (LER) File (NUREG-0161)

5
 Exhibit 1 - Same Source

NARRATIVE SUMMARY OF OPERATING EXPERIENCE

DOCKET NO: 50-244

UNIT: R.E. Ginna Nuclear Power Plant

DATE: May 10, 1994

COMPLETED BY: Ronald Ploof

TELEPHONE: (315) 524-4446 Ext. 673

MONTH April, 1994

The unit came on-line on 4/18/94 from its annual maintenance and refueling outage and returned to full power on 4/23/94. On 4/26/94, the unit shutdown to repair a small instrument line steam leak on the HP turbine. The unit was placed back on-line on 4/27/94. At approximately 40% power, the unit tripped off-line on 4/27/94 on its way to full power due to low S/G level caused by a faulty main feedwater regulatory valve. The unit was placed back on-line on 4/28/94 and returned to full power on 4/30/94.

