

NARRATIVE SUMMARY OF OPERATING EXPERIENCE

DOCKET NO: 50-244

UNIT: R.E. Ginna Nuclear Power Plant

DATE: June 15, 1994

COMPLETED BY: *Ronald Ploof*
Ronald Ploof

TELEPHONE: (315) 524-4446 Ext. 673

MONTH May, 1994

During the month of May the average power level was 97%. On May 3, the unit was taken off line to repair a leak in the CCW cooling line to the "A" RCP. The unit was returned to full power on May 6.

