

REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR: 9408220109 DOC. DATE: ~~94/07/31~~ NOTARIZED: NO DOCKET #
 FACIL: 50-244 Robert Emmet Ginna Nuclear Plant, Unit 1, Rochester G 05000244
 AUTH. NAME AUTHOR AFFILIATION
 PLOOF, R. Rochester Gas & Electric Corp.
 WIDAY, J.A. Rochester Gas & Electric Corp.
 RECIP. NAME RECIPIENT AFFILIATION

SUBJECT: Monthly operating ~~rept~~ for Jul 1994 for RE Ginna Nuclear
 Power Plant. W/940809 ltr.

DISTRIBUTION CODE: IE24D COPIES RECEIVED: LTR 1 ENCL 1 SIZE: 5
 TITLE: Monthly Operating Report (per Tech Specs)

NOTES: License Exp date in accordance with 10CFR2,2.109(9/19/72). 05000244

	RECIPIENT ID CODE/NAME	COPIES LTTR ENCL	RECIPIENT ID CODE/NAME	COPIES LTTR ENCL
	PD1-3 PD	1 1	JOHNSON, A	1 1
INTERNAL:	AEOD/DSP/TPAB	1 1	NRR/DORS/OEAB	1 1
	NRR/DRIL/RPEB	1 1	<u>REG FILE</u> 01	1 1
	RGN1	1 1		
EXTERNAL:	EG&G BRYCE, J.H	1 1	NOAC	1 1
	NRC PDR	1 1		

NOTE TO ALL "RIDS" RECIPIENTS:

PLEASE HELP US TO REDUCE WASTE! CONTACT THE DOCUMENT CONTROL
 DESK, ROOM P1-37 (EXT. 504-2083) TO ELIMINATE YOUR NAME FROM
 DISTRIBUTION LISTS FOR DOCUMENTS YOU DON'T NEED!


TOTAL NUMBER OF COPIES REQUIRED: LTTR 10 ENCL 10

MR

P
R
I
O
R
I
T
Y

1

D
O
C
U
M
E
N
T



ROCHESTER GAS AND ELECTRIC CORPORATION • 89 EAST AVENUE, ROCHESTER, N.Y. 14649-0001

JOSEPH A. WIDAY
Plant Manager
Ginna Nuclear Plant

TELEPHONE
AREA CODE 716 546-2700

GINNA STATION

August 9, 1994

US Nuclear Regulatory Commission
Document Control Desk
Washington, DC 20555

Subject: Monthly Report for July, 1994
Operating Status Information
R. E. Ginna Nuclear Power Plant
Docket No. 50-244

Dear Sir:

Pursuant to our Technical Specification 6.9.1,
attached herewith is the monthly operating status report
for Ginna Station for the month of July, 1994.

Very truly yours,

Thomas A. Marlow *Per*
Joseph A. Widay
Plant Manager

JAW:tjn

Attachments

c: Mr. Thomas T. Martin NRC (1)

100000
9408220109 940731
PDR ADDCK 05000244
R PDR

IFR
11

2011-2012

OPERATING DATA REPORT

-1-

DOCKET NO. 50-244

DATE: August 9, 1994

COMPLETED BY: Ronald D. Ploof

Ronald D. Ploof

TELEPHONE (315)524-4446 Ext.673

OPERATING STATUS

1. Unit N R.E. GINNA NUCLEAR POWER PLANT

Notes:

2. Reporting Period: July, 1994

3. Licensed Thermal Power (MWt): 1520

4. Nameplate Rating (Gross MWe): 490

5. Design Electric Rating (Net MWe): 470

6. Maximum Dependable Capacity (Gross MWe): 490

7. Maximum Dependable Capacity (Net MWe): 470

8. If Changes Occur in Capacity Rating (Items Number 3 Through 7) Since Last Report, Give Reason:

9. Power Level to Which Restricted, If Any (Net MWe):

10. Reason For Restrictions, If Any:

	This Month	Yr.-to-Date	Cumulative**
11. Hours in Reported Period	<u>744.0</u>	<u>5087.0</u>	<u>216335.0</u>
12. Number of hours Reactor Was Critical	<u>744.0</u>	<u>3915.1</u>	<u>172441.6</u>
13. Reactor Reserve Shutdown Hours	<u>0.0</u>	<u>0.0</u>	<u>1688.0 *</u>
14. Hours Generator On-line	<u>744.0</u>	<u>3851.9</u>	<u>169603.9</u>
15. Unit Reserve Shutdown Hours	<u>0.0</u>	<u>0.0</u>	<u>8.5 *</u>
16. Gross Thermal Energy Generated (MWH)	<u>1103845</u>	<u>5570613</u>	<u>240526626</u>
17. Gross Electrical Energy Generated (MWH)	<u>366443</u>	<u>1882634</u>	<u>79565993</u>
18. Net Electrical Energy Generated (MWH)	<u>348165</u>	<u>1788132</u>	<u>75523505</u>
19. Unit Service Factor (%)	<u>100.0</u>	<u>75.7</u>	<u>78.4</u>
20. Unit Availability Factor (%)	<u>100.0</u>	<u>75.7</u>	<u>78.4</u>
21. Unit Capacity Factor (using MDC Net) (%)	<u>99.6</u>	<u>74.8</u>	<u>75.4</u>
22. Unit Capacity Factor (using DER Net) (%)	<u>99.6</u>	<u>74.8</u>	<u>75.4</u>
23. Unit Forced Outage Rate (%)	<u>7.7</u>	<u>4.2</u>	<u>5.6</u>

24. Shutdowns Scheduled Over Next 6 Months (Type, Date and Duration of Each):

25. If Shutdown At End of Report Period, Estimate Date of Startup:

26. Units in Test Status (Prior to Commercial Operation):

Forecast

Achieved

INITIAL CRITICALITY

INITIAL ELECTRICITY

COMMERCIAL OPERATION

* CUMULATIVE TOTAL COMMENCING JANUARY 1, 1975

** CUMULATIVE TOTAL COMMENCING NOVEMBER 8, 1969

AVERAGE DAILY UNIT POWER LEVEL

DOCKET NO: 50-244

UNIT: R.E. Ginna Nuclear Power Plant

DATE: August 9, 1994

COMPLETED BY: _____

Ronald Ploof

TELEPHONE: (315) 524-4446 Ext. 673

MONTH July, 1994

DAY AVERAGE DAILY POWER LEVEL
(MWe-Net)

1.	<u>476</u>
2.	<u>477</u>
3.	<u>476</u>
4.	<u>475</u>
5.	<u>474</u>
6.	<u>473</u>
7.	<u>472</u>
8.	<u>472</u>
9.	<u>470</u>
10.	<u>469</u>
11.	<u>471</u>
12.	<u>471</u>
13.	<u>468</u>
14.	<u>468</u>
15.	<u>469</u>
16.	<u>467</u>

DAY AVERAGE DAILY POWER LEVEL
(MWe-Net)

17.	<u>467</u>
18.	<u>468</u>
19.	<u>467</u>
20.	<u>467</u>
21.	<u>467</u>
22.	<u>466</u>
23.	<u>463</u>
24.	<u>467</u>
25.	<u>462</u>
26.	<u>463</u>
27.	<u>463</u>
28.	<u>463</u>
29.	<u>463</u>
30.	<u>462</u>
31.	<u>462</u>

INSTRUCTIONS

On this format, list the average daily unit power level in MWe-Net for each day in reporting month. Compute to the nearest whole megawatt.

UNIT SHUTDOWN AND POWER REDUCTIONS

REPORT MONTH July

DOCKET NO. 50-244
 UNIT NAME R.E. GINNA NUCLEAR POWER PLANT
 DATE August 9, 1994
 COMPLETED BY Ronald Ploof
 TELEPHONE (315) 524-4446 Ext. 673

No.	Date	Type 1	Duration (Hours)	Reason 2	Method of Shutting Down Reactor 3	Licensee Event Report #	System Code 4	Component Code 5	Cause & Corrective Action to Prevent Recurrence
---	----	--	---	---	---	---	--	---	-----

1
 F: Forced
 S: Scheduled

2
 Reason:
 A-Equipment Failure (Explain)
 B-Maintenance or Test
 C-Refueling
 D-Regulatory Restriction
 E-Operator Training & License Examination
 F-Administrative
 G-Operational Error (Explain)
 H-Other (Explain)

3
 Method:
 1-Manual
 2-Manual Scram.
 3-Automatic Scram.
 4-Other (Explain)

4
 Exhibit G - Instructions
 for Preparation of Data
 Entry Sheets for Licensee
 Event Report (LER) File (NUREG-
 0161)

5
 Exhibit 1 - Same Source

NARRATIVE SUMMARY OF OPERATING EXPERIENCE

DOCKET NO: 50-244

UNIT: R.E. Ginna Nuclear Power Plant

DATE: August 9, 1994

COMPLETED BY: Ronald Ploof

TELEPHONE: (315) 524-4446 Ext. 673

MONTH July, 1994

During the month of July the average power was 98%.