

PRIORITY 1

(ACCELERATED RIDS PROCESSING)

REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR: 9410040089 DOC. DATE: 94/09/27 NOTARIZED: NO DOCKET #
 FACIL: 50-244 Robert Emmet Ginna Nuclear Plant, Unit 1, Rochester G 05000244
 AUTH. NAME AUTHOR AFFILIATION
 MECREDY, R.C. Rochester Gas & Electric Corp.
 RECIP. NAME RECIPIENT AFFILIATION
 JOHNSON, A.R. Project Directorate I-3

See Rpt.

SUBJECT: Forwards 51-1224912-01, "Safety Evaluation of Ginna SG Replacement."

DISTRIBUTION CODE: A001D COPIES RECEIVED: LTR 1 ENCL 1 SIZE: 2+67
 TITLE: OR Submittal: General Distribution

NOTES: License Exp date in accordance with 10CFR2,2.109(9/19/72). 05000244

RECIPIENT ID CODE/NAME	COPIES LTTR ENCL	RECIPIENT ID CODE/NAME	COPIES LTTR ENCL
PD1-3 LA	1 1	PD1-3 PD	1 1
JOHNSON, A	1 1		
INTERNAL: FREE CENTER 01	1 1	NRR/DE/EELB	1 1
NRR/DRCH/HICB	1 1	NRR/DRPW	1 1
NRR/DSSA/SPLB	1 1	NRR/DSSA/SRXB	1 1
NUDOCS-ABSTRACT	1 1	OC/LFDCB	1 0
OGC/HDS3	1 0		
EXTERNAL: NOAC	1 1	NRC PDR	1 1

NOTE TO ALL "RIDS" RECIPIENTS:

PLEASE HELP US TO REDUCE WASTE! CONTACT THE DOCUMENT CONTROL
 DESK, ROOM P1-37 (EXT. 504-2083) TO ELIMINATE YOUR NAME FROM
 DISTRIBUTION LISTS FOR DOCUMENTS YOU DON'T NEED!

TOTAL NUMBER OF COPIES REQUIRED: LTTR 14 ENCL 12

MA2

P
R
I
O
R
I
T
Y

1

D
O
C
U
M
E
N
T



ROCHESTER GAS AND ELECTRIC CORPORATION • 89 EAST AVENUE, ROCHESTER, N.Y. 14649-0001



AREA CODE 716 546-2700

ROBERT C. MECREDDY
Vice President
Ginna Nuclear Production

September 27, 1994

U.S. Nuclear Regulatory Commission
Document Control Desk
Attn: Allen R. Johnson
Project Directorate I-3
Washington, D.C. 20555


Subject: Preliminary Safety Evaluation of
Replacement Steam Generators
R.E. Ginna Nuclear Power Plant
Docket No. 50-244

Dear Mr. Johnson:

Rochester Gas and Electric has completed a preliminary safety evaluation of the BWI Replacement Steam Generators (RSGs). RG&E intends to install the RSGs in the Ginna Plant in the spring of 1996. The results of the safety evaluation show that operation of Ginna with the replacement steam generators does not involve any unreviewed safety questions, nor will it require any Technical Specification changes. Consequently, the preliminary safety evaluation indicates that the replacement may be performed under the provisions of 10CFR50.59 without prior NRC approval.

RG&E is providing a copy of this safety evaluation in order to keep the NRC informed of the ongoing status of this project. RG&E is not requesting NRC review and approval of this document. The final safety evaluation will be forwarded for your information when completed.

Very truly yours,


Robert C. Mecreddy

BJF\347
Attachment

xc: Mr. Allen R. Johnson (Mail Stop 14D1)
Project Directorate I-3
Washington, D.C. 20555

U.S. Nuclear Regulatory Commission
Region I
475 Allendale Road
King of Prussia, PA 19406

Ginna Senior Resident Inspector

6488 9410040089 940927
PDR AD00CK 05000244
PDR

Accol
11

1-1

1-1

1-1

1-1

1-1

1-1

Rochester Gas & Electric Corporation

Interoffice Correspondence

September 22, 1994


To: File EWR 10034

Subject: Approval of Vendor Technical Documents
BWNT Document #51-1224912-01, "Evaluation
of Ginna SG Replacement"

In accordance with Engineering Procedure QE-704 Rev. 3, effective 5/11/92, the purpose of this memorandum is to identify that the subject document has been reviewed and accepted for use by Rochester Gas and Electric Corporation.


The results of the evaluation are applicable to R.E. Ginna. The evaluation is preliminary, and requires that the conclusions of several sections be verified by detailed analysis. These sections are adequately identified in the body of the evaluation, and are summarized in Section 6, pp 64-65. The evaluation will be revised to include the results of these analyses.

Prepared by:


Nuclear Engineer, SGRP


Date: 9/22/94

NS&L Review:


NS&L Engineer

Date: 9/22/94

Reviewed &
Approved


Manager NS&L

Date: 9/22/94

BJF:tad

RGE 94-077