

PRIORITY 1

ACCELERATED RIDS PROCESSING

REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR: 9410170121 DOC. DATE: ~~94/09/30~~ NOTARIZED: NO DOCKET #
 FACIL: 50-244 Robert Emmet Ginna Nuclear Plant, Unit 1, Rochester G 05000244
 AUTH. NAME AUTHOR AFFILIATION
 PLOOF, R. Rochester Gas & Electric Corp.
 WIDAY, J.A. Rochester Gas & Electric Corp.
 RECIP. NAME RECIPIENT AFFILIATION

SUBJECT: Monthly operating rpt for Sept 1994 for RE Ginna Nuclear
 Power Plant. ~~W/941007~~ Ltr.

DISTRIBUTION CODE: IE24D COPIES RECEIVED: LTR 1 ENCL 1 SIZE: 5
 TITLE: Monthly Operating Report (per Tech Specs)

NOTES: License Exp date in accordance with 10CFR2,2.109(9/19/72). 05000244

	RECIPIENT ID CODE/NAME	COPIES LTTR ENCL	RECIPIENT ID CODE/NAME	COPIES LTTR ENCL
	PD1-3 PD	1 1	JOHNSON, A	1 1
INTERNAL:	AEOD/SPD/RRAB	1 1	<u>FILE CENTER 01</u>	1 1
	NRR/DORS/OEAB	1 1	<u>NRR/PMAS/IRCB=E</u>	1 1
	RGN1	1 1		
EXTERNAL:	EG&G BRYCE, J.H	1 1	NOAC	1 1
	NRC PDR	1 1		

NOTE TO ALL "RIDS" RECIPIENTS:

PLEASE HELP US TO REDUCE WASTE! CONTACT THE DOCUMENT CONTROL
 DESK, ROOM P1-37 (EXT. 504-2083) TO ELIMINATE YOUR NAME FROM
 DISTRIBUTION LISTS FOR DOCUMENTS YOU DON'T NEED!

TOTAL NUMBER OF COPIES REQUIRED: LTTR 10 ENCL 10

mk



ROCHESTER GAS AND ELECTRIC CORPORATION • 89 EAST AVENUE, ROCHESTER, N.Y. 14649-0001

JOSEPH A. WIDAY
Plant Manager
Ginna Nuclear Plant

TELEPHONE
AREA CODE 716 546-2700

GINNA STATION

October 7, 1994

US Nuclear Regulatory Commission
Document Control Desk
Washington, DC 20555

Subject: Monthly Report for September, 1994
Operating Status Information
R. E. Ginna Nuclear Power Plant
Docket No. 50-244

Dear Sir:

Pursuant to our Technical Specification 6.9.1,
attached herewith is the monthly operating status report
for Ginna Station for the month of September, 1994.

Very truly yours,

Joseph A. Widay
Joseph A. Widay
Plant Manager

JAW: jkl

Attachments

c: Mr. Thomas T. Martin NRC (1)

170056

9410170121 940930
PDR ADCEK 05000244
R PDR

JE24

OPERATING DATA REPORT

-1-

DOCKET NO. 50-244

DATE: October 7, 1994

COMPLETED BY: Ronald D. Ploof
Ronald D. Ploof

TELEPHONE (315)524-4446 Ext.673

OPERATING STATUS

1. Unit Na R.E. GINNA NUCLEAR POWER PLANT
2. Reporting Period: September, 1994
3. Licensed Thermal Power (MWt): 1520
4. Nameplate Rating (Gross MWe): 490
5. Design Electric Rating (Net MWe): 470
6. Maximum Dependable Capacity (Gross MWe): 490
7. Maximum Dependable Capacity (Net MWe): 470
8. If Changes Occur in Capacity Rating (Items Number 3 Through 7) Since Last Report, Give Reason:

Notes: On 9/10/94 the unit reduced power to 50% for 24 hrs in order to repair a condenser tube leak

9. Power Level to Which Restricted, If Any (Net MWe):

10. Reason For Restrictions, If Any:

	This Month	Yr.-to-Date	Cumulative**
11. Hours in Reported Period	720.0	6551.0	217799.0
12. Number of hours Reactor Was Critical	720.0	1165.0	1165.0
13. Reactor Reserve Shutdown Hours	0.0	0.0	0.0 *
14. Hours Generator On-line	720.0	5010.9	170762.9
15. Unit Reserve Shutdown Hours	0.0	0.0	8.5 *
16. Gross Thermal Energy Generated (MWH)	1060583	7246875	242202888
17. Gross Electrical Energy Generated (MWH)	351720	2435374	80118733
18. Net Electrical Energy Generated (MWH)	334120	2312587	76047960
19. Unit Service Factor (%)	100.0	76.5	78.4
20. Unit Availability Factor (%)	100.0	76.5	78.4
21. Unit Capacity Factor (using MDC Net) (%)	98.7	75.1	75.4
22. Unit Capacity Factor (using DER Net) (%)	98.7	75.1	75.4
23. Unit Forced Outage Rate (%)	0.0	5.7	0.2

24. Shutdowns Scheduled Over Next 6 Months (Type, Date and Duration of Each):

Refueling and Maintenance, Start 3/19/95, Duration 40 days

25. If Shutdown At End of Report Period, Estimate Date of Startup:

26. Units in Test Status (Prior to Commercial Operation):

Forecast

Achieved

INITIAL CRITICALITY

INITIAL ELECTRICITY

COMMERCIAL OPERATION

* CUMULATIVE TOTAL COMMENCING JANUARY 1, 1975

** CUMULATIVE TOTAL COMMENCING NOVEMBER 8, 1969

AVERAGE DAILY UNIT POWER LEVEL

DOCKET NO: 50-244UNIT: R.E. Ginna Nuclear Power PlantDATE: 10/7/94COMPLETED BY: Ron Ploof (R.P.)
Ron PloofTELEPHONE: (315) 524-4446 Ext. 673MONTH September, 1994DAY AVERAGE DAILY POWER LEVEL
(MWe-Net)

1.	<u>466</u>
2.	<u>467</u>
3.	<u>468</u>
4.	<u>468</u>
5.	<u>468</u>
6.	<u>468</u>
7.	<u>468</u>
8.	<u>469</u>
9.	<u>469</u>
10.	<u>271</u>
11.	<u>463</u>
12.	<u>469</u>
13.	<u>470</u>
14.	<u>469</u>
15.	<u>471</u>
16.	<u>470</u>

DAY AVERAGE DAILY POWER LEVEL
(MWe-Net)

17.	<u>469</u>
18.	<u>469</u>
19.	<u>470</u>
20.	<u>469</u>
21.	<u>470</u>
22.	<u>469</u>
23.	<u>472</u>
24.	<u>478</u>
25.	<u>479</u>
26.	<u>480</u>
27.	<u>480</u>
28.	<u>479</u>
29.	<u>477</u>
30.	<u>476</u>
31.	<u></u>

INSTRUCTIONS

On this format, list the average daily unit power level in MWe-Net for each day in reporting month. Compute to the nearest whole megawatt.

UNIT SHUTDOWN AND POWER REDUCTIONS

REPORT MONTH September

DOCKET NO. 50-244

UNIT NAME R.E. GINNA NUCLEAR POWER PLANT

DATE 10/07/94

COMPLETED BY Ron Ploof (JL)
Ron Ploof

TELEPHONE (315) 524-4446, Ext. 673

No.	Date	Type 1	Duration (Hours)	Reason 2	Method of Shutting Down Reactor 3	Licensee Event Report #	System Code 4	Component Code 5	Cause & Corrective Action to Prevent Recurrence
94-09	9/10/94	F	24.7	A	1	-	-	-	Repair Condenser Tube Leak

1
F: Forced
S: Scheduled

2
Reason:
A-Equipment Failure (Explain)
B-Maintenance or Test
C-Refueling
D-Regulatory Restriction
E-Operator Training & License Examination
F-Administrative
G-Operational Error (Explain)
H-Other (Explain)

3
Method:
1-Manual
2-Manual Scram.
3-Automatic Scram.
4-Other (Explain)

4
Exhibit G - Instructions
for Preparation of Data
Entry Sheets for Licensee
Event Report (LER) File (NUREG-
0161)

5
Exhibit 1 - Same Source

NARRATIVE SUMMARY OF OPERATING EXPERIENCE

DOCKET NO: 50-244

UNIT: R.E. Ginna Nuclear Power Plant

DATE: 10/7/94

COMPLETED BY: Ron Ploof (R)
Ron Ploof

TELEPHONE: (315) 524-4446 Ext. 673

MONTH September, 1994

During the month of September, the average power level was 97%.
On September 10, the unit reduced power to 49% to repair a
condenser tube leak. The unit was returned to full power on
September 11.