

# PRIORITY 1

(ACCELERATED RIDS PROCESSING)

## REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR: 9503140226      DOC. DATE: ~~95/02/28~~ NOTARIZED: NO      DOCKET #  
 FACIL: 50-244 Robert Emmet Ginna Nuclear Plant, Unit 1, Rochester G      05000244  
 AUTH. NAME      AUTHOR AFFILIATION  
 WALDEN, J. V.      Rochester Gas & Electric Corp.  
 WIDAY, J. A.      Rochester Gas & Electric Corp.  
 RECIP. NAME      RECIPIENT AFFILIATION

SUBJECT: Monthly operating ~~rept~~ for Feb 1995 for RE Ginna Nuclear  
 Power Plant. W/950307 Ltr.

DISTRIBUTION CODE: IE24D      COPIES RECEIVED: LTR 1 ENCL 1 SIZE: 5  
 TITLE: Monthly Operating Report (per Tech Specs)

NOTES: License Exp date in accordance with 10CFR2,2.109(9/19/72).      05000244

	RECIPIENT ID CODE/NAME	COPIES LTTR ENCL	RECIPIENT ID CODE/NAME	COPIES LTTR ENCL
	PD1-3 PD	1    1	JOHNSON, A	1    1
INTERNAL:	AEOD/SPD/RRAB	1    1	<u>FILE CENTER</u> 01	1    1
	NRR/DISP/PIPB	1    1	NRR/DOPS/OECB	1    1
	RGN1	1    1		
EXTERNAL:	LITCO BRYCE, J H	1    1	NOAC	1    1
	NRC PDR	1    1		

**NOTE TO ALL "RIDS" RECIPIENTS:**

PLEASE HELP US TO REDUCE WASTE! CONTACT THE DOCUMENT CONTROL  
 DESK, ROOM P1-37 (EXT. 504-2083) TO ELIMINATE YOUR NAME FROM  
 DISTRIBUTION LISTS FOR DOCUMENTS YOU DON'T NEED!

TOTAL NUMBER OF COPIES REQUIRED: LTTR    10    ENCL    10

*MR*



ROCHESTER GAS AND ELECTRIC CORPORATION • 89 EAST AVENUE, ROCHESTER, N.Y. 14649-0001



TELEPHONE  
AREA CODE 716 546-2700

GINNA STATION

March 7, 1995

US Nuclear Regulatory Commission  
Document Control Desk  
Washington, DC 20555

Subject: Monthly Report for February, 1995  
Operating Status Information  
R. E. Ginna Nuclear Power Plant  
Docket No. 50-244

Dear Sir:

Pursuant to our Technical Specification 6.9.1,  
attached herewith is the monthly operating status report  
for Ginna Station for the month of February, 1995.

Very truly yours,

*Joseph A. Widay*  
Joseph A. Widay  
Plant Manager

JAW:tjn

Attachments

c: Mr. Thomas T. Martin NRC (1)

140100  
9503140226 950228  
PDR ADCK 05000244  
R PDR

*IF24*  
*11*

# OPERATING DATA REPORT

-1-

50-244

March 7, 1995

COMPLETED BY:

*John V. Walden*  
John V. Walden

TELEPHONE (315)524-4446 Ext.673

## OPERATING STATUS

1. Unit Name: R.E. GINNA NUCLEAR POWER PLANT

Notes:

2. Reporting Period: February, 1995

3. Licensed Thermal Power (MWt): 1520

4. Nameplate Rating (Gross MWe): 490

5. Design Electric Rating (Net MWe): 470

6. Maximum Dependable Capacity (Gross MWe): 490

7. Maximum Dependable Capacity (Net MWe): 470

8. If Changes Occur In Capacity Rating (Items Number 3 Through 7) Since Last Report, Give Reason:

9. Power Level to Which Restricted, If Any (Net MWe):

10. Reason For Restrictions, If Any:

	This Month	Yr.-to-Date	Cumulative**
11. Hours In Reported Period	<u>672.0</u>	<u>1416.0</u>	<u>221424.0</u>
12. Number of hours Reactor Was Critical	<u>672.0</u>	<u>1416.0</u>	<u>177231.8</u>
13. Reactor Reserve Shutdown Hours	<u>0.0</u>	<u>0.0</u>	<u>1687.6 *</u>
14. Hours Generator On-line	<u>672.0</u>	<u>1416.0</u>	<u>174388.3</u>
15. Unit Reserve Shutdown Hours	<u>0.0</u>	<u>0.0</u>	<u>8.5 *</u>
16. Gross Thermal Energy Generated (MWH)	<u>1000530.0</u>	<u>2096422.0</u>	<u>247611659.0</u>
17. Gross Electrical Energy Generated (MWH)	<u>338388.0</u>	<u>708460.0</u>	<u>81942512.0</u>
18. Net Electrical Energy Generated (MWH)	<u>321771.0</u>	<u>673576.0</u>	<u>77782806.0</u>
19. Unit Service Factor (%)	<u>100.0</u>	<u>100.0</u>	<u>78.8</u>
20. Unit Availability Factor (%)	<u>100.0</u>	<u>100.0</u>	<u>78.8</u>
21. Unit Capacity Factor (using MDC Net) (%)	<u>101.9</u>	<u>101.2</u>	<u>75.8</u>
22. Unit Capacity Factor (using DER Net) (%)	<u>101.9</u>	<u>101.2</u>	<u>75.8</u>
23. Unit Forced Outage Rate (%)	<u>0.0</u>	<u>0.0</u>	<u>5.7</u>

24. Shutdowns Scheduled Over Next 6 Months (Type, Date and Duration of Each):

Refueling and Maintenance, Start 3/26/95, Duration 36 days

25. If Shutdown At End of Report Period, Estimate Date of Startup:

26. Units in Test Status (Prior to Commercial Operation):

Forecast

INITIAL CRITICALITY

INITIAL ELECTRICITY

COMMERCIAL OPERATION

\* CUMULATIVE TOTAL COMMENCING JANUARY 1, 1975

\*\* CUMULATIVE TOTAL COMMENCING NOVEMBER 8, 1969

# AVERAGE DAILY UNIT POWER LEVEL

DOCKET NO: 50-244

UNIT: R.E. Ginna Nuclear Power Plant

DATE: March 7, 1995

COMPLETED BY: John Walden  
John Walden

TELEPHONE: (315) 524-4446 Ext. 588

MONTH February, 1995

DAY AVERAGE DAILY POWER LEVEL  
(MWe-Net)

1.	<u>484</u>
2.	<u>483</u>
3.	<u>483</u>
4.	<u>484</u>
5.	<u>484</u>
6.	<u>484</u>
7.	<u>484</u>
8.	<u>484</u>
9.	<u>484</u>
10.	<u>433</u>
11.	<u>412</u>
12.	<u>482</u>
13.	<u>482</u>
14.	<u>482</u>
15.	<u>483</u>
16.	<u>483</u>

DAY AVERAGE DAILY POWER LEVEL  
(MWe-Net)

17.	<u>483</u>
18.	<u>484</u>
19.	<u>484</u>
20.	<u>484</u>
21.	<u>483</u>
22.	<u>484</u>
23.	<u>483</u>
24.	<u>483</u>
25.	<u>483</u>
26.	<u>484</u>
27.	<u>484</u>
28.	<u>483</u>
29.	<u>---</u>
30.	<u>---</u>
31.	<u>---</u>

## INSTRUCTIONS

On this format, list the average daily unit power level in MWe-Net for each day in reporting month. Compute to the nearest whole megawatt.

# UNIT SHUTDOWN AND POWER REDUCTIONS

REPORT MONTH February, 1995

DOCKET NO. 50-244

UNIT NAME R.E. GINNA NUCLEAR POWER PLANT

DATE March 7, 1995

COMPLETED BY John V. Walden  
John V. Walden

TELEPHONE (315) 524-4446 Ext. 588

No.	Date	Type 1	Duration (Hours)	Reason 2	Method of Shutting Down Reactor 3	Licensee Event Report #	System Code 4	Component Code 5	Cause & Corrective Action to Prevent Recurrence
95-02	2/10/95	F	16.1	A	1	-----	--	----	Condenser Tube leaks caused a deviation in Steam Generator Secondary Chemistry. Power was reduced to 46% to allow condenser tube plugging.

1  
F: Forced  
S: Scheduled

2  
Reason:  
A-Equipment Failure (Explain)  
B-Maintenance or Test  
C-Refueling  
D-Regulatory Restriction  
E-Operator Training & License Examination  
F-Administrative  
G-Operational Error (Explain)  
H-Other (Explain)

3  
Method:  
1-Manual  
2-Manual Scram.  
3-Automatic Scram.  
4-Other (Explain)

4  
Exhibit G - Instructions for Preparation of Data Entry Sheets for Licensee Event Report (LER) File (NUREG-0161)

5  
Exhibit I - Same Source

NARRATIVE SUMMARY OF OPERATING EXPERIENCE

DOCKET NO: 50-244

UNIT: R.E. Ginna Nuclear Power Plant

DATE: March 7, 1995

COMPLETED BY: John Walden  
John Walden

TELEPHONE: (315) 524-4446 Ext. 588

MONTH February, 1995

During the month of February the average power was 98%. Power was reduced to 46% on February 10 to allow condenser water box isolation and tube plugging. The unit was restored to full power on February 11.