

CATEGORY 1

REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR: 9602130072 DOC. DATE: ~~96/01/31~~ NOTARIZED: NO DOCKET #
 FACIL: 50-244 Robert Emmet Ginna Nuclear Plant, Unit 1, Rochester G 05000244
 AUTH. NAME AUTHOR AFFILIATION
 WALDEN, J.V. Rochester Gas & Electric Corp.
 WIDAY, J.A. Rochester Gas & Electric Corp.
 RECIP. NAME RECIPIENT AFFILIATION

SUBJECT: Monthly operating rept for Jan 1996 for R.E. Ginna Nuclear
 Power Plant. W/960207 ltr. 4

DISTRIBUTION CODE: IE24D COPIES RECEIVED: LTR 1 ENCL 1 SIZE: 5
 TITLE: Monthly Operating Report (per Tech Specs)

NOTES: License Exp date in accordance with 10CFR2,2.109(9/19/72). 05000244

	RECIPIENT ID CODE/NAME	COPIES LTTR ENCL	RECIPIENT ID CODE/NAME	COPIES LTTR ENCL
	PD1-1 PD	1 1	JOHNSON, A	1 1
INTERNAL:	AEOD/SPD/RRAB	1 1	<u>FILE CENTER 01</u>	1 1
	NRR/DRPM/PECB	1 1	RGN1	1 1
EXTERNAL:	LITCO BRYCE, J H	1 1	NOAC	1 1
	NRC PDR	1 1		

C
A
T
E
G
O
R
Y

1

D
O
C
U
M
E
N
T


NOTE TO ALL "RIDS" RECIPIENTS:
 PLEASE HELP US TO REDUCE WASTE! CONTACT THE DOCUMENT CONTROL DESK,
 ROOM OWFN 5D-5 (EXT. 415-2083) TO ELIMINATE YOUR NAME FROM
 DISTRIBUTION LISTS FOR DOCUMENTS YOU DON'T NEED!

TOTAL NUMBER OF COPIES REQUIRED: LTTR 9 ENCL 9

MR



ROCHESTER GAS AND ELECTRIC CORPORATION • 89 EAST AVENUE, ROCHESTER, N.Y. 14649-0001



TELEPHONE
AREA CODE 716 546-2700

GINNA STATION

February 7, 1996

US Nuclear Regulatory Commission
Document Control Desk
Washington, DC 20555

Subject: Monthly Report for January, 1996
Operating Status Information
R. E. Ginna Nuclear Power Plant
Docket No. 50-244

Dear Sir:

Pursuant to our Technical Specification 6.9.1,
attached herewith is the monthly operating status report
for Ginna Station for the month of January, 1996.

Very truly yours,

Joseph A. Widay
Joseph A. Widay
Plant Manager

JAW:tjn

Attachments

c: Mr. Thomas T. Martin NRC (1)

130065

9602130072 960131
PDR ADDCK 05000244
R PDR

JE24

OPERATING DATA REPORT

-1-

50-244

February 7, 1996

COMPLETED BY:

John V. Walden

TELEPHONE (716) 771-3588

OPERATING STATUS

1. Unit Name: R.E. GINNA NUCLEAR POWER PLANT Notes:
2. Reporting Period: January, 1996
3. Licensed Thermal Power (MWt): 1520
4. Nameplate Rating (Gross MWe): 490
5. Design Electric Rating (Net MWe): 470
6. Maximum Dependable Capacity (Gross MWe): 490
7. Maximum Dependable Capacity (Net MWe): 470
8. If Changes Occur in Capacity Rating (Items Number 3 Through 7) Since Last Report, Give Reason:

9. Power Level to Which Restricted, If Any (Net MWe):

10. Reason For Restrictions, If Any:

	This Month	Yr.-to-Date	Cumulative**
11. Hours in Reported Period	<u>744.0</u>	<u>744.0</u>	<u>229512.0</u>
12. Number of hours Reactor Was Critical	<u>744.0</u>	<u>744.0</u>	<u>184411.1</u>
13. Reactor Reserve Shutdown Hours	<u>0.0</u>	<u>0.0</u>	<u>1687.6 *</u>
14. Hours Generator On-line	<u>744.0</u>	<u>744.0</u>	<u>181492.7</u>
15. Unit Reserve Shutdown Hours	<u>0.0</u>	<u>0.0</u>	<u>8.5 *</u>
16. Gross Thermal Energy Generated (MWH)	<u>1096191.0</u>	<u>1096191.0</u>	<u>257959499.0</u>
17. Gross Electrical Energy Generated (MWH)	<u>373104.0</u>	<u>373104.0</u>	<u>85435604.0</u>
18. Net Electrical Energy Generated (MWH)	<u>354741.0</u>	<u>354741.0</u>	<u>81102553.0</u>
19. Unit Service Factor (%)	<u>100.0</u>	<u>100.0</u>	<u>79.1</u>
20. Unit Availability Factor (%)	<u>100.0</u>	<u>100.0</u>	<u>79.1</u>
21. Unit Capacity Factor (using MDC Net) (%)	<u>101.4</u>	<u>101.4</u>	<u>76.3</u>
22. Unit Capacity Factor (using DER Net) (%)	<u>101.4</u>	<u>101.4</u>	<u>76.3</u>
23. Unit Forced Outage Rate (%)	<u>0.0</u>	<u>0.0</u>	<u>5.5</u>

24. Shutdowns Scheduled Over Next 6 Months (Type, Date and Duration of Each):

Refueling and Maintenance, Start 4/01/96, Duration 62 days

25. If Shutdown At End of Report Period, Estimate Date of Startup:

26. Units in Test Status (Prior to Commercial Operation):

Forecast

Achieved

INITIAL CRITICALITY

INITIAL ELECTRICITY

COMMERCIAL OPERATION

* CUMULATIVE TOTAL COMMENCING JANUARY 1, 1975

** CUMULATIVE TOTAL COMMENCING NOVEMBER 8, 1969

AVERAGE DAILY UNIT POWER LEVEL

DOCKET NO: 50-244UNIT: R.E. Ginna Nuclear Power PlantDATE: February 7, 1996COMPLETED BY: John Walden

John Walden

TELEPHONE: (716) 771-3588MONTH January, 1996DAY AVERAGE DAILY POWER LEVEL
(MWe-Net)

1.	<u>477</u>
2.	<u>476</u>
3.	<u>476</u>
4.	<u>476</u>
5.	<u>476</u>
6.	<u>476</u>
7.	<u>476</u>
8.	<u>476</u>
9.	<u>476</u>
10.	<u>476</u>
11.	<u>476</u>
12.	<u>476</u>
13.	<u>476</u>
14.	<u>476</u>
15.	<u>476</u>
16.	<u>476</u>

DAY AVERAGE DAILY POWER LEVEL
(MWe-Net)

17.	<u>477</u>
18.	<u>477</u>
19.	<u>477</u>
20.	<u>477</u>
21.	<u>477</u>
22.	<u>477</u>
23.	<u>477</u>
24.	<u>477</u>
25.	<u>477</u>
26.	<u>476</u>
27.	<u>477</u>
28.	<u>476</u>
29.	<u>476</u>
30.	<u>476</u>
31.	<u>476</u>

INSTRUCTIONS

On this format, list the average daily unit power level in MWe-Net for each day in reporting month. Compute to the nearest whole megawatt.

UNIT SHUTDOWN AND POWER REDUCTIONS

REPORT MONTH January, 1996

DOCKET NO. 50-244
 UNIT NAME R.E. GINNA NUCLEAR POWER PLANT
 DATE February 7, 1996
 COMPLETED BY John V. Walden
 TELEPHONE (716) 771-3588

No.	Date	Type 1	Duration (Hours)	Reason 2	Method of Shutting Down Reactor 3	Licensee Event Report #	System Code 4	Component Code 5	Cause & Corrective Action to Prevent Recurrence
---	-----	--	---	---	---	-----	---	---	-----

1
 F: Forced
 S: Scheduled

2
 Reason:
 A-Equipment Failure (Explain)
 B-Maintenance or Test
 C-Refueling
 D-Regulatory Restriction
 E-Operator Training & License Examination
 F-Administrative
 G-Operational Error (Explain)
 H-Other (Explain)

3
 Method:
 1-Manual
 2-Manual Scram.
 3-Automatic Scram.
 4-Other (Explain)

4
 Exhibit G - Instructions
 for Preparation of Data
 Entry Sheets for Licensee
 Event Report (LER) File (NUREG-
 0161)

5
 Exhibit 1 - Same Source

NARRATIVE SUMMARY OF OPERATING EXPERIENCE

DOCKET NO: 50-244

UNIT: R.E. Ginna Nuclear Power Plant

DATE: February 7, 1996

COMPLETED BY: John Walden
John Walden

TELEPHONE: (716) 771-3588

MONTH January, 1996

Average power for the month was 97%.