

Attachment B

Marked-up Current Ginna Station Technical Specification

Included page:

3.3-27

9602130474 960209
PDR ADOCK 05000244
P PDR

Table 3.3.2-1 (page 3 of 3)
Engineered Safety Feature Actuation System Instrumentation

FUNCTION	APPLICABLE MODES OR OTHER SPECIFIED CONDITIONS	REQUIRED CHANNELS	CONDITIONS	SURVEILLANCE REQUIREMENTS	ALLOWABLE VALUE	TRIP SETPOINT
5. Feedwater Isolation						
a. Automatic Actuation Logic and Actuation Relays	1,2 ^(c) ,3 ^(c)	2 trains	E,G	SR 3.3.2.7	NA	NA
b. SG Water Level -High	1,2 ^(c) ,3 ^(c)	3 per SG	F,G	SR 3.3.2.1 SR 3.3.2.2 SR 3.3.2.5	94% ≤ 68%	85% ≤ 67%
c. Safety Injection	Refer to Function 1 (Safety Injection) for all initiation functions and requirements.					
6. Auxiliary Feedwater (AFW)*						
a. Manual Initiation						
AFW	1,2,3	1 per pump	N	SR 3.3.2.4	NA	NA
Standby AFW	1,2,3	1 per pump	N	SR 3.3.2.4	NA	NA
b. Automatic Actuation Logic and Actuation Relays	1,2,3	2 trains	E,G	SR 3.3.2.7	NA	NA
c. SG Water Level -Low Low	1,2,3	3 per SG	D,G	SR 3.3.2.1 SR 3.3.2.2 SR 3.3.2.5	≥ 16%	≥ 17%
d. Safety Injection (Motor driven pumps only)	Refer to Function 1 (Safety Injection) for all initiation functions and requirements.					
e. Undervoltage -Bus 11A and 11B (Turbine driven pump only)	1,2,3	2 per bus	D,G	SR 3.3.2.3 SR 3.3.2.5	≥ 2450 V with ≤ 3.6 sec time delay	≥ 2579 V with ≤ 3.6 sec time delay
f. Trip of Both Main Feedwater Pumps (Motor driven pumps only)	1,2	2 per MFW pump	B,C	SR 3.3.2.4	NA	NA

(c) Except when all Main Feedwater Regulating and associated bypass valves are closed and de-activated or isolated by a closed manual valve.

Attachment C

Proposed Ginna Station Technical Specification

Table 3.3.2-1 (page 3 of 3)
Engineered Safety Feature Actuation System Instrumentation

FUNCTION	APPLICABLE MODES OR OTHER SPECIFIED CONDITIONS	REQUIRED CHANNELS	CONDITIONS	SURVEILLANCE REQUIREMENTS	ALLOWABLE VALUE	TRIP SETPOINT
5. Feedwater Isolation						
a. Automatic Actuation Logic and Actuation Relays	1,2 ^(c) ,3 ^(c)	2 trains	E,G	SR 3.3.2.7	NA	NA
b. SG Water Level -High	1,2 ^(c) ,3 ^(c)	3 per SG	F,G	SR 3.3.2.1 SR 3.3.2.2 SR 3.3.2.5	≤ 94%	≤ 85%
c. Safety Injection	Refer to Function 1 (Safety Injection) for all initiation functions and requirements.					
6. Auxiliary Feedwater (AFW)						
a. Manual Initiation						
AFW	1,2,3	1 per pump	N	SR 3.3.2.4	NA	NA
Standby AFW	1,2,3	1 per pump	N	SR 3.3.2.4	NA	NA
b. Automatic Actuation Logic and Actuation Relays	1,2,3	2 trains	E,G	SR 3.3.2.7	NA	NA
c. SG Water Level -Low Low	1,2,3	3 per SG	D,G	SR 3.3.2.1 SR 3.3.2.2 SR 3.3.2.5	≥ 16%	≥ 17%
d. Safety Injection (Motor driven pumps only)	Refer to Function 1 (Safety Injection) for all initiation functions and requirements.					
e. Undervoltage -Bus 11A and 11B (Turbine driven pump only)	1,2,3	2 per bus	D,G	SR 3.3.2.3 SR 3.3.2.5	≥ 2450 V with ≤ 3.6 sec time delay	≥ 2579 V with ≤ 3.6 sec time delay
f. Trip of Both Main Feedwater Pumps (Motor driven pumps only)	1,2	2 per MFW pump	B,C	SR 3.3.2.4	NA	NA

(c) Except when all Main Feedwater Regulating and associated bypass valves are closed and de-activated or isolated by a closed manual valve.