

# CATEGORY 1

## REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR: 9605140277      DOC. DATE: ~~96/04/30~~ NOTARIZED: NO      DOCKET #  
 FACIL: 50-244 Robert Emmet Ginna Nuclear Plant, Unit 1, Rochester G      05000244  
 AUTH. NAME      AUTHOR AFFILIATION  
 WALDEN, J.V.      Rochester Gas & Electric Corp.  
 WIDAY, J.A.      Rochester Gas & Electric Corp.  
 RECIP. NAME      RECIPIENT AFFILIATION

SUBJECT: Monthly operating ~~rept~~ for Apr 1996 for RE Ginna Nuclear Power Plant. W/960507 ltr.

DISTRIBUTION CODE: IE24D    COPIES RECEIVED: LTR 1 ENCL 1 SIZE: 5  
 TITLE: Monthly Operating Report (per Tech Specs)

NOTES: License Exp date in accordance with 10CFR2,2.109(9/19/72).      05000244

	RECIPIENT ID CODE/NAME	COPIES LTTR ENCL	RECIPIENT ID CODE/NAME	COPIES LTTR ENCL
	PD1-1 PD	1 1	VISSING, G.	1 1
INTERNAL:	AEOD/SPD/RRAB	1 1	<u>FILE CENTER OP</u>	1 1
	NRR/DRPM/PECB	1 1	RGNI	1 1
EXTERNAL:	LITCO BRYCE, J H	1 1	NOAC	1 1
	NRC PDR	1 1		

C  
A  
T  
E  
G  
O  
R  
Y  
  
1  
  
D  
O  
C  
U  
M  
E  
N  
T

NOTE TO ALL "RIDS" RECIPIENTS:  
 PLEASE HELP US TO REDUCE WASTE! CONTACT THE DOCUMENT CONTROL DESK,  
 ROOM OWFN 5D-5 (EXT. 415-2083) TO ELIMINATE YOUR NAME FROM  
 DISTRIBUTION LISTS FOR DOCUMENTS YOU DON'T NEED!

TOTAL NUMBER OF COPIES REQUIRED: LTTR 9 ENCL 9





ROCHESTER GAS AND ELECTRIC CORPORATION • 89 EAST AVENUE, ROCHESTER, N.Y. 14649-0001



TELEPHONE  
AREA CODE 716 546-2700

GINNA STATION

May 7, 1996

US Nuclear Regulatory Commission  
Document Control Desk  
Washington, DC 20555

Subject: Monthly Report for April, 1996  
Operating Status Information  
R.E. Ginna Nuclear Power Plant  
Docket No. 50-244

Dear Sir:

Pursuant to our Technical Specification 6.9.1, attached herewith is the monthly operating status report for Ginna Station for the month of April 1996.

Very truly yours,

*Joseph A. Widay*  
Joseph A. Widay  
Plant Manager

JAW:tjn

Attachments

c: Mr. Thomas T. Martin NRC (1)

9605140277 960430  
PDR ADOCK 05000244  
R PDR

140136

*IF24*  
11



# OPERATING DATA REPORT

-1-

50-244

May 7, 1996

COMPLETED BY:

*John V. Walden*

John V. Walden

TELEPHONE (716) 771-3588

## OPERATING STATUS

1. Unit Name: R.E. GINNA NUCLEAR POWER PLANT Notes:
2. Reporting Period: April, 1996
3. Licensed Thermal Power (MWt): 1520
4. Nameplate Rating (Gross MWe): 517
5. Design Electric Rating (Net MWe): 470
6. Maximum Dependable Capacity (Gross MWe): 490
7. Maximum Dependable Capacity (Net MWe): 470
8. If Changes Occur in Capacity Rating (Items Number 3 Through 7) Since Last Report, Give Reason:

9. Power Level to Which Restricted, If Any (Net MWe):

10. Reason For Restrictions, If Any:

	This Month	Yr.-to-Date	Cumulative**
11. Hours in Reported Period	<u>719.0</u>	<u>2903.0</u>	<u>231671.0</u>
12. Number of hours Reactor Was Critical	<u>6.8</u>	<u>2109.3</u>	<u>185776.4</u>
13. Reactor Reserve Shutdown Hours	<u>0.0</u>	<u>0.0</u>	<u>1687.6 *</u>
14. Hours Generator On-line	<u>6.3</u>	<u>2106.1</u>	<u>182854.8</u>
15. Unit Reserve Shutdown Hours	<u>0.0</u>	<u>0.0</u>	<u>8.5 *</u>
16. Gross Thermal Energy Generated (MWH)	<u>4135.0</u>	<u>3072934.0</u>	<u>259936242.0</u>
17. Gross Electrical Energy Generated (MWH)	<u>1416.0</u>	<u>1045592.0</u>	<u>86108092.0</u>
18. Net Electrical Energy Generated (MWH)	<u>1285.0</u>	<u>994041.0</u>	<u>81741853.0</u>
19. Unit Service Factor (%)	<u>0.9</u>	<u>72.5</u>	<u>78.9</u>
20. Unit Availability Factor (%)	<u>0.9</u>	<u>72.5</u>	<u>78.9</u>
21. Unit Capacity Factor (using MDC Net) (%)	<u>0.4</u>	<u>72.9</u>	<u>76.1</u>
22. Unit Capacity Factor (using DER Net) (%)	<u>0.4</u>	<u>72.9</u>	<u>76.1</u>
23. Unit Forced Outage Rate (%)	<u>0.0 ***</u>	<u>3.8</u>	<u>5.5</u>

24. Shutdowns Scheduled Over Next 6 Months (Type, Date and Duration of Each):

Refueling and Maintenance, Start 4/01/96, Scheduled Duration 62 days

25. If Shutdown At End of Report Period, Estimate Date of Startup:

26. Units In Test Status (Prior to Commercial Operation):

Forecast

Achieved

INITIAL CRITICALITY

INITIAL ELECTRICITY

COMMERCIAL OPERATION

\* CUMULATIVE TOTAL COMMENCING JANUARY 1, 1975

\*\* CUMULATIVE TOTAL COMMENCING NOVEMBER 8, 1969

\*\*\* UNIT IN REFUELING SHUTDOWN

AVERAGE DAILY UNIT POWER LEVEL

DOCKET NO: 50-244

UNIT: R.E. Ginna Nuclear Power Plant

DATE: May 7, 1996

COMPLETED BY: John Walden

TELEPHONE: (716) 771-3588

MONTH April, 1996

DAY AVERAGE DAILY POWER LEVEL  
(MWe-Net)

1.	<u>50</u>
2.	<u>-11</u>
3.	<u>-6</u>
4.	<u>-4</u>
5.	<u>-4</u>
6.	<u>-4</u>
7.	<u>-3</u>
8.	<u>-3</u>
9.	<u>-2</u>
10.	<u>-2</u>
11.	<u>-2</u>
12.	<u>-2</u>
13.	<u>-2</u>
14.	<u>-2</u>
15.	<u>-2</u>
16.	<u>-3</u>

DAY AVERAGE DAILY POWER LEVEL  
(MWe-Net)

17.	<u>-2</u>
18.	<u>-2</u>
19.	<u>-2</u>
20.	<u>-2</u>
21.	<u>-2</u>
22.	<u>-1</u>
23.	<u>-1</u>
24.	<u>-1</u>
25.	<u>-1</u>
26.	<u>-1</u>
27.	<u>-1</u>
28.	<u>-1</u>
29.	<u>-1</u>
30.	<u>-1</u>
31.	<u>---</u>

INSTRUCTIONS

On this format, list the average daily unit power level in MWe-Net for each day in reporting month. Compute to the nearest whole megawatt.

# UNIT SHUTDOWN AND POWER REDUCTIONS

REPORT MONTH April, 1996

DOCKET NO. 50-244  
 UNIT NAME: R.E. GINNA NUCLEAR POWER PLANT  
 DATE May 7, 1996  
 COMPLETED BY: John V. Walden  
 TELEPHONE: (716) 771-3588

No.	Date	Type 1	Duration (Hours)	Reason 2	Method of Shutting Down Reactor 3	Licensee Event Report #	System Code 4	Component Code 5	Cause & Corrective Action to Prevent Recurrence
2	4/1/96	S	712.7	C	1	-----	---	----	Scheduled shut down for refueling and maintenance.

1  
 F: Forced  
 S: Scheduled

2  
 Reason:  
 A-Equipment Failure (Explain)  
 B-Maintenance or Test  
 C-Refueling  
 D-Regulatory Restriction  
 E-Operator Training & License Examination  
 F-Administrative  
 G-Operational Error (Explain)  
 H-Other (Explain)

3  
 Method:  
 1-Manual  
 2-Manual Scram.  
 3-Automatic Scram.  
 4-Other (Explain)

4  
 Exhibit G - Instructions for Preparation of Data Entry Sheets for Licensee Event Report (LER) File (NUREG-0161)

5  
 Exhibit I - Same Source

NARRATIVE SUMMARY OF OPERATING EXPERIENCE

DOCKET NO: 50-244

UNIT: R.E. Ginna Nuclear Power Plant

DATE: May 7, 1996

COMPLETED BY: John Walden  
John Walden

TELEPHONE: (716) 771-3588

MONTH April, 1996

The unit was shutdown on April 1, 1996 for refueling and Steam Generator Replacement. A full core off load to the spent fuel pool was performed during the first week of the outage. The containment dome was opened to allow access to the Steam Generators. The old Steam Generators were removed intact following cutting of Reactor Coolant System, Main Steam, and Feedwater piping. New Steam Generators have been lowered into position and reattachment to piping systems is in progress. Closure of containment is also in progress.