

CATEGORY 1

REGULATOR INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR: 9606060147 DOC. DATE: 96/06/03 NOTARIZED: YES DOCKET #
 FACIL: 50-244 Robert Emmet Ginna Nuclear Plant, Unit 1, Rochester G 05000244
 AUTH. NAME AUTHOR AFFILIATION
 MERCREDY, R.C. Rochester Gas & Electric Corp.
 RECIP. NAME RECIPIENT AFFILIATION
 VISSING, G.S.

SUBJECT: Forwards update to correction of typographical errors
 request for application for amend to DPR-18.

DISTRIBUTION CODE: A001D COPIES RECEIVED: LTR 1 ENCL 1 SIZE: 3+6
 TITLE: OR Submittal: General Distribution

NOTES: License Exp date in accordance with 10CFR2,2.109(9/19/72). 05000244

RECIPIENT ID CODE/NAME	COPIES LTTR ENCL	RECIPIENT ID CODE/NAME	COPIES LTTR ENCL
PD1-1 LA	1 1	PD1-1 PD	1 1
VISSING, G.	1 1		
INTERNAL: FILE CENTER 001	1 1	NRR/DE/EMCB	1 1
NRR/DRCH/HICB	1 1	NRR/DSSA/SPLB	1 1
NRR/DSSA/SRXB	1 1	NUDOCS-ABSTRACT	1 1
OGC/HDS3	1 0		
EXTERNAL: NOAC	1 1	NRC PDR	1 1

C
A
T
E
G
O
R
Y

1

D
O
C
U
M
E
N
T

NOTE TO ALL "RIDS" RECIPIENTS:
 PLEASE HELP US TO REDUCE WASTE! CONTACT THE DOCUMENT CONTROL DESK,
 ROOM OWFN 5D-5(EXT. 415-2083) TO ELIMINATE YOUR NAME FROM
 DISTRIBUTION LISTS FOR DOCUMENTS YOU DON'T NEED!

TOTAL NUMBER OF COPIES REQUIRED: LTTR 12 ENCL 11



ROCHESTER GAS AND ELECTRIC CORPORATION • 89 EAST AVENUE, ROCHESTER, N.Y. 14649-0001



AREA CODE 716 546-2700

ROBERT C. MECREDY
Vice President
Nuclear Operations

June 3, 1996

U.S. Nuclear Regulatory Commission
Document Control Desk
Attn: Guy S. Vissing
Project Directorate I-1
Washington, D.C. 20555

Subject: Application for Amendment to Facility Operating License
Update to Correction of Typographical Errors Request
Rochester Gas & Electric Corporation
R.E. Ginna Nuclear Power Plant
Docket No. 50-244

- References:
- (a) Letter from R.C. Mecredy, RG&E, to G.S. Vissing, NRC, Subject: *Application for Amendment to Facility Operating License, Correction of Typographical Errors*, dated May 8, 1996.
 - (b) Letter from R.C. Mecredy, RG&E, to G.S. Vissing, NRC, Subject: *Application for Amendment to Facility Operating License, Correction of Typographical Errors, Request for Exigent Consideration*, dated May 10, 1996.
 - (c) Letter from R.C. Mecredy, RG&E, to G.S. Vissing, NRC, Subject: *Application for Amendment to Facility Operating License, Update to Correction of Typographical Errors*, dated May 29, 1996.

Dear Mr. Vissing,

By Reference (a), RG&E submitted a license amendment request (LAR) to correct several typographical errors within the Ginna Station Improved Technical Specifications (ITS). Subsequently, RG&E requested that this LAR be considered on an exigent basis due to the potential to delay a planned startup (Reference (b)). However, the NRC Staff has requested additional information as to why the LAR should be considered on an exigent basis. This information is provided below.

9606060147 960603
PDR ADOCK 05000244
P PDR

A001
11



00000000

The majority of changes documented in Attachment A to Reference (a) (and as updated in Reference (c)), are minor editorial corrections which are readily apparent to operators if they were in the applicable LCO. That is, these errors would not be expected to cause significant operator confusion but are errors which must be corrected. However, changes 3.ii.b and 3.ii.c as documented in Attachment A, Section B are more serious. These two changes relate to the equations for Overtemperature ΔT and Overpower ΔT and are discussed in detail below.

Change 3.ii.b corrects an inequality sign with respect to defining $f(\Delta I)$ for both the Overtemperature ΔT and Overpower ΔT equations. This is significant since the value used for $f(\Delta I)$ in both equations is treated as a penalty (i.e., depending on the degree of power tilt within the core, $f(\Delta I)$ may be either "0" or some value by which the Overtemperature ΔT and Overpower ΔT setpoints must be reduced to ensure that the plant remains bounded by the accident analysis). Without this correction, the equations have no specified value which should be used for $f(\Delta I)$ when the difference in power between the top and bottom halves of the reactor core is $\leq 13\%$ RTP. Meanwhile, there are two different values which are to be used when the power difference between the top and bottom halves of the reactor core is $> 13\%$ RTP. This conflict would be confusing to operators and creates two equations in which a specific input is not defined for one instance and is defined twice in another instance.


Change 3.ii.c adds units to the equations for Overtemperature ΔT and Overpower ΔT and corrects an error in the Overpower ΔT equation with respect to constant K_s . The correction of constant K_s is significant since the current Overpower ΔT equation essentially has no defined value to be used for this constant. This is due to the fact that K_s is supposed to have two values, one for when measured RCS average temperature is less than nominal T_{avg} and one for when measured RCS average temperature is \geq nominal T_{avg} . In the current technical specifications, values for when K_s is less than " T^2 " and when K_s is \geq than " T^2 " are specified. However, " T^2 " is not defined anywhere in the current specifications since it is a typographical error which should be " T ." Again, this would be confusing to operators and creates an equation in which a specific input is not defined.

Both the Overtemperature ΔT and Overpower ΔT equations are required to be used during MODES 1 and 2 per LCO 3.3.1. The proposed corrections makes both the Overtemperature ΔT and Overpower ΔT equations consistent with those equations used prior to implementation of the ITS. Failure to approve this LAR prior to entry into MODE 2 following the current refueling outage would prevent a planned startup due to editorial and typographical errors only since it would not be possible to operate with the technical specifications for these equations. Therefore, RG&E contends that the LAR meets the criteria for exigent consideration per 10 CFR 50.91.



In addition, RG&E has noticed an error in the revised Attachment II and III submitted by Reference (c). This error is the removal of "RTP" from the end of the two lines which define $f(\Delta I)$ in the Overtemperature ΔT and Overpower ΔT equations. The current equations have this "RTP" and it was RG&E's intent to retain this text. The "RTP" was inadvertently removed following a conference call with the NRC on May 28, 1996 and not added back in following a conference call on May 29, 1996. As such, please find attached copies of the properly revised Attachments II and III. No other pages of Reference (c) are affected.

Very truly yours,



Robert C. Mecredy

Subscribed and sworn to before me
on this 3rd day of June 1996.


Notary Public

JOANNE S. GORMAN
Notary Public in the State of New York
Orleans County
Commission Expires Nov. 18 1996

MDF\857
Attachments

xc: U.S. Nuclear Regulatory Commission
Mr. Guy Vissing (Mail Stop 14C7)
PWR Project Directorate I-1
Washington, D.C. 20555

U.S. Nuclear Regulatory Commission
Region I
475 Allendale Road
King of Prussia, PA 19406

Ginna Senior Resident Inspector

Mr. F. William Valentine, President
New York State Energy, Research, and Development Authority
2 Rockefeller Plaza
Albany, NY 12223-1253

JOANNE S. GORMAN
Notary Public in the State of New York
Queens County
Commission Expires Nov. 19