

CATEGORY 1

REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR: 9610310096 DOC. DATE: 96/10/29 NOTARIZED: YES DOCKET #
 FACIL: 50-244 Robert Emmet Ginna Nuclear Plant, Unit 1, Rochester G 05000244
 AUTH. NAME AUTHOR AFFILIATION
 MECREDY, R.C. Rochester Gas & Electric Corp.
 RECIP. NAME RECIPIENT AFFILIATION
 Document Control Branch (Document Control Desk)

SUBJECT: Forwards application for amends to licenses DPR-18,
 requesting change to required actions of inoperable channels
 associated with feedwater pump.

DISTRIBUTION CODE: A001D COPIES RECEIVED: LTR 1 ENCL 1 SIZE: 2 + 15
 TITLE: OR Submittal: General Distribution

NOTES: License Exp date in accordance with 10CFR2,2.109(9/19/72). 05000244

RECIPIENT ID CODE/NAME	COPIES LTTR ENCL	RECIPIENT ID CODE/NAME	COPIES LTTR ENCL
PD1-1 LA	1 1	PD1-1 PD	1 1
VISSING, G.	1 1		
INTERNAL: FILE CENTER-01	1 1	NRR/DE/EMCB	1 1
NRR/DRCH/HICB	1 1	NRR/DSSA/SPLB	1 1
NRR/DSSA/SRXB	1 1	NUDOCS-ABSTRACT	1 1
OGC/HDS3	1 0		
EXTERNAL: NOAC	1 1	NRC PDR	1 1

C
A
T
E
G
O
R
Y

1

D
O
C
U
M
E
N
T

NOTE TO ALL "RIDS" RECIPIENTS:
 PLEASE HELP US TO REDUCE WASTE. TO HAVE YOUR NAME OR ORGANIZATION REMOVED FROM DISTRIBUTION LISTS
 OR REDUCE THE NUMBER OF COPIES RECEIVED BY YOU OR YOUR ORGANIZATION, CONTACT THE DOCUMENT CONTROL
 DESK (DCD) ON EXTENSION 415-2083

TOTAL NUMBER OF COPIES REQUIRED: LTTR 12 ENCL 11

1980

1980

1980



ROCHESTER GAS AND ELECTRIC CORPORATION • 89 EAST AVENUE, ROCHESTER, N.Y. 14649-0001



AREA CODE 716 546-2700

ROBERT C. MECREDY
Vice President
Nuclear Operations

October 29, 1996

U.S. Nuclear Regulatory Commission
Document Control Desk
Attn: Guy S. Vissing
Project Directorate I-1
Washington, D.C. 20555


Subject: Application for Amendment to Facility Operating License, Change to Required Actions for Inoperable Channels Associated With Auxiliary Feedwater Pump Actuation on Steam Generator Level - Low Low
Rochester Gas & Electric Corporation
R.E. Ginna Nuclear Power Plant
Docket No. 50-244

References: (a) Letter from A.R. Johnson, NRC, to R.C. Mecredy, RG&E, *Issuance of Amendment No. 61 to Facility Operating License No. DPR-18, R.E. Ginna Nuclear Power Plant*, dated February 13, 1996.

Dear Mr. Vissing,

By Reference (a), the NRC issued the Improved Technical Specifications (ITS) for Ginna Station. Following implementation of the ITS, RG&E discovered an error with respect to Table 3.3.2-1, Function 6.c which references the incorrect Required Action for inoperable channels of the auxiliary feedwater pump actuation on Steam Generator Level - Low Low logic. The current Required Action is to restore the inoperable channel within 48 hours or initiate a plant shutdown to Mode 4. The correct Required Action is to place the inoperable channel in "trip" within 6 hours or initiate a plant shutdown to Mode 4. The inoperable channel can then remain in trip indefinitely. As such, the purpose of this license amendment request (LAR) is to revise the specified required actions to be consistent with NUREG-1431 (which was the basis for Amendment No. 61). RG&E requests that upon NRC approval, this LAR should be effective immediately and implemented within 30 days.

Very truly yours,


Robert C. Mecredy

MDF\883
Attachments

9610310096 961029
PDR ADDCK 05000244
P PDR

7001
11

xc: U.S. Nuclear Regulatory Commission
Mr. Guy S. Vissing (Mail Stop 14C7)
PWR Project Directorate I-1
Washington, D.C. 20555

U.S. Nuclear Regulatory Commission
Region I
475 Allendale Road
King of Prussia, PA 19406

Ginna Senior Resident Inspector

Mr. F. William Valentine, President
New York State Energy, Research, and Development Authority
2 Rockefeller Plaza
Albany, NY 12223-1253