

CATEGORY 1

REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR: 9701140299 DOC. DATE: 96/12/31 NOTARIZED: NO DOCKET #
 FACIL: 50-244 Robert Emmet Ginna Nuclear Plant, Unit 1, Rochester G 05000244
 AUTH. NAME AUTHOR AFFILIATION
 WALDEN, J.V. Rochester Gas & Electric Corp.
 WIDAY, J.A. Rochester Gas & Electric Corp.
 RECIP. NAME RECIPIENT AFFILIATION

SUBJECT: Monthly operating rept for Dec 1996 for R.E. Ginna Nuclear Power Plant. W/970108 ltr.

DISTRIBUTION CODE: IE24D COPIES RECEIVED: LTR 1 ENCL 1 SIZE: 5
 TITLE: Monthly Operating Report (per Tech Specs)

NOTES: License Exp date in accordance with 10CFR2,2.109(9/19/72). 05000244

| | RECIPIENT ID CODE/NAME | COPIES LTTR ENCL | RECIPIENT ID CODE/NAME | COPIES LTTR ENCL |
|-----------|---------------------------|---------------------|---------------------------|---------------------|
| | PD1-1 PD | 1 1 | VISSING, G. | 1 1 |
| INTERNAL: | AEOD/SPD/RRAB | 1 1 | <u>ETLE CENTER</u> 01 | 1 1 |
| | NRR/DRPM/PECB | 1 1 | OC/DBA/PAD | 1 1 |
| | RGN1 | 1 1 | | |
| EXTERNAL: | LITCO BRYCE, J H | 1 1 | NOAC | 1 1 |
| | NRC PDR | 1 1 | | |

C
A
T
E
G
O
R
Y

1

D
O
C
U
M
E
N
T

NOTE TO ALL "RIDS" RECIPIENTS:
 PLEASE HELP US TO REDUCE WASTE! CONTACT THE DOCUMENT CONTROL DESK,
 ROOM OWFN 5D-5 (EXT. 415-2083) TO ELIMINATE YOUR NAME FROM
 DISTRIBUTION LISTS FOR DOCUMENTS YOU DON'T NEED!

TOTAL NUMBER OF COPIES REQUIRED: LTTR 10 ENCL 10

MRE



ROCHESTER GAS AND ELECTRIC CORPORATION • 89 EAST AVENUE, ROCHESTER, N.Y. 14649-0001



TELEPHONE
AREA CODE 716 546-2700

January 8, 1997

US Nuclear Regulatory Commission
Document Control Desk
Attn: Guy S. Vissing
Project Directorate I-1
Washington, DC 20555

Subject: Monthly Report for December, 1996
Operating Status Information
R.E. Ginna Nuclear Power Plant
Docket No. 50-244

Dear Mr. Vissing:

Pursuant to Ginna Improved Technical Specifications Section 5.6.4, attached is the monthly operating status report for Ginna Station for the month of December, 1996.

Very truly yours,

Joseph A. Widay
Joseph A. Widay
Plant Manager

xc: U.S. Nuclear Regulatory Commission
Mr. Guy S. Vissing (Mail Stop 14C7)
Project Directorate I-1
Washington, D.C. 20555

U.S. Nuclear Regulatory Commission
Region I
475 Allendale Road
King of Prussia, PA 19406

U.S. NRC Ginna Senior Resident Inspector

Attachments

9701140299 761231
PDR ADOCK 05000244
R PDR

140109

11/14
1224

OPERATING DATA REPORT

-1-

50-244

January 8, 1997

COMPLETED BY:

John V. Walden

TELEPHONE (716) 771-3588

OPERATING STATUS

1. Unit Name: R.E. GINNA NUCLEAR POWER PLANT Notes:
2. Reporting Period: December, 1996
3. Licensed Thermal Power (MWt): 1520
4. Nameplate Rating (Gross MWe): 517
5. Design Electric Rating (Net MWe): 470
6. Maximum Dependable Capacity (Gross MWe): 490
7. Maximum Dependable Capacity (Net MWe): 470
8. If Changes Occur In Capacity Rating (Items Number 3 Through 7) Since Last Report, Give Reason:

9. Power Level to Which Restricted, If Any (Net MWe):

10. Reason For Restrictions, If Any:

| | This Month | Yr.-to-Date | Cumulative** |
|--|------------|-------------|--------------|
| 11. Hours in Reported Period | 744.0 | 8784.0 | 237552.0 |
| 12. Number of hours Reactor Was Critical | 744.0 | 6247.2 | 189914.3 |
| 13. Reactor Reserve Shutdown Hours | 0.0 | 0.0 | 1687.6 * |
| 14. Hours Generator On-line | 744.0 | 6177.8 | 186926.5 |
| 15. Unit Reserve Shutdown Hours | 0.0 | 0.0 | 8.5 * |
| 16. Gross Thermal Energy Generated (MWH) | 1129271.0 | 9012962.0 | 265876270.0 |
| 17. Gross Electrical Energy Generated (MWH) | 386399.0 | 3047809.0 | 88110309.0 |
| 18. Net Electrical Energy Generated (MWH) | 368215.0 | 2898054.8 | 83645866.8 |
| 19. Unit Service Factor (%) | 100.0 | 70.3 | 78.7 |
| 20. Unit Availability Factor (%) | 100.0 | 70.3 | 78.7 |
| 21. Unit Capacity Factor (using MDC Net) (%) | 105.3 | 70.2 | 75.9 |
| 22. Unit Capacity Factor (using DER Net) (%) | 105.3 | 70.2 | 75.9 |
| 23. Unit Forced Outage Rate (%) | 0.0 | 13.0 | 5.8 |

24. Shutdowns Scheduled Over Next 6 Months (Type, Date and Duration of Each):

25. If Shutdown At End of Report Period, Estimate Date of Startup:

26. Units in Test Status (Prior to Commercial Operation):

Forecast

Achieved

INITIAL CRITICALITY

INITIAL ELECTRICITY

COMMERCIAL OPERATION

* CUMULATIVE TOTAL COMMENCING JANUARY 1, 1975

** CUMULATIVE TOTAL COMMENCING NOVEMBER 8, 1969

AVERAGE DAILY UNIT POWER LEVEL

DOCKET NO: 50-244

UNIT: R.E. Ginna Nuclear Power Plant

DATE: January 8, 1997

COMPLETED BY: John Walden
John Walden

TELEPHONE: (716) 771-3588

MONTH December, 1996

DAY AVERAGE DAILY POWER LEVEL
(MWe-Net)

| | |
|-----|------------|
| 1. | <u>495</u> |
| 2. | <u>494</u> |
| 3. | <u>495</u> |
| 4. | <u>495</u> |
| 5. | <u>495</u> |
| 6. | <u>495</u> |
| 7. | <u>495</u> |
| 8. | <u>495</u> |
| 9. | <u>495</u> |
| 10. | <u>494</u> |
| 11. | <u>494</u> |
| 12. | <u>495</u> |
| 13. | <u>495</u> |
| 14. | <u>496</u> |
| 15. | <u>496</u> |
| 16. | <u>495</u> |

DAY AVERAGE DAILY POWER LEVEL
(MWe-Net)

| | |
|-----|------------|
| 17. | <u>495</u> |
| 18. | <u>495</u> |
| 19. | <u>495</u> |
| 20. | <u>495</u> |
| 21. | <u>495</u> |
| 22. | <u>495</u> |
| 23. | <u>496</u> |
| 24. | <u>496</u> |
| 25. | <u>496</u> |
| 26. | <u>496</u> |
| 27. | <u>496</u> |
| 28. | <u>496</u> |
| 29. | <u>496</u> |
| 30. | <u>496</u> |
| 31. | <u>496</u> |

INSTRUCTIONS

On this format, list the average daily unit power level in MWe-Net for each day in reporting month. Compute to the nearest whole megawatt.

DOCKET NO: 50-244
 UNIT: R.E. GINNA NUCLEAR POWER PLANT
 DATE: January 8, 1997
 COMPLETED BY: John Walden
 John Walden
 TELEPHONE: (716) 771-3588

UNIT SHUTDOWN AND POWER REDUCTIONS

REPORT MONTH December, 1996

| No. | Date | Type ¹ | Duration (hours) | Reason ² | Method of shuting down reactors ³ | Licensee Event Report # | System Code ⁴ | Component Code ⁵ | Cause & Corrective Action to Prevent Recurrence |
|-----|------|-------------------|---------------------|---------------------|--|-------------------------------|-----------------------------|--------------------------------|--|
| --- | --- | --- | --- | --- | --- | --- | --- | --- | --- |

¹
 F: Forced
 S: Scheduled

²
 Reason:
 A-Equipment (Explain)
 B-Maintenance or Test
 C-Refueling
 D-Regulatory
 E-Operator Training &
 Licensee Examination
 F-Administrative
 G-Operational Error
 (Explain)
 H-Other (Explain)

³
 Method:
 1-Manual
 2-Manual Scram.
 3-Automatic Scram.
 4-Other (Explain)

⁴
 Exhibit G - Instructions
 for Preparation of Data
 Entry Sheets for
 Licensee Event Report
 (LER) File (NUREG-
 0161)

⁵
 Exhibit 1- Same Source

NARRATIVE SUMMARY OF OPERATING EXPERIENCE

DOCKET NO: 50-244

UNIT: R.E. Ginna Nuclear Power Plant

DATE: January 8, 1997

COMPLETED BY: John Walden

TELEPHONE: (716) 771-3588

MONTH December, 1996

The unit operated all full power for the entire month of December.
The average power level was 99.9%.

Distribution Sheet

50-244
Priority: Normal

From: Stefanie Fountain

Action Recipients:

G Vissing

Copies:

1

Paper Copy

Internal Recipients:

RidsRgn1MailCenter

0

OK

RidsResDraaOerab

0

OK

RidsOcfoDpbaPab

0

OK

RidsManager

0

OK

RidsAcraAcnwMailCenter

0

OK

RGN1.

1

Paper Copy

RES/DRAA/OERAB

1

Paper Copy

~~OCFO/DPBA~~

1

Paper Copy

~~FILE CENTER-01~~

1

Paper Copy

ACRS

1

Paper Copy

External Recipients:

NOAC

1

Paper Copy

INEEL Marshall

1

Paper Copy

Total Copies:

8

Item: ADAMS Document

Library: ML_ADAMS^HQNTAD01

ID: 003694568:1

Subject:

Monthly Report for February, 2000 Operating Status Information R.E. Ginna Nuclear Power Plant

Body:

ADAMS DISTRIBUTION NOTIFICATION.

Electronic Recipients can RIGHT CLICK and OPEN the first Attachment to View the Document in ADAMS. The Document may also be viewed by searching for Accession Number ML003694568.

MR

Distri62.txt

IE24 - Monthly Operating Report (per Tech Specs)

Docket: 05000244



ROCHESTER GAS AND ELECTRIC CORPORATION • 89 EAST AVENUE, ROCHESTER, N.Y. 14649-0001
AREA CODE 716-546-2700



March 10, 2000

US Nuclear Regulatory Commission
Document Control Desk
Attn: Guy S. Vissing
Project Directorate I-1
Washington, DC 20555

Subject: Monthly Report for February, 2000
Operating Status Information
R.E. Ginna Nuclear Power Plant
Docket No. 50-244

Dear Mr. Vissing:

Pursuant to Ginna Improved Technical Specifications Section 5.6.4, attached is the monthly operating status report for Ginna Station for the month of February, 2000.

Very truly yours,

Robert Lopp (FOR)
Joseph A. Widay
Plant Manager

xc: U.S. Nuclear Regulatory Commission
Mr. Guy S. Vissing (Mail Stop 14B2)
Project Directorate I-1
Washington, D.C. 20555

U.S. Nuclear Regulatory Commission
Region I
475 Allendale Road
King of Prussia, PA 19406

U.S. NRC Ginna Senior Resident Inspector

Attachments

003694568

IE24

OPERATING DATA REPORT

-1-

50-244

March 10, 2000

COMPLETED BY:

John V. Walden
John V. Walden

TELEPHONE (716) 771-3588

OPERATING STATUS

1. Unit Name: R.E. GINNA NUCLEAR POWER PLANT
2. Reporting Period: February, 2000
3. Design Electric Rating (Net MWe): 470
4. Maximum Dependable Capacity (Net MWe): 480

Notes:

| | This Month | Yr.-to-Date | Cumulative** |
|--|-----------------|-----------------|-------------------|
| 5. Number of hours Reactor Was Critical | <u>696.0</u> | <u>1440.0</u> | <u>215654.0</u> |
| 6. Hours Generator On-line | <u>696.0</u> | <u>1440.0</u> | <u>212583.9</u> |
| 7. Unit Reserve Shutdown Hours | <u>0.0</u> | <u>0.0</u> | <u>8.5 *</u> |
| 8. Net Electrical Energy Generated (MWH) | <u>331765.0</u> | <u>700301.0</u> | <u>96085436.4</u> |

** CUMULATIVE TOTAL COMMENCING NOVEMBER 8, 1969

DOCKET NO: 50-244
UNIT NAME: R.E. GINNA NUCLEAR POWER PLANT
DATE: March 10, 2000
COMPLETED BY: John V. Walden
TELEPHONE: (716) 771-3588

UNIT SHUTDOWN

REPORTING PERIOD: February, 2000
(Month/Year)

| NO. | DATE | TYPE | DURATION (HOURS) | REASON ⁽¹⁾ | METHOD OF SHUTTING DOWN ⁽²⁾ | CAUSE/CORRECTIVE ACTIONS |
|-----|------|---------------------------|---------------------|-----------------------|--|--------------------------|
| | | F: FORCED S: SCHEDULED | | | | COMMENTS |
| | | | | | | |

SUMMARY:

The unit experienced two power reductions due to frazil ice formation on the intake structure. The events occurred on February 8 and 12. Power was reduced to approximately 40% during each occurrence. Average power for the month of February was 96.5%.

(1) Reason

- A - Equipment Failure (Explain)
- B - Maintenance or Test
- C - Refueling
- D - Regulatory Restriction
- E - Operator Training/License Examination
- F - Administrative
- G - Operational Error (Explain)
- H - Other (Explain)

(2) Method

- 1 - Manual
- 2 - Manual Trip/Scram
- 3 - Automatic Trip/Scram
- 4 - Continuation
- 5 - Other (Explain)

Distribution Sheet

50-244
Priority: Normal

2/7/00

From: Patricia Exum

Action Recipients: .. Copies:
G Vissing 1 Paper Copy

Internal Recipients:
RidsRgn1MailCenter 0 OK
RidsResDraaOerab 0 OK
RidsManager 0 OK
RidsAcrsAcnwMailCenter 0 OK
RGN1 1 Paper Copy
RES/DRAA/OERAB 1 Paper Copy
OCFO/DPBA 1 Paper Copy
FILE CENTER 01 1 Paper Copy
ACRS 1 Paper Copy

External Recipients:
NOAC 1 Paper Copy
INEEL Marshall 1 Paper Copy

Total Copies: 8

Item: ADAMS Document
Library: ML_ADAMS^HQNTAD01
ID: 003685028:1

Subject:
Monthly Report for January, 2000 Operating Status Information R.E. Ginna Nuclear Power Plant

Body:
ADAMS DISTRIBUTION NOTIFICATION.

Electronic Recipients can RIGHT CLICK and OPEN the first Attachment to View the Document in ADAMS. The Document may also be viewed by searching for Accession Number ML003685028.

MR



1955

1955

Distri49.txt

IE24 - Monthly Operating Report (per Tech Specs)

Docket: 05000244



ROCHESTER GAS AND ELECTRIC CORPORATION • 89 EAST AVENUE, ROCHESTER, N.Y. 14649-0001
AREA CODE 716-546-2700



February 7, 2000

US Nuclear Regulatory Commission
Document Control Desk
Attn: Guy S. Vissing
Project Directorate I-1
Washington, DC 20555

Subject: Monthly Report for January, 2000
Operating Status Information
R.E. Ginna Nuclear Power Plant
Docket No. 50-244

Dear Mr. Vissing:

Pursuant to Ginna Improved Technical Specifications Section 5.6.4, attached is the monthly operating status report for Ginna Station for the month of January, 2000.

Very truly yours,

Joseph A. Widay
Joseph A. Widay
Plant Manager

xc: U.S. Nuclear Regulatory Commission
Mr. Guy S. Vissing (Mail Stop 14B2)
Project Directorate I-1
Washington, D.C. 20555

U.S. Nuclear Regulatory Commission
Region I
475 Allendale Road
King of Prussia, PA 19406

U.S. NRC Ginna Senior Resident Inspector

Attachments

ML003685028

IE24

OPERATING DATA REPORT

-1-

50-244

February 7, 2000

COMPLETED BY:

John V. Walden
John V. Walden

TELEPHONE (716) 771-3588

OPERATING STATUS

1. Unit Name: R.E. GINNA NUCLEAR POWER PLANT

Notes:

2. Reporting Period: January, 2000

3. Design Electric Rating (Net MWe): 470

4. Maximum Dependable Capacity (Net MWe): 480

| | This Month | Yr.-to-Date | Cumulative** |
|--|-----------------|-----------------|-------------------|
| 5. Number of hours Reactor Was Critical | <u>744.0</u> | <u>744.0</u> | <u>214958.0</u> |
| 6. Hours Generator On-line | <u>744.0</u> | <u>744.0</u> | <u>211887.9</u> |
| 7. Unit Reserve Shutdown Hours | <u>0.0</u> | <u>0.0</u> | <u>8.5 *</u> |
| 8. Net Electrical Energy Generated (MWH) | <u>368536.0</u> | <u>368536.0</u> | <u>95753671.4</u> |

** CUMULATIVE TOTAL COMMENCING NOVEMBER 8, 1969

DOCKET NO: 50-244
UNIT NAME: R.E. GINNA NUCLEAR POWER PLANT
DATE: February 7, 2000
COMPLETED BY: John V. Walden
TELEPHONE: (716) 771-3588

UNIT SHUTDOWN

REPORTING PERIOD: January, 2000
(Month/Year)

| NO. | DATE | TYPE | DURATION (HOURS) | REASON ⁽¹⁾ | METHOD OF SHUTTING DOWN ⁽²⁾ | CAUSE/CORRECTIVE ACTIONS |
|-----|------|---------------------------|---------------------|-----------------------|--|--------------------------|
| | | F: FORCED S: SCHEDULED | | | | COMMENTS |
| | | | | | | |

SUMMARY:

The unit operated at full power for the entire month of January. Average power for the month was 99.8%.

(1) Reason

- A - Equipment Failure (Explain)
- B - Maintenance or Test
- C - Refueling
- D - Regulatory Restriction
- E - Operator Training/License Examination
- F - Administrative
- G - Operational Error (Explain)
- H - Other (Explain)

(2) Method

- 1 - Manual
- 2 - Manual Trip/Scram
- 3 - Automatic Trip/Scram
- 4 - Continuation
- 5 - Other (Explain)



ROCHESTER GAS AND ELECTRIC CORPORATION • 89 EAST AVENUE, ROCHESTER, N.Y. 14649-0001
AREA CODE 716-546-2700



January 10, 2000

US Nuclear Regulatory Commission
Document Control Desk
Attn: Guy S. Vissing
Project Directorate I-1
Washington, DC 20555

Subject: Monthly Report for December, 1999
Operating Status Information
R.E. Ginna Nuclear Power Plant
Docket No. 50-244

Dear Mr. Vissing:

Pursuant to Ginna Improved Technical Specifications Section 5.6.4, attached is the monthly operating status report for Ginna Station for the month of December, 1999.

Very truly yours,

Joseph A. Widay
Joseph A. Widay
Plant Manager

xc: U.S. Nuclear Regulatory Commission
Mr. Guy S. Vissing (Mail Stop 14B2)
Project Directorate I-1
Washington, D.C. 20555

U.S. Nuclear Regulatory Commission
Region I
475 Allendale Road
King of Prussia, PA 19406

U.S. NRC Ginna Senior Resident Inspector

Attachments

M1003676972

IE24

OPERATING DATA REPORT

-1-

50-244

January 10, 2000

COMPLETED BY:

John V. Walden
John V. Walden

TELEPHONE (716) 771-3588

OPERATING STATUS

1. Unit Name: R.E. GINNA NUCLEAR POWER PLANT
2. Reporting Period: December, 1999
3. Design Electric Rating (Net MWe): 470
4. Maximum Dependable Capacity (Net MWe): 480

Notes:

| | This Month | Yr.-to-Date | Cumulative** |
|--|-----------------|------------------|-------------------|
| 5. Number of hours Reactor Was Critical | <u>744.0</u> | <u>7494.8</u> | <u>214214.0</u> |
| 6. Hours Generator On-line | <u>744.0</u> | <u>7445.2</u> | <u>211143.9</u> |
| 7. Unit Reserve Shutdown Hours | <u>0.0</u> | <u>0.0</u> | <u>8.5 *</u> |
| 8. Net Electrical Energy Generated (MWH) | <u>368290.0</u> | <u>3534055.0</u> | <u>95385135.4</u> |

** CUMULATIVE TOTAL COMMENCING NOVEMBER 8, 1969

DOCKET NO: 50-244
UNIT NAME: R.E. GINNA NUCLEAR POWER PLANT
DATE: January 10, 2000
COMPLETED BY: John V. Walden
TELEPHONE: (716) 771-3588

UNIT SHUTDOWN

REPORTING PERIOD: December, 1999
(Month/Year)

| NO. | DATE | TYPE | DURATION (HOURS) | REASON ⁽¹⁾ | METHOD OF SHUTTING DOWN ⁽²⁾ | CAUSE/CORRECTIVE ACTIONS |
|-----|------|---------------------------|---------------------|-----------------------|--|--------------------------|
| | | F: FORCED S: SCHEDULED | | | | COMMENTS |
| | | | | | | |

SUMMARY:

The unit operated at full power for the entire month of December. Average power for the month was 99.8%.

(1) Reason

- A - Equipment Failure (Explain)
- B - Maintenance or Test
- C - Refueling
- D - Regulatory Restriction
- E - Operator Training/License Examination
- F - Administrative
- G - Operational Error (Explain)
- H - Other (Explain)

(2) Method

- 1 - Manual
- 2 - Manual Trip/Scram
- 3 - Automatic Trip/Scram
- 4 - Continuation
- 5 - Other (Explain)

Distribution Sheet

Priority: Normal

From: Elaine Walker

Action Recipients:

G Vissing

Copies:

1

Not Found

Internal Recipients:

RGN1

1

Not Found

RES/DRAA/OERAB

1

Not Found

OCFO/DPBA

1

Not Found

FILE CENTER 01

1

Not Found

ACRS

1

Not Found

External Recipients:

NOAC

1

Not Found

INEEL Marshall

1

Not Found

Total Copies:

8

Item: ADAMS Document

Library: ML_ADAMS^HQNTAD01

ID: 003676972

Subject:

Monthly Report for December, 1999 Operating Status Information R.E. Ginna Nuclear Power Plant Docket No. 50-244. With January 10, 2000 letter.

Body:

Docket: 05000244, Notes: License Exp date in accordance with 10CFR2.2.109(9/19/72).

Distribution Sheet

Priority: Normal

12/7/99

From: Stefanie Fountain

Action Recipients:

G Vissing

Copies:

1

Not Found

Internal Recipients:

RGN 1.

1

Not Found

RES/DRAA/OERAB

1

Not Found

OC/DBA/PAD

1

Not Found

FILE CENTER 01

1

Not Found

ACRS

1

Not Found

External Recipients:

NRC PDR

1

Not Found

NOAC

1

Not Found

INEEL Marshall

1

Not Found

Total Copies:

9

Item: ADAMS Document

Library: ML_ADAMS^HQNTAD01

ID: 993480495

Subject:

Monthly operating report for November 1999 for R. E. Ginna Nuclear Power Plant. With letter dated 12/7/99.

Body:

PDR ADOCK 05000244 R

Docket: 05000244, Notes: License Exp date in accordance with 10CFR2.2.109(9/19/72).



ROCHESTER GAS AND ELECTRIC CORPORATION • 89 EAST AVENUE, ROCHESTER, N.Y. 14649-0001
AREA CODE 716-546-2700



December 7, 1999

US Nuclear Regulatory Commission
Document Control Desk
Attn: Guy S. Vissing
Project Directorate I-1
Washington, DC 20555

Subject: Monthly Report for November, 1999
Operating Status Information
R.E. Ginna Nuclear Power Plant
Docket No. 50-244

Dear Mr. Vissing:

Pursuant to Ginna Improved Technical Specifications Section 5.6.4, attached is the monthly operating status report for Ginna Station for the month of November, 1999.

Very truly yours,

Joseph A. Widay
Joseph A. Widay
Plant Manager

xc: U.S. Nuclear Regulatory Commission
Mr. Guy S. Vissing (Mail Stop 14B2)
Project Directorate I-1
Washington, D.C. 20555

U.S. Nuclear Regulatory Commission
Region I
475 Allendale Road
King of Prussia, PA 19406

U.S. NRC Ginna Senior Resident Inspector

Attachments

IE24

993480495

POR APOCK 05000244

OPERATING DATA REPORT

-1-

50-244

December 7, 1999

COMPLETED BY:

John V. Walden
John V. Walden

TELEPHONE (716) 771-3588

OPERATING STATUS

1. Unit Name: R.E. GINNA NUCLEAR POWER PLANT
2. Reporting Period: November, 1999
3. Design Electric Rating (Net MWe): 470
4. Maximum Dependable Capacity (Net MWe): 480

Notes:

| | This Month | Yr.-to-Date | Cumulative** |
|--|-----------------|------------------|-------------------|
| 5. Number of hours Reactor Was Critical | <u>720.0</u> | <u>6750.8</u> | <u>213470.0</u> |
| 6. Hours Generator On-line | <u>720.0</u> | <u>6701.2</u> | <u>210399.9</u> |
| 7. Unit Reserve Shutdown Hours | <u>0.0</u> | <u>0.0</u> | <u>8.5 *</u> |
| 8. Net Electrical Energy Generated (MWH) | <u>348064.0</u> | <u>3165765.0</u> | <u>95016845.4</u> |

** CUMULATIVE TOTAL COMMENCING NOVEMBER 8, 1969

DOCKET NO: 50-244
UNIT NAME: R.E. GINNA NUCLEAR POWER PLANT
DATE: December 7, 1999
COMPLETED BY: John V. Walden
TELEPHONE: (716) 771-3588

UNIT SHUTDOWN

REPORTING PERIOD: November, 1999
(Month/Year)

| NO. | DATE | TYPE | DURATION (HOURS) | REASON ⁽¹⁾ | METHOD OF SHUTTING DOWN ⁽²⁾ | CAUSE/CORRECTIVE ACTIONS |
|-----|------|---------------------------|---------------------|-----------------------|--|--------------------------|
| | | F: FORCED S: SCHEDULED | | | | COMMENTS |
| | | | | | | |

SUMMARY:

Power was reduced to approximately 50% for a planned condenser waterbox inspection on November 13, 1999. The unit operated at full power prior to and after the inspection. Average power for the month was 97.7%.

(1) Reason

- A - Equipment Failure (Explain)
- B - Maintenance or Test
- C - Refueling
- D - Regulatory Restriction
- E - Operator Training/License Examination
- F - Administrative
- G - Operational Error (Explain)
- H - Other (Explain)

(2) Method

- 1 - Manual
- 2 - Manual Trip/Scram
- 3 - Automatic Trip/Scram
- 4 - Continuation
- 5 - Other (Explain)

11 22 25



ROCHESTER GAS AND ELECTRIC CORPORATION • 89 EAST AVENUE, ROCHESTER, N.Y. 14649-0001
AREA CODE 716-546-2700



November 10, 1999

US Nuclear Regulatory Commission
Document Control Desk
Attn: Guy S. Vissing
Project Directorate I-1
Washington, DC 20555

Subject: Monthly Report for October, 1999
Operating Status Information
R.E. Ginna Nuclear Power Plant
Docket No. 50-244

Dear Mr. Vissing:

Pursuant to Ginna Improved Technical Specifications Section 5.6.4, attached is the monthly operating status report for Ginna Station for the month of October, 1999.

Very truly yours,

Joseph A. Widay
Joseph A. Widay
Plant Manager

xc: U.S. Nuclear Regulatory Commission
Mr. Guy S. Vissing (Mail Stop 14B2)
Project Directorate I-1
Washington, D.C. 20555

U.S. Nuclear Regulatory Commission
Region I
475 Allendale Road
King of Prussia, PA 19406

U.S. NRC Ginna Senior Resident Inspector

Attachments

0500244 R
10/31/99

JE24

993240386



2-1

2-2

OPERATING DATA REPORT

-1-

50-244

November 10, 1999

COMPLETED BY:

John V. Walden

John V. Walden

TELEPHONE (716) 771-3588

OPERATING STATUS

1. Unit Name: R.E. GINNA NUCLEAR POWER PLANT

Notes:

2. Reporting Period: October, 1999

3. Design Electric Rating (Net MWe): 470

4. Maximum Dependable Capacity (Net MWe): 480

| | This Month | Yr.-to-Date | Cumulative** |
|--|-----------------|------------------|-------------------|
| 5. Number of hours Reactor Was Critical | <u>745.0</u> | <u>6030.8</u> | <u>212750.0</u> |
| 6. Hours Generator On-line | <u>745.0</u> | <u>5981.2</u> | <u>209679.9</u> |
| 7. Unit Reserve Shutdown Hours | <u>0.0</u> | <u>0.0</u> | <u>8.5 *</u> |
| 8. Net Electrical Energy Generated (MWH) | <u>366752.0</u> | <u>2817701.0</u> | <u>94668781.4</u> |

** CUMULATIVE TOTAL COMMENCING NOVEMBER 8, 1969



THE UNIVERSITY OF CHICAGO

1964

1964

1964

1964

1964

1964

1964

1964

1964

1964

1964

1964

1964

1964

1964

1964

1964

1964

1964

DOCKET NO: 50-244
UNIT NAME: R.E. GINNA NUCLEAR POWER PLANT
DATE: November 10, 1999
COMPLETED BY: John V. Walden
TELEPHONE: (716) 771-3588

UNIT SHUTDOWN

REPORTING PERIOD: October, 1999
(Month/Year)

| NO. | DATE | TYPE | DURATION (HOURS) | REASON ⁽¹⁾ | METHOD OF SHUTTING DOWN ⁽²⁾ | CAUSE/CORRECTIVE ACTIONS |
|-----|------|---------------------------|---------------------|-----------------------|--|--------------------------|
| | | F: FORCED S: SCHEDULED | | | | COMMENTS |
| | | | | | | |

SUMMARY:

The unit operated at full power for the entire month of October. Average power for the month was 99.7%.

(1) Reason

- A - Equipment Failure (Explain)
- B - Maintenance or Test
- C - Refueling
- D - Regulatory Restriction
- E - Operator Training/License Examination
- F - Administrative
- G - Operational Error (Explain)
- H - Other (Explain)

(2) Method

- 1 - Manual
- 2 - Manual Trip/Scram
- 3 - Automatic Trip/Scram
- 4 - Continuation
- 5 - Other (Explain)

NOV 1 6 1999

Distribution Sheet

Priority: Normal

From: Stefanie Fountain

Action Recipients:

G Vissing

Copies:

1

Not Found

Internal Recipients:

RGN 1 .

1

Not Found

RES/DRAA/OERAB

1

Not Found

OC/DBA/PAD

1

Not Found

FILE CENTER 01

1

Not Found

ACRS

1

Not Found

External Recipients:

NRC PDR

1

Not Found

NOAC

1

Not Found

INEEL Marshall

1

Not Found

Total Copies:

9

Item: ADAMS Document

Library: ML_ADAMS^HQNTAD01

ID: 993240386

Subject:

Monthly Report for October,1999 Operating Status for RE Ginna Nuclear Power Plant

Body:

PDR ADOCK 05000244 R

Docket: 05000244, Notes: License Exp date in accordance with 10CFR2,2.109(9/19/72).