

# CATEGORY 1

REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR: 9703180052      DOC. DATE: 97/02/28      NOTARIZED: NO      DOCKET #  
 FACID: 50-244 Robert Emmet Ginna Nuclear Plant, Unit 1, Rochester, G      05000244  
 AUTH. NAME      AUTHOR AFFILIATION  
 WALDEN, J.V.      Rochester Gas & Electric Corp.  
 WIDAY, J.A.      Rochester Gas & Electric Corp.  
 RECIP. NAME      RECIPIENT AFFILIATION  
 VISSING, G.S.

SUBJECT: Monthly operating rept for Feb 1997 for R.E. Ginna Nuclear  
 Power Plant. W/970307 ltr.

DISTRIBUTION CODE: IE24D      COPIES RECEIVED: LTR 1 ENCL 1 SIZE: 5  
 TITLE: Monthly Operating Report (per Tech Specs)

NOTES: License Exp date in accordance with 10CFR2,2.109(9/19/72).      05000244

	RECIPIENT ID CODE/NAME	COPIES LTTR ENCL	RECIPIENT ID CODE/NAME	COPIES LTTR ENCL
	PDL-1 PD	1 1	VISSING, G.	1 1
INTERNAL:	AEOD/SPD/RRAB	1 1	<u>FILE CENTER 01</u>	1 1
	NRR/DRPM/PECB	1 1	OC/DBA/PAD	1 1
	RGN1	1 1		
EXTERNAL:	LITCO BRYCE, J H	1 1	NOAC	1 1
	NRC PDR	1 1		

NOTE TO ALL "RIDS" RECIPIENTS:  
 PLEASE HELP US TO REDUCE WASTE! CONTACT THE DOCUMENT CONTROL DESK,  
 ROOM OWFN 5D-5 (EXT. 415-2083) TO ELIMINATE YOUR NAME FROM  
 DISTRIBUTION LISTS FOR DOCUMENTS YOU DON'T NEED!

TOTAL NUMBER OF COPIES REQUIRED: LTTR 10 ENCL 10

*MRE*

C  
A  
T  
E  
G  
O  
R  
Y  
  
1  
  
D  
O  
C  
U  
M  
E  
N  
T





ROCHESTER GAS AND ELECTRIC CORPORATION • 89 EAST AVENUE, ROCHESTER, N.Y. 14649-0001



TELEPHONE  
AREA CODE 716 546-2700

March 7, 1997

US Nuclear Regulatory Commission  
Document Control Desk  
Attn: Guy S. Vissing  
Project Directorate I-1  
Washington, DC 20555

Subject: Monthly Report for February, 1997  
Operating Status Information  
R.E. Ginna Nuclear Power Plant  
Docket No. 50-244

Dear Mr. Vissing:

Pursuant to Ginna Improved Technical Specifications Section 5.6.4, attached is the monthly operating status report for Ginna Station for the month of February, 1997.

Very truly yours,

*Joseph A. Widay*  
Joseph A. Widay  
Plant Manager

xc: U.S. Nuclear Regulatory Commission  
Mr. Guy S. Vissing (Mail Stop 14C7)  
Project Directorate I-1  
Washington, D.C. 20555

U.S. Nuclear Regulatory Commission  
Region I  
475 Allendale Road  
King of Prussia, PA 19406

U.S. NRC Ginna Senior Resident Inspector

Attachments

*IE241*

9703180052 970228  
PDR ADOCK 05000244  
R PDR

180020



# OPERATING DATA REPORT

-1-

50-244

March 7, 1997

COMPLETED BY:

John V. Walden

TELEPHONE (716) 771-3588

## OPERATING STATUS

1. Unit Name: R.E. GINNA NUCLEAR POWER PLANT Notes:
2. Reporting Period: February, 1997
3. Licensed Thermal Power (MWt): 1520
4. Nameplate Rating (Gross MWe): 517
5. Design Electric Rating (Net MWe): 470
6. Maximum Dependable Capacity (Gross MWe): 490
7. Maximum Dependable Capacity (Net MWe): 480
8. If Changes Occur In Capacity Rating (Items Number 3 Through 7) Since Last Report, Give Reason:

9. Power Level to Which Restricted, If Any (Net MWe):

10. Reason For Restrictions, If Any:

	This Month	Yr.-to-Date	Cumulative**
11. Hours in Reported Period	672.0	1416.0	238968.0
12. Number of hours Reactor Was Critical	672.0	1416.0	191330.3
13. Reactor Reserve Shutdown Hours	0.0	0.0	1687.6 *
14. Hours Generator On-line	672.0	1416.0	188342.5
15. Unit Reserve Shutdown Hours	0.0	0.0	8.5 *
16. Gross Thermal Energy Generated (MWH)	1018091.0	2147103.0	268023373.0
17. Gross Electrical Energy Generated (MWH)	348586.0	735417.0	88845726.0
18. Net Electrical Energy Generated (MWH)	332129.0	700705.0	84346571.8
19. Unit Service Factor (%)	100.0	100.0	78.8
20. Unit Availability Factor (%)	100.0	100.0	78.8
21. Unit Capacity Factor (using MDC Net) (%)	103.0	103.1	76.1
22. Unit Capacity Factor (using DER Net) (%)	103.0	103.1	76.1
23. Unit Forced Outage Rate (%)	0.0	0.0	5.7

24. Shutdowns Scheduled Over Next 6 Months (Type, Date and Duration of Each):

25. If Shutdown At End of Report Period, Estimate Date of Startup:

26. Units in Test Status (Prior to Commercial Operation):

Forecast

Achieved

INITIAL CRITICALITY

INITIAL ELECTRICITY

COMMERCIAL OPERATION

\* CUMULATIVE TOTAL COMMENCING JANUARY 1, 1975

\*\* CUMULATIVE TOTAL COMMENCING NOVEMBER 8, 1969

AVERAGE DAILY UNIT POWER LEVEL

DOCKET NO: 50-244

UNIT: R.E. Ginna Nuclear Power Plant

DATE: March 7, 1997

COMPLETED BY: John V. Walden

John Walden

TELEPHONE: (716) 771-3588

MONTH February, 1997

DAY AVERAGE DAILY POWER LEVEL  
(MWe-Net)

1.	<u>496</u>
2.	<u>496</u>
3.	<u>496</u>
4.	<u>495</u>
5.	<u>495</u>
6.	<u>495</u>
7.	<u>495</u>
8.	<u>495</u>
9.	<u>495</u>
10.	<u>495</u>
11.	<u>486</u>
12.	<u>481</u>
13.	<u>494</u>
14.	<u>495</u>
15.	<u>495</u>
16.	<u>495</u>

DAY AVERAGE DAILY POWER LEVEL  
(MWe-Net)

17.	<u>495</u>
18.	<u>495</u>
19.	<u>495</u>
20.	<u>495</u>
21.	<u>496</u>
22.	<u>496</u>
23.	<u>495</u>
24.	<u>495</u>
25.	<u>496</u>
26.	<u>496</u>
27.	<u>496</u>
28.	<u>495</u>
29.	<u>---</u>
30.	<u>---</u>
31.	<u>---</u>

INSTRUCTIONS

On this format, list the average daily unit power level in MWe-Net for each day in reporting month. Compute to the nearest whole megawatt.

DOCKET NO: 50-244  
UNIT: R.E. GINNA NUCLEAR POWER PLANT  
DATE: March 7, 1997  
COMPLETED BY: John Walden  
John Walden  
TELEPHONE: (716) 771-3588

### UNIT SHUTDOWN AND POWER REDUCTIONS

REPORT MONTH February, 1997

No.	Date	Type <sup>1</sup>	Duration (hours)	Reason <sup>2</sup>	Method of shuting down reactors <sup>3</sup>	Licensee Event Report #	System Code <sup>4</sup>	Component Code <sup>5</sup>	Cause & Corrective Action to Prevent Recurrence

1  
F: Forced  
S: Scheduled

2  
Reason:  
A-Equipment (Explain)  
B-Maintenance or Test  
C-Refueling  
D-Regulatory  
E-Operator Training &  
Licensee Examination  
F-Administrative  
G-Operational Error  
(Explain)  
H-Other (Explain)

3  
Method:  
1-Manual  
2-Manual Scram.  
3-Automatic Scram.  
4-Other (Explain)

4  
Exhibit G - Instructions  
for Preparation of Data  
Entry Sheets for  
Licensee Event Report  
(LER) File (NUREG-  
0161)

5  
Exhibit 1- Same Source

NARRATIVE SUMMARY OF OPERATING EXPERIENCE

DOCKET NO: 50-244

UNIT: R.E. Ginna Nuclear Power Plant

DATE: March 7, 1997

COMPLETED BY: John V. Walden  
John Walden

TELEPHONE: (716) 771-3588

MONTH February, 1997

The unit operated all full power for the entire month of February.  
The average power level was 99.7%.

